



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Craig W. Butler, Interim Director

OHIO E.P.A.

JAN 15 2014

ENTERED DIRECTOR'S JOURNAL

I certify this to be a true and accurate copy of the official documents as filed in the records of the Ohio Environmental Protection Agency.

By: Donna Lassiter Date: 1-15-14

Dan Kiely
301 North Clematis St, Suite 3000
West Palm Beach, FL 33401

Effective Date: JAN 15 2014

Certified Mail
9171082133393715015463

Re: 2014 Conditioned License to Operate a Public Water System

Dear Mr. Kiely:

Enclosed is the 2014 license to operate (LTO) a public water system (PWS) for the Glen at State Line Mobile Home Park #2 (MHP2) (PWS ID# OH5002112). In accordance with Ohio Revised Code (ORC) § 6109.21 and Ohio Administrative Code (OAC) Rule 3745-84-06, the LTO is hereby issued with conditions due to violations of drinking water regulations at the PWS. In accordance with OAC Rule 3745-84-04, PWSs are required to display the yellow, conditioned license at the office of the PWS where it is clearly visible to the residents and general public, and to notify the residents of the conditioned status of the license in the Consumer Confidence Report (CCR), pursuant to OAC Chapter 3745-96.

The LTO is conditioned through January 30, 2015, with the following requirements:

1. Comply with all LTO renewal requirements, in accordance with OAC Chapter 3745-84.
2. Comply with all current and subsequent monitoring schedules issued by the Director, in accordance with OAC Chapter 3745-81.
3. Comply with total coliform bacteria monitoring requirements, including both routine and repeat sampling and ground water rule sampling, in accordance with OAC Rule 3745-81-21 and OAC Rule 3745-81-42.
4. Comply with the total coliform maximum contaminant level (MCL), in accordance with OAC Rule 3745-81-14.

5. Issue public notices for all violations, in accordance with OAC Rule 3745-81-32.
6. By July 1, 2014, provide to customers a CCR containing data collected during or prior to the previous calendar year, and provide a copy of the CCR distributed and a distribution certification to the Director, in accordance with OAC Chapter 3745-96.
7. Complete all applicable requirements in accordance with OAC Rules 3745-81-81, 3745-81-82, and 3745-81-85, to address the Lead 90th percentile action level exceedance including, but not limited to:
 - a. installing the orthophosphate feed equipment approved on December 19th, 2012 by no later than September 30, 2014;
 - b. complying with all of the conditions identified in the Director's plan approval letters dated December 19, 2012).


If the requirements of the conditioned LTO are fulfilled, the PWS may be eligible for a green, unconditioned license in the next renewal period. Should the PWS fail to comply with these conditions, the LTO may be suspended or revoked. A PWS with a suspended LTO may only operate as authorized by the Director, and a PWS with a revoked LTO is prohibited from producing water for human consumption. Human consumption is defined in OAC Rule 3745-81-01 to include, but is not limited to, drinking, food preparation, dishwashing, and hand washing. Additionally, owners and/or operators who fail to comply with Ohio's safe drinking water laws are subject to civil penalties of up to \$25,000.00 per day per violation under ORC § 6109.33. Operating with a suspended or revoked LTO may jeopardize other licenses, including the mobile home park license.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to ORC § 3745.04. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
77 South High Street, 17th Floor
Columbus, OH 43215

If you have any questions regarding this action, please contact Anne Speakman at (614) 644-2752.

Sincerely,

A handwritten signature in black ink that reads "Craig W. Butler". The signature is written in a cursive style with a large initial "C" and a long horizontal stroke at the end.

Craig W. Butler, Interim Director
Ohio Environmental Protection Agency

cc: Mahoning County Health Department
Edward Janosky, Operator in Charge

ec: Holly Kaloz, Manager, DDAGW-CO
Julie Spangler, Supervisor, DDAGW-CO
Nancy Rice, Manager, DDAGW-NEDO
Dave Maschak, DOCC, DDAGW-NEDO
Stivo DiFranco, Supervisor, DDAGW-NEDO
Chris Maslo, DDAGW-NEDO
Kimberly Rhoads, Office of Legal Services
Ohio Manufactured Homes Commission



State of Ohio Environmental Protection Agency

CONDITIONAL LICENSE TO OPERATE OR MAINTAIN A PUBLIC WATER SYSTEM

THE OHIO EPA, PURSUANT TO SECTION 6109.21 OF THE OHIO REVISED CODE, HEREBY ISSUES THIS
LICENSE TO OPERATE OR MAINTAIN A PUBLIC WATER SYSTEM TO

GLEN AT STATE LINE MHP 2 PWS

PWS ID: OH5002112

THE LICENSEE IS OBLIGATED TO ENSURE THAT THE PUBLIC WATER SYSTEM IS OPERATED AND
MAINTAINED IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 6109 OF THE OHIO REVISED
CODE, ALL OTHER APPLICABLE STATUTES AND THE ADMINISTRATIVE RULES ADOPTED THEREUNDER.

THIS LICENSE WILL EXPIRE ON JANUARY 30, 2015

APPLICATION FOR RENEWAL IS REQUIRED TO BE SUBMITTED TO THE OHIO EPA AT LEAST THIRTY
DAYS PRIOR TO THIS DATE.

EFFECTIVE DATE: **JANUARY 15, 2014**

EXPIRATION DATE: **JANUARY 30, 2015**

LICENSE NUMBER: **5002112-954479-2014**

A handwritten signature in black ink that reads "Craig W. Butler". The signature is written in a cursive style and is positioned above a horizontal line.

Craig W. Butler, Interim Director

THE GLEN AT STATE LINE MOBILE HOME PARK 2 CONDITIONS

Effective Date: January 15, 2014

The LTO is conditioned through January 30, 2015, with the following requirements:

1. Comply with all LTO renewal requirements.
2. Comply with all current and subsequent chemical monitoring schedules.
3. Comply with total coliform bacteria monitoring requirements, including both routine and repeat samples.
4. Comply with the total coliform maximum contaminant level.
5. Issue public notices for all violations.
6. By July 1, 2014 provide to customers a CCR containing data collected during or prior to the previous year.
7. Complete all applicable requirements to address the Lead 90th percentile action level including:
 - a) installing the approved orthophosphate feed equipment by September 30, 2014;
 - b) complying with all of the conditions identified in the Director's plan approval letters;