

3745-91-09

Iron and manganese treatment.

(A) New community water systems shall provide treatment for removal of the following:

- (1) Iron to meet the secondary maximum contaminant level (SMCL) set forth in rule 3745-82-02 of the Administrative Code when the level of iron in water entering the water plant exceeds the ~~secondary maximum contaminant level;~~ and SMCL.
- (2) Manganese to meet the ~~secondary maximum contaminant level~~ SMCL set forth in rule 3745-82-02 of the Administrative Code when the level of manganese in water entering the water plant exceeds the ~~secondary maximum contaminant level~~ SMCL.

(B) Existing community water systems, which develop a new source, or change a source shall provide treatment for removal of the following:

- (1) Iron to meet the SMCL set forth in rule 3745-82-02 of the Administrative Code, if the level of iron at the entry point to the distribution system increases and exceeds the ~~secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code.;~~ and SMCL.
- (2) Manganese to meet the SMCL in rule 3745-82-02 of the Administrative Code, if the level of manganese at the entry point to the distribution system increases and exceeds the ~~secondary maximum contaminant level set forth in rule 3745-82-02 of the Administrative Code~~ SMCL.

Effective:

Five Year Review (FYR) Dates: 07/26/2016

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 6109.04
Rule Amplifies: 6109.03, 6109.04
Prior Effective Dates: 11/26/80, 01/01/02