

TO BE RESCINDED

3745-95-07

Booster pumps.

- (A) No person shall install or maintain a water service connection to any one, two or three family dwelling where a booster pump has been installed, unless an air gap separation is provided to ensure that the booster pump cannot exert suction on the service line.
- (B) For booster pumps not intended to be used for fire suppression, no person shall install or maintain a water service connection to any premises not included in paragraph (A) of this rule where a booster pump has been installed on the service line to or within such premises, unless such booster pump is equipped with a low pressure cut-off designed to shut-off the booster pump when the pressure in the service line on the suction side of the pump drops to ten pounds per square inch gauge or less.
- (C) For booster pumps used for fire suppression installed after the effective date of this rule, no person shall install or maintain a water service connection to any premises not included in paragraph (A) of this rule where a booster pump has been installed on the service line to or within such premises, unless the pump is equipped with a minimum pressure sustaining valve on the booster pump discharge, which throttles the discharge of the pump when necessary so that suction pressure will not be reduced below ten pounds per square inch gauge while the pump is operating.
- (D) For booster pumps used for fire suppression installed prior to the effective date of this rule, no person shall maintain a water service connection to any premises not included in paragraph (A) of this rule where a booster pump has been installed on the service line to or within such premises, unless the pump is equipped with either a low pressure cut-off designed to shut-off the booster pump when the pressure in the service line on the suction side of the pump drops to ten pounds per square inch gauge or less, or a minimum pressure sustaining valve on the booster pump discharge, which throttles the discharge of the pump when necessary so that suction pressure will not be reduced below ten pounds per square inch gauge while the pump is operating.
- (E) It shall be the duty of the water consumer to maintain the low pressure cut-off device or minimum pressure sustaining valve in proper working order and to certify to the supplier of water, at least once every twelve months that the device is operable and maintained in continuous operation.

Effective:

Five Year Review (FYR) Dates: 07/06/2015

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 6109.04
Rule Amplifies: 6109.04, 6109.13
Prior Effective Dates: 07/01/72, 11/26/80, 05/01/03, 08/08/08