



The Revised Total Coliform Rule: Baseline Routine Monitoring Frequencies

November 2015

Population Served	Type of System	Minimum Number of Samples Per Month	Minimum Number of Samples Per Quarter
25 – 1,000	Noncommunity GW		1*
25 – 1,000	Depressurized Seasonal Noncommunity GW	1 (During operating season)	1* (During off-season if partially-depressurized)
25 – 1,000	Fully-Pressurized Seasonal Noncommunity GW		1*
25 – 1,000	Community GW	1	
25 – 1,000	Consecutive SW	1	
1,001 to 2,500	GW and Consecutive SW	2	
2,501 to 3,300		3	
3,301 to 4,100		4	
25 – 4,100	SW	4	
4,101 to 4,900	ALL	5	
4,901 to 5,800		6	
5,801 to 6,700		7	
6,701 to 7,600		8	
7,601 to 8,500		9	
8,501 to 12,900		10	
12,901 to 17,200		15	
17,201 to 21,500		20	
21,501 to 25,000		25	
25,001 to 33,000		30	
33,001 to 41,000		40	
41,001 to 50,000		50	
50,001 to 59,000		60	
59,001 to 70,000		70	
70,001 to 83,000		80	
83,001 to 96,000		90	
96,001 to 130,000		100	
130,001 to 220,000		120	
220,001 to 320,000		150	
320,001 to 450,000		180	
450,001 to 600,000		210	
600,001 to 780,000		240	
780,001 to 970,000		270	
970,001 to 1,230,000		300	
1,230,001 to 1,520,000		330	
1,520,001 to 1,850,000		360	
1,850,001 to 2,270,000		390	
2,270,001 to 3,020,000	420		
3,020,001 to 3,960,000	450		
3,960,001 or more	480		

* Systems on quarterly monitoring may trigger an increase to monthly monitoring (See OAC 3745-81-51(B)(3)).