



OH1300011 BATAVIA VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: BATAVIA, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

LEAD - 1030 AND COPPER - 1022	Not Required
-------------------------------	--------------

ASBESTOS - 1094	Not Required
-----------------	--------------

TOTAL COLIFORM (TCR) - 3100	2 Sample(s) Required between 1/1/2016 and 1/31/2016
	2 Sample(s) Required between 2/1/2016 and 2/29/2016
	2 Sample(s) Required between 3/1/2016 and 3/31/2016
	2 Sample(s) Required between 4/1/2016 and 4/30/2016
	2 Sample(s) Required between 5/1/2016 and 5/31/2016
	2 Sample(s) Required between 6/1/2016 and 6/30/2016
	2 Sample(s) Required between 7/1/2016 and 7/31/2016
	2 Sample(s) Required between 8/1/2016 and 8/31/2016
	2 Sample(s) Required between 9/1/2016 and 9/30/2016
	2 Sample(s) Required between 10/1/2016 and 10/31/2016
	2 Sample(s) Required between 11/1/2016 and 11/30/2016
	2 Sample(s) Required between 12/1/2016 and 12/31/2016

TOTAL CHLORINE - 1000	2 Sample(s) Required between 1/1/2016 and 1/31/2016
	2 Sample(s) Required between 2/1/2016 and 2/29/2016
	2 Sample(s) Required between 3/1/2016 and 3/31/2016
	2 Sample(s) Required between 4/1/2016 and 4/30/2016
	2 Sample(s) Required between 5/1/2016 and 5/31/2016
	2 Sample(s) Required between 6/1/2016 and 6/30/2016
	2 Sample(s) Required between 7/1/2016 and 7/31/2016
	2 Sample(s) Required between 8/1/2016 and 8/31/2016
	2 Sample(s) Required between 9/1/2016 and 9/30/2016
	2 Sample(s) Required between 10/1/2016 and 10/31/2016
	2 Sample(s) Required between 11/1/2016 and 11/30/2016
	2 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: BATAVIA, VILLAGE OF DISTRIBUTION 950 KENT RD.	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/1/2016 and 3/7/2016 at SMP: DS201
	1 Sample(s) Required between 6/1/2016 and 6/7/2016 at SMP: DS201
	1 Sample(s) Required between 9/1/2016 and 9/7/2016 at SMP: DS201



OH1300011 BATAVIA VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: BATAVIA, VILLAGE OF DISTRIBUTION 950 KENT RD.	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 12/1/2016 and 12/7/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: BATAVIA, VILLAGE OF DISTRIBUTION 61 LOU DARBRO PLACE	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS

1 Sample(s) Required between 3/1/2016 and 3/7/2016 at SMP: DS202

1 Sample(s) Required between 6/1/2016 and 6/7/2016 at SMP: DS202

1 Sample(s) Required between 9/1/2016 and 9/7/2016 at SMP: DS202

1 Sample(s) Required between 12/1/2016 and 12/7/2016 at SMP: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 DISTRIBUTION SCHEDULE

OH1300116 BETHEL VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: BETHEL, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
LEAD - 1030 AND COPPER - 1022	Not Required
ASBESTOS - 1094	Not Required
TOTAL COLIFORM (TCR) - 3100	3 Sample(s) Required between 1/1/2016 and 1/31/2016 3 Sample(s) Required between 2/1/2016 and 2/29/2016 3 Sample(s) Required between 3/1/2016 and 3/31/2016 3 Sample(s) Required between 4/1/2016 and 4/30/2016 3 Sample(s) Required between 5/1/2016 and 5/31/2016 3 Sample(s) Required between 6/1/2016 and 6/30/2016 3 Sample(s) Required between 7/1/2016 and 7/31/2016 3 Sample(s) Required between 8/1/2016 and 8/31/2016 3 Sample(s) Required between 9/1/2016 and 9/30/2016 3 Sample(s) Required between 10/1/2016 and 10/31/2016 3 Sample(s) Required between 11/1/2016 and 11/30/2016 3 Sample(s) Required between 12/1/2016 and 12/31/2016
TOTAL CHLORINE - 1000	3 Sample(s) Required between 1/1/2016 and 1/31/2016 3 Sample(s) Required between 2/1/2016 and 2/29/2016 3 Sample(s) Required between 3/1/2016 and 3/31/2016 3 Sample(s) Required between 4/1/2016 and 4/30/2016 3 Sample(s) Required between 5/1/2016 and 5/31/2016 3 Sample(s) Required between 6/1/2016 and 6/30/2016 3 Sample(s) Required between 7/1/2016 and 7/31/2016 3 Sample(s) Required between 8/1/2016 and 8/31/2016 3 Sample(s) Required between 9/1/2016 and 9/30/2016 3 Sample(s) Required between 10/1/2016 and 10/31/2016 3 Sample(s) Required between 11/1/2016 and 11/30/2016 3 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: BETHEL, VILLAGE OF DISTRIBUTION 2894 BURKE RD.	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 DISTRIBUTION SCHEDULE

OH1300116 BETHEL VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: BETHEL, VILLAGE OF DISTRIBUTION 2571 ST. RT. 133	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS202
-------------------------	---

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 ENTRY POINT SCHEDULE

OH1300612 FELICITY VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 1353369	Facility Name: FELICITY WTP	
Location	SMP ID: EP001	Facility Source: Ground Water	Facility Class: CLASS 1

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	Not Required



OH1300612 FELICITY VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: FELICITY, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required

ASBESTOS - 1094 Not Required

TOTAL COLIFORM (TCR) - 3100

3 Sample(s) Required between	1/1/2016	and	1/31/2016
3 Sample(s) Required between	2/1/2016	and	2/29/2016
3 Sample(s) Required between	3/1/2016	and	3/31/2016
3 Sample(s) Required between	4/1/2016	and	4/30/2016
3 Sample(s) Required between	5/1/2016	and	5/31/2016
3 Sample(s) Required between	6/1/2016	and	6/30/2016
3 Sample(s) Required between	7/1/2016	and	7/31/2016
3 Sample(s) Required between	8/1/2016	and	8/31/2016
3 Sample(s) Required between	9/1/2016	and	9/30/2016
3 Sample(s) Required between	10/1/2016	and	10/31/2016
3 Sample(s) Required between	11/1/2016	and	11/30/2016
3 Sample(s) Required between	12/1/2016	and	12/31/2016

TOTAL CHLORINE - 1000

3 Sample(s) Required between	1/1/2016	and	1/31/2016
3 Sample(s) Required between	2/1/2016	and	2/29/2016
3 Sample(s) Required between	3/1/2016	and	3/31/2016
3 Sample(s) Required between	4/1/2016	and	4/30/2016
3 Sample(s) Required between	5/1/2016	and	5/31/2016
3 Sample(s) Required between	6/1/2016	and	6/30/2016
3 Sample(s) Required between	7/1/2016	and	7/31/2016
3 Sample(s) Required between	8/1/2016	and	8/31/2016
3 Sample(s) Required between	9/1/2016	and	9/30/2016
3 Sample(s) Required between	10/1/2016	and	10/31/2016
3 Sample(s) Required between	11/1/2016	and	11/30/2016
3 Sample(s) Required between	12/1/2016	and	12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: FELICITY, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 DISTRIBUTION SCHEDULE

OH1300612 FELICITY VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: FELICITY, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS202
-------------------------	---

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 ENTRY POINT SCHEDULE

OH1300812 LOVELAND CITY PWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 1353371	Facility Name: LOVELAND CITY OF	Facility Class: CLASS 2
	SMP ID: EP001	Facility Source: Ground Water	

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	Not Required



Effective Date: 08/18/2016

2016 DISTRIBUTION SCHEDULE

OH1300812 LOVELAND CITY PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: LOVELAND, CITY OF DISTRIBUTION	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 30 Sample(s) Required between 6/1/2016 and 9/30/2016

Lead Consumer Notice needs issued to sampling participants within thirty days of receipt of results and verification submitted to Ohio EPA within ninety days from the end of the monitoring period. Submit Form 5105 with appendix to Ohio EPA within ten days from the end of the monitoring period. Forms are available online at: http://epa.ohio.gov/ddagw/reporting.aspx

TOTAL COLIFORM (TCR) - 3100

10 Sample(s) Required between 1/1/2016 and 1/31/2016

10 Sample(s) Required between 2/1/2016 and 2/29/2016

10 Sample(s) Required between 3/1/2016 and 3/31/2016

10 Sample(s) Required between 4/1/2016 and 4/30/2016

10 Sample(s) Required between 5/1/2016 and 5/31/2016

10 Sample(s) Required between 6/1/2016 and 6/30/2016

10 Sample(s) Required between 7/1/2016 and 7/31/2016

10 Sample(s) Required between 8/1/2016 and 8/31/2016

10 Sample(s) Required between 9/1/2016 and 9/30/2016

10 Sample(s) Required between 10/1/2016 and 10/31/2016

10 Sample(s) Required between 11/1/2016 and 11/30/2016

10 Sample(s) Required between 12/1/2016 and 12/31/2016

TOTAL CHLORINE - 1000

10 Sample(s) Required between 1/1/2016 and 1/31/2016

10 Sample(s) Required between 2/1/2016 and 2/29/2016

10 Sample(s) Required between 3/1/2016 and 3/31/2016

10 Sample(s) Required between 4/1/2016 and 4/30/2016

10 Sample(s) Required between 5/1/2016 and 5/31/2016

10 Sample(s) Required between 6/1/2016 and 6/30/2016

10 Sample(s) Required between 7/1/2016 and 7/31/2016

10 Sample(s) Required between 8/1/2016 and 8/31/2016

10 Sample(s) Required between 9/1/2016 and 9/30/2016

10 Sample(s) Required between 10/1/2016 and 10/31/2016

10 Sample(s) Required between 11/1/2016 and 11/30/2016

10 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: LOVELAND, CITY OF DISTRIBUTION 126 S. LEBANON	Facility Class: CLASS 2
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) - 2456
- 2) TTHM - 2950



Effective Date: 08/18/2016

2016 DISTRIBUTION SCHEDULE

OH1300812 LOVELAND CITY PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: LOVELAND, CITY OF DISTRIBUTION 10535 LOVELAND MADEIRA	Facility Class: CLASS 2
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH1301012 MILFORD CITY PWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 1353372	Facility Name: MILFORD CITY	
Location	SMP ID: EP001	Facility Source: Ground Water	Facility Class: CLASS 2

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 2	1 Sample(s) Required between 4/1/2016 and 6/30/2016
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 3	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 4	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 1/1/2016 and 3/31/2016 1 Sample(s) Required between 4/1/2016 and 6/30/2016 1 Sample(s) Required between 7/1/2016 and 9/30/2016 1 Sample(s) Required between 10/1/2016 and 12/31/2016



OH1301012 MILFORD CITY PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: MILFORD, CITY OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 20 Sample(s) Required between 6/1/2016 and 9/30/2016

Lead Consumer Notice needs issued to sampling participants within thirty days of receipt of results and verification submitted to Ohio EPA within ninety days from the end of the monitoring period. Submit Form 5105 with appendix to Ohio EPA within ten days from the end of the monitoring period. Forms are available online at: http://epa.ohio.gov/ddagw/reporting.aspx

TOTAL COLIFORM (TCR) - 3100

7 Sample(s) Required between 1/1/2016 and 1/31/2016

7 Sample(s) Required between 2/1/2016 and 2/29/2016

7 Sample(s) Required between 3/1/2016 and 3/31/2016

7 Sample(s) Required between 4/1/2016 and 4/30/2016

7 Sample(s) Required between 5/1/2016 and 5/31/2016

7 Sample(s) Required between 6/1/2016 and 6/30/2016

7 Sample(s) Required between 7/1/2016 and 7/31/2016

7 Sample(s) Required between 8/1/2016 and 8/31/2016

7 Sample(s) Required between 9/1/2016 and 9/30/2016

7 Sample(s) Required between 10/1/2016 and 10/31/2016

7 Sample(s) Required between 11/1/2016 and 11/30/2016

7 Sample(s) Required between 12/1/2016 and 12/31/2016

TOTAL CHLORINE - 1000

7 Sample(s) Required between 1/1/2016 and 1/31/2016

7 Sample(s) Required between 2/1/2016 and 2/29/2016

7 Sample(s) Required between 3/1/2016 and 3/31/2016

7 Sample(s) Required between 4/1/2016 and 4/30/2016

7 Sample(s) Required between 5/1/2016 and 5/31/2016

7 Sample(s) Required between 6/1/2016 and 6/30/2016

7 Sample(s) Required between 7/1/2016 and 7/31/2016

7 Sample(s) Required between 8/1/2016 and 8/31/2016

7 Sample(s) Required between 9/1/2016 and 9/30/2016

7 Sample(s) Required between 10/1/2016 and 10/31/2016

7 Sample(s) Required between 11/1/2016 and 11/30/2016

7 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: MILFORD, CITY OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 DISTRIBUTION SCHEDULE

OH1301012 MILFORD CITY PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: MILFORD, CITY OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
------------------	--------------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS202
-------------------------	---

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 ENTRY POINT SCHEDULE

OH1301212 NEW RICHMOND VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 1353373	Facility Name: NEW RICHMOND VILLAGE OF	Facility Class: CLASS 1
	SMP ID: EP001	Facility Source: Ground Water	

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	Not Required



OH1301212 NEW RICHMOND VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location Facility ID: **DS1** Facility Name: **NEW RICHMOND,VILLAGE OF DISTRIBUTION** Facility Class: **CLASS 1**
SMP ID: **DS000**

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required

ASBESTOS - 1094 Not Required

TOTAL COLIFORM (TCR) - 3100
3 Sample(s) Required between 1/1/2016 and 1/31/2016
3 Sample(s) Required between 2/1/2016 and 2/29/2016
3 Sample(s) Required between 3/1/2016 and 3/31/2016
3 Sample(s) Required between 4/1/2016 and 4/30/2016
3 Sample(s) Required between 5/1/2016 and 5/31/2016
3 Sample(s) Required between 6/1/2016 and 6/30/2016
3 Sample(s) Required between 7/1/2016 and 7/31/2016
3 Sample(s) Required between 8/1/2016 and 8/31/2016
3 Sample(s) Required between 9/1/2016 and 9/30/2016
3 Sample(s) Required between 10/1/2016 and 10/31/2016
3 Sample(s) Required between 11/1/2016 and 11/30/2016
3 Sample(s) Required between 12/1/2016 and 12/31/2016

TOTAL CHLORINE - 1000
3 Sample(s) Required between 1/1/2016 and 1/31/2016
3 Sample(s) Required between 2/1/2016 and 2/29/2016
3 Sample(s) Required between 3/1/2016 and 3/31/2016
3 Sample(s) Required between 4/1/2016 and 4/30/2016
3 Sample(s) Required between 5/1/2016 and 5/31/2016
3 Sample(s) Required between 6/1/2016 and 6/30/2016
3 Sample(s) Required between 7/1/2016 and 7/31/2016
3 Sample(s) Required between 8/1/2016 and 8/31/2016
3 Sample(s) Required between 9/1/2016 and 9/30/2016
3 Sample(s) Required between 10/1/2016 and 10/31/2016
3 Sample(s) Required between 11/1/2016 and 11/30/2016
3 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location Facility ID: **DS1** Facility Name: **NEW RICHMOND,VILLAGE OF DISTRIBUTION** Facility Class: **CLASS 1**
SMP ID: **DS201** ADDRESS NOT KNOWN

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2016

2016 DISTRIBUTION SCHEDULE

OH1301212 NEW RICHMOND VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: NEW RICHMOND, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH1301312 TATE-MONROE WATER ASSOCIATION PWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 1353374	Facility Name: TATE MONROE WATER ASSOCIATION STU 1
Location	SMP ID: EP001	Facility Source: Ground Water
		Facility Class: CLASS 2

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
BROMATE - 1011	1 Sample(s) Required between 10/1/2016 and 10/31/2016 1 Sample(s) Required between 11/1/2016 and 11/30/2016 1 Sample(s) Required between 12/1/2016 and 12/31/2016
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 4/1/2016 and 6/30/2016



Effective Date: 10/14/2016

2016 ENTRY POINT SCHEDULE

OH1301312 TATE-MONROE WATER ASSOCIATION PWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 1360941 SMP ID: EP002	Facility Name: TATE MONROE WATER ASSOCIATION STU 2 Facility Source: Ground Water	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
INORGANICS	Not Required
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 1/1/2016 and 5/31/2016



OH1301312 TATE-MONROE WATER ASSOCIATION PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

DISTRIBUTION MONITORING SCHEDULE

Sampling Location Facility ID: DS1 Facility Name: TATE-MONROE WATER ASSOC. DISTRIBUTIC Facility Class: CLASS 1 SMP ID: DS000

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 30 Sample(s) Required between 6/1/2016 and 9/30/2016

Lead Consumer Notice needs issued to sampling participants within thirty days of receipt of results and verification submitted to Ohio EPA within ninety days from the end of the monitoring period. Submit Form 5105 with appendix to Ohio EPA within ten days from the end of the monitoring period. Forms are available online at: http://epa.ohio.gov/ddagw/reporting.aspx

ASBESTOS - 1094 Not Required

TOTAL COLIFORM (TCR) - 3100 30 Sample(s) Required between 1/1/2016 and 1/31/2016 30 Sample(s) Required between 2/1/2016 and 2/29/2016 30 Sample(s) Required between 3/1/2016 and 3/31/2016 30 Sample(s) Required between 4/1/2016 and 4/30/2016 30 Sample(s) Required between 5/1/2016 and 5/31/2016 30 Sample(s) Required between 6/1/2016 and 6/30/2016 30 Sample(s) Required between 7/1/2016 and 7/31/2016 30 Sample(s) Required between 8/1/2016 and 8/31/2016 30 Sample(s) Required between 9/1/2016 and 9/30/2016 30 Sample(s) Required between 10/1/2016 and 10/31/2016 30 Sample(s) Required between 11/1/2016 and 11/30/2016 30 Sample(s) Required between 12/1/2016 and 12/31/2016

TOTAL CHLORINE - 1000 30 Sample(s) Required between 1/1/2016 and 1/31/2016 30 Sample(s) Required between 2/1/2016 and 2/29/2016 30 Sample(s) Required between 3/1/2016 and 3/31/2016 30 Sample(s) Required between 4/1/2016 and 4/30/2016 30 Sample(s) Required between 5/1/2016 and 5/31/2016 30 Sample(s) Required between 6/1/2016 and 6/30/2016 30 Sample(s) Required between 7/1/2016 and 7/31/2016 30 Sample(s) Required between 8/1/2016 and 8/31/2016 30 Sample(s) Required between 9/1/2016 and 9/30/2016 30 Sample(s) Required between 10/1/2016 and 10/31/2016 30 Sample(s) Required between 11/1/2016 and 11/30/2016 30 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.



OH1301312 TATE-MONROE WATER ASSOCIATION PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: TATE-MONROE WATER ASSOC. DISTRIBUTIC 3846 SR 133	Facility Class: CLASS 1
--------------------------	---	--	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: TATE-MONROE WATER ASSOC. DISTRIBUTIC 410 MARKET ST.	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH1301411 WILLIAMSBURG VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: WILLIAMSBURG, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
LEAD - 1030 AND COPPER - 1022	Not Required
ASBESTOS - 1094	Not Required
TOTAL COLIFORM (TCR) - 3100	2 Sample(s) Required between 1/1/2016 and 1/31/2016 2 Sample(s) Required between 2/1/2016 and 2/29/2016 2 Sample(s) Required between 3/1/2016 and 3/31/2016 2 Sample(s) Required between 4/1/2016 and 4/30/2016 2 Sample(s) Required between 5/1/2016 and 5/31/2016 2 Sample(s) Required between 6/1/2016 and 6/30/2016 2 Sample(s) Required between 7/1/2016 and 7/31/2016 2 Sample(s) Required between 8/1/2016 and 8/31/2016 2 Sample(s) Required between 9/1/2016 and 9/30/2016 2 Sample(s) Required between 10/1/2016 and 10/31/2016 2 Sample(s) Required between 11/1/2016 and 11/30/2016 2 Sample(s) Required between 12/1/2016 and 12/31/2016
TOTAL CHLORINE - 1000	2 Sample(s) Required between 1/1/2016 and 1/31/2016 2 Sample(s) Required between 2/1/2016 and 2/29/2016 2 Sample(s) Required between 3/1/2016 and 3/31/2016 2 Sample(s) Required between 4/1/2016 and 4/30/2016 2 Sample(s) Required between 5/1/2016 and 5/31/2016 2 Sample(s) Required between 6/1/2016 and 6/30/2016 2 Sample(s) Required between 7/1/2016 and 7/31/2016 2 Sample(s) Required between 8/1/2016 and 8/31/2016 2 Sample(s) Required between 9/1/2016 and 9/30/2016 2 Sample(s) Required between 10/1/2016 and 10/31/2016 2 Sample(s) Required between 11/1/2016 and 11/30/2016 2 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: WILLIAMSBURG, VILLAGE OF DISTRIBUTION 365 CORAL CT.	Facility Class: CLASS 1
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/1/2016 and 3/7/2016 at SMP: DS201 1 Sample(s) Required between 6/1/2016 and 6/7/2016 at SMP: DS201 1 Sample(s) Required between 9/1/2016 and 9/7/2016 at SMP: DS201



OH1301411 WILLIAMSBURG VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location Facility ID: **DS1** Facility Name: **WILLIAMSBURG, VILLAGE OF DISTRIBUTION** Facility Class: **CLASS 1**
SMP ID: **DS201** **365 CORAL CT.**

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 12/1/2016 and 12/7/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location Facility ID: **DS1** Facility Name: **WILLIAMSBURG, VILLAGE OF DISTRIBUTION** Facility Class: **CLASS 1**
SMP ID: **DS202** **481 S. BROADWAY**

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS 1 Sample(s) Required between 3/1/2016 and 3/7/2016 at SMP: DS202
1 Sample(s) Required between 6/1/2016 and 6/7/2016 at SMP: DS202
1 Sample(s) Required between 9/1/2016 and 9/7/2016 at SMP: DS202
1 Sample(s) Required between 12/1/2016 and 12/7/2016 at SMP: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling	Facility ID: 1353366	Facility Name: CLERMONT CO. PWS PUB PLANT
Location	SMP ID: EP001	Facility Source: Ground Water Facility Class: CLASS 3

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
DIOXIN - 2063	1 Sample(s) Required between 4/1/2016 and 6/30/2016
INORGANICS	1 Sample(s) Required between 1/1/2016 and 5/31/2016
<i>Sample for all the analytes listed below:</i>	
ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085	
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	Not Required



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 1353367 SMP ID: EP002	Facility Name: CLERMONT CO. PWS MGS PLANT Facility Source: Ground Water	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals	Monitoring Requirements
INORGANICS <i>Sample for all the analytes listed below:</i> ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085	1 Sample(s) Required between 1/1/2016 and 5/31/2016
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 5/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	Not Required
VOLATILE ORGANIC CHEMICALS (VOC)	Not Required



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 1353368 SMP ID: EP003	Facility Name: CLERMONT CO. PWS BMWT PLANT Facility Source: Surface Water	Facility Class: CLASS 4
--------------------------	---	--	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

Chemicals	Monitoring Requirements
INORGANICS	1 Sample(s) Required between 1/1/2016 and 5/31/2016
<i>Sample for all the analytes listed below:</i>	
ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085	
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2016 and 1/31/2016 1 Sample(s) Required between 2/1/2016 and 2/29/2016 1 Sample(s) Required between 3/1/2016 and 3/31/2016 1 Sample(s) Required between 4/1/2016 and 4/30/2016 1 Sample(s) Required between 5/1/2016 and 5/31/2016 1 Sample(s) Required between 6/1/2016 and 6/30/2016 1 Sample(s) Required between 7/1/2016 and 7/31/2016 1 Sample(s) Required between 8/1/2016 and 8/31/2016 1 Sample(s) Required between 9/1/2016 and 9/30/2016 1 Sample(s) Required between 10/1/2016 and 10/31/2016 1 Sample(s) Required between 11/1/2016 and 11/30/2016 1 Sample(s) Required between 12/1/2016 and 12/31/2016
RADIOLOGICALS	Not Required
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between 4/1/2016 and 6/30/2016
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 1/1/2016 and 5/31/2016
TOTAL ORGANIC CARBON (TOC)	1 Paired Sample Set Required between 1/1/2016 and 1/31/2016 1 Paired Sample Set Required between 2/1/2016 and 2/29/2016 1 Paired Sample Set Required between 3/1/2016 and 3/31/2016 1 Paired Sample Set Required between 4/1/2016 and 4/30/2016 1 Paired Sample Set Required between 5/1/2016 and 5/31/2016 1 Paired Sample Set Required between 6/1/2016 and 6/30/2016 1 Paired Sample Set Required between 7/1/2016 and 7/31/2016 1 Paired Sample Set Required between 8/1/2016 and 8/31/2016 1 Paired Sample Set Required between 9/1/2016 and 9/30/2016 1 Paired Sample Set Required between 10/1/2016 and 10/31/2016 1 Paired Sample Set Required between 11/1/2016 and 11/30/2016 1 Paired Sample Set Required between 12/1/2016 and 12/31/2016

A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.



Effective Date: 05/13/2016

2016 ENTRY POINT SCHEDULE

OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 1353368	Facility Name: CLERMONT CO. PWS BMWT PLANT	Facility Class: CLASS 4
	SMP ID: EP003/LT2003	Facility Source: Surface Water	

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

Chemicals

Monitoring Requirements

TOTAL MICROCYSTINS	1 Sample Set Required WEEKLY starting June 5
--------------------	---

Total microcystins sample set refers to one raw source water sample at LT2003 and one finished water sample at EP003. Both are required every week from January 1 to December 31 (reduced monitoring available from November to April). A week is defined as Sunday through Saturday. Samples must be analyzed at a lab accepted by Ohio EPA for microcystins analysis.



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 1353368 SMP ID: LT2003	Facility Name: CLERMONT CO. PWS BMWT PLANT Facility Source: Surface Water	Facility Class: CLASS 4
--------------------------	--	--	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

Chemicals	Monitoring Requirements
-----------	-------------------------

CYANOBACTERIA SCREENING	1 Sample(s) Required between 6/5/2016 and 6/11/2016
	1 Sample(s) Required between 6/19/2016 and 6/25/2016
	1 Sample(s) Required between 7/3/2016 and 7/9/2016
	1 Sample(s) Required between 7/17/2016 and 7/23/2016
	1 Sample(s) Required between 7/31/2016 and 8/6/2016
	1 Sample(s) Required between 8/14/2016 and 8/20/2016
	1 Sample(s) Required between 8/28/2016 and 9/3/2016
	1 Sample(s) Required between 9/11/2016 and 9/17/2016
	1 Sample(s) Required between 9/25/2016 and 10/1/2016
	1 Sample(s) Required between 10/9/2016 and 10/15/2016
	1 Sample(s) Required between 10/23/2016 and 10/29/2016
	1 Sample(s) Required between 11/6/2016 and 11/12/2016
	1 Sample(s) Required between 11/20/2016 and 11/26/2016
	1 Sample(s) Required between 12/4/2016 and 12/10/2016
	1 Sample(s) Required between 12/18/2016 and 12/24/2016

Cyanobacteria screening sample is to be collected biweekly from raw source water at sample point LT2003 and must be collected at the same time as the raw total microcystins sample. SAMPLES MUST BE SHIPPED OVERNIGHT ON ICE ON THE DAY OF COLLECTION AND ARRIVE AT OHIO EPA DIVISION OF ENVIRONMENTAL SERVICES BY NOON MONDAY THROUGH THURSDAY ONLY!

LT2 MONITORING	1 Sample(s) Required between 1/17/2016 and 1/21/2016
	1 Sample(s) Required between 2/21/2016 and 2/25/2016
	1 Sample(s) Required between 3/20/2016 and 3/24/2016
	1 Sample(s) Required between 4/17/2016 and 4/21/2016
	1 Sample(s) Required between 5/15/2016 and 5/19/2016
	1 Sample(s) Required between 6/19/2016 and 6/23/2016
	1 Sample(s) Required between 7/17/2016 and 7/21/2016
	1 Sample(s) Required between 8/21/2016 and 8/25/2016
	1 Sample(s) Required between 9/18/2016 and 9/22/2016
	1 Sample(s) Required between 10/16/2016 and 10/20/2016
	1 Sample(s) Required between 11/20/2016 and 11/24/2016
	1 Sample(s) Required between 12/29/2016 and 1/2/2017

Monitor for: Cryptosporidium - 2078, E-coli count - 3014, Turbidity - 0100

LT2 MATRIX SPIKE SAMPLE	1 Sample(s) Required between 7/17/2016 and 7/21/2016
-------------------------	--



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: CLERMONT CO PWS DISTRIBUTION	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required

CHLORITE - 1009

3 Sample(s) Required between	1/1/2016	and	1/31/2016
3 Sample(s) Required between	2/1/2016	and	2/29/2016
3 Sample(s) Required between	3/1/2016	and	3/31/2016
3 Sample(s) Required between	4/1/2016	and	4/30/2016
3 Sample(s) Required between	5/1/2016	and	5/31/2016
3 Sample(s) Required between	6/1/2016	and	6/30/2016
3 Sample(s) Required between	7/1/2016	and	7/31/2016
3 Sample(s) Required between	8/1/2016	and	8/31/2016
3 Sample(s) Required between	9/1/2016	and	9/30/2016
3 Sample(s) Required between	10/1/2016	and	10/31/2016
3 Sample(s) Required between	11/1/2016	and	11/30/2016
3 Sample(s) Required between	12/1/2016	and	12/31/2016

One sample at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

TOTAL COLIFORM (TCR) - 3100

100 Sample(s) Required between	1/1/2016	and	1/31/2016
100 Sample(s) Required between	2/1/2016	and	2/29/2016
100 Sample(s) Required between	3/1/2016	and	3/31/2016
100 Sample(s) Required between	4/1/2016	and	4/30/2016
100 Sample(s) Required between	5/1/2016	and	5/31/2016
100 Sample(s) Required between	6/1/2016	and	6/30/2016
100 Sample(s) Required between	7/1/2016	and	7/31/2016
100 Sample(s) Required between	8/1/2016	and	8/31/2016
100 Sample(s) Required between	9/1/2016	and	9/30/2016
100 Sample(s) Required between	10/1/2016	and	10/31/2016
100 Sample(s) Required between	11/1/2016	and	11/30/2016
100 Sample(s) Required between	12/1/2016	and	12/31/2016

TOTAL CHLORINE - 1000

100 Sample(s) Required between	1/1/2016	and	1/31/2016
100 Sample(s) Required between	2/1/2016	and	2/29/2016
100 Sample(s) Required between	3/1/2016	and	3/31/2016
100 Sample(s) Required between	4/1/2016	and	4/30/2016
100 Sample(s) Required between	5/1/2016	and	5/31/2016
100 Sample(s) Required between	6/1/2016	and	6/30/2016
100 Sample(s) Required between	7/1/2016	and	7/31/2016
100 Sample(s) Required between	8/1/2016	and	8/31/2016
100 Sample(s) Required between	9/1/2016	and	9/30/2016
100 Sample(s) Required between	10/1/2016	and	10/31/2016
100 Sample(s) Required between	11/1/2016	and	11/30/2016



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: CLERMONT CO PWS DISTRIBUTION	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

TOTAL CHLORINE - 1000 100 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: CLERMONT CO PWS DISTRIBUTION GOSHEN TANK	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS201
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS201
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS201
	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: CLERMONT CO PWS DISTRIBUTION WERNER'S TAX SERVICE	Facility Class: CLASS 2
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS202
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS202
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS202
	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS203	Facility Name: CLERMONT CO PWS DISTRIBUTION OWENSVILLE VILLAGE HALL	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS203
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS203
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS203
	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS203

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS204	Facility Name: CLERMONT CO PWS DISTRIBUTION BUCKWHEAT TANK ST 131	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS204
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS204
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS204
	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS204

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS205	Facility Name: CLERMONT CO PWS DISTRIBUTION ARROWHEAD APTS. 800 ARROWHE	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS205
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS205
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS205
	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS205

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS206	Facility Name: CLERMONT CO PWS DISTRIBUTION PERMIT CENTRAL BAUER RD.	Facility Class: CLASS 2
--------------------------	---	---	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS206
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS206
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS206
	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS206

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS207	Facility Name: CLERMONT CO PWS DISTRIBUTION SUBWAY ON WARD'S CORNER ROA	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS207
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS207
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS207



OH1302212 CLERMONT PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS207	Facility Name: CLERMONT CO PWS DISTRIBUTION SUBWAY ON WARD'S CORNER ROA	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS207
-------------------------	---

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1 SMP ID: DS208	Facility Name: CLERMONT CO PWS DISTRIBUTION UDF 131 AND 132	Facility Class: CLASS 2
--------------------------	---	--	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 3/8/2016 and 3/14/2016 at SMP: DS208
	1 Sample(s) Required between 6/8/2016 and 6/14/2016 at SMP: DS208
	1 Sample(s) Required between 9/8/2016 and 9/14/2016 at SMP: DS208
	1 Sample(s) Required between 12/8/2016 and 12/14/2016 at SMP: DS208

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH1330912 NEW RICHMOND ROBIN-GRAYS PWS

System Type: Community

Operating Period: 1/1 to 12/31

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2016

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1	Facility Name: NEW RICHMOND ROBIN-GRAYS DISTRIBUTIC
	SMP ID: DS000	

Chemicals	Monitoring Requirements
-----------	-------------------------

LEAD - 1030 AND COPPER - 1022	5 Sample(s) Required between 6/1/2016 and 9/30/2016
-------------------------------	---

Lead Consumer Notice needs issued to sampling participants within thirty days of receipt of results and verification submitted to Ohio EPA within ninety days from the end of the monitoring period. Submit Form 5105 with appendix to Ohio EPA within ten days from the end of the monitoring period. Forms are available online at: <http://epa.ohio.gov/ddagw/reporting.aspx>

TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between 1/1/2016 and 1/31/2016
	1 Sample(s) Required between 2/1/2016 and 2/29/2016
	1 Sample(s) Required between 3/1/2016 and 3/31/2016
	1 Sample(s) Required between 4/1/2016 and 4/30/2016
	1 Sample(s) Required between 5/1/2016 and 5/31/2016
	1 Sample(s) Required between 6/1/2016 and 6/30/2016
	1 Sample(s) Required between 7/1/2016 and 7/31/2016
	1 Sample(s) Required between 8/1/2016 and 8/31/2016
	1 Sample(s) Required between 9/1/2016 and 9/30/2016
	1 Sample(s) Required between 10/1/2016 and 10/31/2016
	1 Sample(s) Required between 11/1/2016 and 11/30/2016
	1 Sample(s) Required between 12/1/2016 and 12/31/2016

TOTAL CHLORINE - 1000	1 Sample(s) Required between 1/1/2016 and 1/31/2016
	1 Sample(s) Required between 2/1/2016 and 2/29/2016
	1 Sample(s) Required between 3/1/2016 and 3/31/2016
	1 Sample(s) Required between 4/1/2016 and 4/30/2016
	1 Sample(s) Required between 5/1/2016 and 5/31/2016
	1 Sample(s) Required between 6/1/2016 and 6/30/2016
	1 Sample(s) Required between 7/1/2016 and 7/31/2016
	1 Sample(s) Required between 8/1/2016 and 8/31/2016
	1 Sample(s) Required between 9/1/2016 and 9/30/2016
	1 Sample(s) Required between 10/1/2016 and 10/31/2016
	1 Sample(s) Required between 11/1/2016 and 11/30/2016
	1 Sample(s) Required between 12/1/2016 and 12/31/2016

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1	Facility Name: NEW RICHMOND ROBIN-GRAYS DISTRIBUTIC
	SMP ID: DS201	947 GRAYS LANE

Chemicals	Monitoring Requirements
-----------	-------------------------

DISINFECTION BYPRODUCTS	1 Sample(s) Required between 7/1/2016 and 9/30/2016 at SMP: DS201
-------------------------	---

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950