



OH0100012 ADAMS COUNTY REGIONAL WD PWS

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 152614 SMP ID: EP001	Facility Name: ADAMS COUNTY WATER CO INC Facility Source: Ground Water	Facility Class: CLASS 3
--------------------------	----------------------------------------------------	-----------------------------------------------------------------------------------------	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017

Chemicals	Monitoring Requirements
INORGANICS <i>Sample for all the analytes listed below:</i> ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085	1 Sample(s) Required between 1/1/2017 and 5/31/2017
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2017 and 5/31/2017
RADIOLOGICALS <i>Sample for all the analytes listed below:</i> GROSS ALPHA - 4002 RADIUM-228 - 4030	1 Sample(s) Required between 1/1/2017 and 5/31/2017
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1 <i>Sample for all the analytes listed below:</i> ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037	1 Sample(s) Required between 1/1/2017 and 5/31/2017
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 1/1/2017 and 5/31/2017



OH0100012 ADAMS COUNTY REGIONAL WD PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: ADAMS COUNTY REGIONAL WD DISTRIBUTIO	Facility Class: CLASS 2
--------------------------	-------------------------------------------------	------------------------------------------------------------	--------------------------------

Chemicals	Monitoring Requirements
-----------	-------------------------

LEAD - 1030 AND COPPER - 1022	30 Sample(s) Required between 6/1/2017 and 9/30/2017
-------------------------------	------------------------------------------------------

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Form 5105 with appendix must be submitted to Ohio EPA within ten days from the end of the month(s) in which samples are collected. Forms are available online at: <http://epa.ohio.gov/ddagw/reporting.aspx>. For questions contact your Ohio EPA District Office representative.

ASBESTOS - 1094	Not Required
-----------------	--------------

TOTAL COLIFORM (TCR) - 3100	20 Sample(s) Required between 1/1/2017 and 1/31/2017
	20 Sample(s) Required between 2/1/2017 and 2/28/2017
	20 Sample(s) Required between 3/1/2017 and 3/31/2017
	20 Sample(s) Required between 4/1/2017 and 4/30/2017
	20 Sample(s) Required between 5/1/2017 and 5/31/2017
	20 Sample(s) Required between 6/1/2017 and 6/30/2017
	20 Sample(s) Required between 7/1/2017 and 7/31/2017
	20 Sample(s) Required between 8/1/2017 and 8/31/2017
	20 Sample(s) Required between 9/1/2017 and 9/30/2017
	20 Sample(s) Required between 10/1/2017 and 10/31/2017
	20 Sample(s) Required between 11/1/2017 and 11/30/2017
	20 Sample(s) Required between 12/1/2017 and 12/31/2017

TOTAL CHLORINE - 1000	20 Sample(s) Required between 1/1/2017 and 1/31/2017
	20 Sample(s) Required between 2/1/2017 and 2/28/2017
	20 Sample(s) Required between 3/1/2017 and 3/31/2017
	20 Sample(s) Required between 4/1/2017 and 4/30/2017
	20 Sample(s) Required between 5/1/2017 and 5/31/2017
	20 Sample(s) Required between 6/1/2017 and 6/30/2017
	20 Sample(s) Required between 7/1/2017 and 7/31/2017
	20 Sample(s) Required between 8/1/2017 and 8/31/2017
	20 Sample(s) Required between 9/1/2017 and 9/30/2017
	20 Sample(s) Required between 10/1/2017 and 10/31/2017
	20 Sample(s) Required between 11/1/2017 and 11/30/2017
	20 Sample(s) Required between 12/1/2017 and 12/31/2017

Samples should be collected at the same time and place as the Total Coliform samples.



OH0100012 ADAMS COUNTY REGIONAL WD PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1	Facility Name: ADAMS COUNTY REGIONAL WD DISTRIBUTIO	Facility Class: CLASS 2
	SMP ID: DS201	ADDRESS NOT KNOWN	

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950

Sampling Location	Facility ID: DS1	Facility Name: ADAMS COUNTY REGIONAL WD DISTRIBUTIO	Facility Class: CLASS 2
	SMP ID: DS202	ADDRESS NOT KNOWN	

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH0100112 MANCHESTER VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 152615 SMP ID: EP001	Facility Name: MANCHESTER WTP Facility Source: Ground Water	Facility Class: CLASS 1
--------------------------	----------------------------------------------------	------------------------------------------------------------------------------	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017

Chemicals	Monitoring Requirements
-----------	-------------------------

INORGANICS	1 Sample(s) Required between 1/1/2017 and 5/31/2017
------------	-----------------------------------------------------

Sample for all the analytes listed below:

ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020
CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085

NITRITE - 1041	Not Required
----------------	--------------

NITRATE - 1040	1 Sample(s) Required between 4/1/2017 and 6/30/2017
----------------	-----------------------------------------------------

RADIOLOGICALS	1 Sample(s) Required between 1/1/2017 and 5/31/2017
---------------	-----------------------------------------------------

Sample for all the analytes listed below:

GROSS ALPHA - 4002 RADIUM-228 - 4030

SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between 1/1/2017 and 5/31/2017
-------------------------------------------	-----------------------------------------------------

Sample for all the analytes listed below:

ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037

SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 2	Not Required
-------------------------------------------	--------------

SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 3	Not Required
-------------------------------------------	--------------

SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 4	1 Sample(s) Required between 4/1/2017 and 6/30/2017
-------------------------------------------	-----------------------------------------------------

Sample for all the analytes listed below:

BENZO (A) PYRENE - 2306 DI(2-ETHYLHEXYL) - ADIPATE - 2035 DI(2-ETHYLHEXYL) - PHTHALATE - 2039
ENDOTHALL - 2033

VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 1/1/2017 and 5/31/2017
----------------------------------	-----------------------------------------------------



Effective Date: 01/01/2017

2017 DISTRIBUTION SCHEDULE

OH0100112 MANCHESTER VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: MANCHESTER, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	-----------------------------------------------------------	--------------------------------

Chemicals	Monitoring Requirements
LEAD - 1030 AND COPPER - 1022	Not Required
ASBESTOS - 1094	Not Required
TOTAL COLIFORM (TCR) - 3100	2 Sample(s) Required between 1/1/2017 and 1/31/2017 2 Sample(s) Required between 2/1/2017 and 2/28/2017 2 Sample(s) Required between 3/1/2017 and 3/31/2017 2 Sample(s) Required between 4/1/2017 and 4/30/2017 2 Sample(s) Required between 5/1/2017 and 5/31/2017 2 Sample(s) Required between 6/1/2017 and 6/30/2017 2 Sample(s) Required between 7/1/2017 and 7/31/2017 2 Sample(s) Required between 8/1/2017 and 8/31/2017 2 Sample(s) Required between 9/1/2017 and 9/30/2017 2 Sample(s) Required between 10/1/2017 and 10/31/2017 2 Sample(s) Required between 11/1/2017 and 11/30/2017 2 Sample(s) Required between 12/1/2017 and 12/31/2017
TOTAL CHLORINE - 1000	2 Sample(s) Required between 1/1/2017 and 1/31/2017 2 Sample(s) Required between 2/1/2017 and 2/28/2017 2 Sample(s) Required between 3/1/2017 and 3/31/2017 2 Sample(s) Required between 4/1/2017 and 4/30/2017 2 Sample(s) Required between 5/1/2017 and 5/31/2017 2 Sample(s) Required between 6/1/2017 and 6/30/2017 2 Sample(s) Required between 7/1/2017 and 7/31/2017 2 Sample(s) Required between 8/1/2017 and 8/31/2017 2 Sample(s) Required between 9/1/2017 and 9/30/2017 2 Sample(s) Required between 10/1/2017 and 10/31/2017 2 Sample(s) Required between 11/1/2017 and 11/30/2017 2 Sample(s) Required between 12/1/2017 and 12/31/2017

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: MANCHESTER, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	---------------------------------------------------------------------------------------	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2017

2017 DISTRIBUTION SCHEDULE

OH0100112 MANCHESTER VILLAGE

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: MANCHESTER, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	---------------------------------------------------------------------------------------	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH0100203 PEEBLES PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: PEEBLES, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	--------------------------------------------------------	--------------------------------

Chemicals	Monitoring Requirements
LEAD - 1030 AND COPPER - 1022	Not Required
ASBESTOS - 1094	Not Required
TOTAL COLIFORM (TCR) - 3100	2 Sample(s) Required between 1/1/2017 and 1/31/2017 2 Sample(s) Required between 2/1/2017 and 2/28/2017 2 Sample(s) Required between 3/1/2017 and 3/31/2017 2 Sample(s) Required between 4/1/2017 and 4/30/2017 2 Sample(s) Required between 5/1/2017 and 5/31/2017 2 Sample(s) Required between 6/1/2017 and 6/30/2017 2 Sample(s) Required between 7/1/2017 and 7/31/2017 2 Sample(s) Required between 8/1/2017 and 8/31/2017 2 Sample(s) Required between 9/1/2017 and 9/30/2017 2 Sample(s) Required between 10/1/2017 and 10/31/2017 2 Sample(s) Required between 11/1/2017 and 11/30/2017 2 Sample(s) Required between 12/1/2017 and 12/31/2017
TOTAL CHLORINE - 1000	2 Sample(s) Required between 1/1/2017 and 1/31/2017 2 Sample(s) Required between 2/1/2017 and 2/28/2017 2 Sample(s) Required between 3/1/2017 and 3/31/2017 2 Sample(s) Required between 4/1/2017 and 4/30/2017 2 Sample(s) Required between 5/1/2017 and 5/31/2017 2 Sample(s) Required between 6/1/2017 and 6/30/2017 2 Sample(s) Required between 7/1/2017 and 7/31/2017 2 Sample(s) Required between 8/1/2017 and 8/31/2017 2 Sample(s) Required between 9/1/2017 and 9/30/2017 2 Sample(s) Required between 10/1/2017 and 10/31/2017 2 Sample(s) Required between 11/1/2017 and 11/30/2017 2 Sample(s) Required between 12/1/2017 and 12/31/2017

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: PEEBLES, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	------------------------------------------------------------------------------------	--------------------------------

Chemicals	Monitoring Requirements
DISINFECTION BYPRODUCTS	Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2017

2017 DISTRIBUTION SCHEDULE

OH0100203 PEEBLES PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: PEEBLES, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	------------------------------------------------------------------------------------	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH0100303 SEAMAN VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: SEAMAN, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	-------------------------------------------------------	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required

TOTAL COLIFORM (TCR) - 3100	1 Sample(s) Required between	1/1/2017	and	1/31/2017
	1 Sample(s) Required between	2/1/2017	and	2/28/2017
	1 Sample(s) Required between	3/1/2017	and	3/31/2017
	1 Sample(s) Required between	4/1/2017	and	4/30/2017
	1 Sample(s) Required between	5/1/2017	and	5/31/2017
	1 Sample(s) Required between	6/1/2017	and	6/30/2017
	1 Sample(s) Required between	7/1/2017	and	7/31/2017
	1 Sample(s) Required between	8/1/2017	and	8/31/2017
	1 Sample(s) Required between	9/1/2017	and	9/30/2017
	1 Sample(s) Required between	10/1/2017	and	10/31/2017
	1 Sample(s) Required between	11/1/2017	and	11/30/2017
	1 Sample(s) Required between	12/1/2017	and	12/31/2017

TOTAL CHLORINE - 1000	1 Sample(s) Required between	1/1/2017	and	1/31/2017
	1 Sample(s) Required between	2/1/2017	and	2/28/2017
	1 Sample(s) Required between	3/1/2017	and	3/31/2017
	1 Sample(s) Required between	4/1/2017	and	4/30/2017
	1 Sample(s) Required between	5/1/2017	and	5/31/2017
	1 Sample(s) Required between	6/1/2017	and	6/30/2017
	1 Sample(s) Required between	7/1/2017	and	7/31/2017
	1 Sample(s) Required between	8/1/2017	and	8/31/2017
	1 Sample(s) Required between	9/1/2017	and	9/30/2017
	1 Sample(s) Required between	10/1/2017	and	10/31/2017
	1 Sample(s) Required between	11/1/2017	and	11/30/2017
	1 Sample(s) Required between	12/1/2017	and	12/31/2017

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: SEAMAN, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	-----------------------------------------------------------------------------------	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2017

2017 DISTRIBUTION SCHEDULE

OH0100303 SEAMAN VILLAGE PWS

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: SEAMAN, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	-----------------------------------------------------------------------------------	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH0100503 WEST UNION PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: WEST UNION, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	-----------------------------------------------------------	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required

ASBESTOS - 1094 Not Required

TOTAL COLIFORM (TCR) - 3100

4 Sample(s) Required between	1/1/2017	and	1/31/2017
4 Sample(s) Required between	2/1/2017	and	2/28/2017
4 Sample(s) Required between	3/1/2017	and	3/31/2017
4 Sample(s) Required between	4/1/2017	and	4/30/2017
4 Sample(s) Required between	5/1/2017	and	5/31/2017
4 Sample(s) Required between	6/1/2017	and	6/30/2017
4 Sample(s) Required between	7/1/2017	and	7/31/2017
4 Sample(s) Required between	8/1/2017	and	8/31/2017
4 Sample(s) Required between	9/1/2017	and	9/30/2017
4 Sample(s) Required between	10/1/2017	and	10/31/2017
4 Sample(s) Required between	11/1/2017	and	11/30/2017
4 Sample(s) Required between	12/1/2017	and	12/31/2017

TOTAL CHLORINE - 1000

4 Sample(s) Required between	1/1/2017	and	1/31/2017
4 Sample(s) Required between	2/1/2017	and	2/28/2017
4 Sample(s) Required between	3/1/2017	and	3/31/2017
4 Sample(s) Required between	4/1/2017	and	4/30/2017
4 Sample(s) Required between	5/1/2017	and	5/31/2017
4 Sample(s) Required between	6/1/2017	and	6/30/2017
4 Sample(s) Required between	7/1/2017	and	7/31/2017
4 Sample(s) Required between	8/1/2017	and	8/31/2017
4 Sample(s) Required between	9/1/2017	and	9/30/2017
4 Sample(s) Required between	10/1/2017	and	10/31/2017
4 Sample(s) Required between	11/1/2017	and	11/30/2017
4 Sample(s) Required between	12/1/2017	and	12/31/2017

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: WEST UNION, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	---------------------------------------------------------------------------------------	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2017

2017 DISTRIBUTION SCHEDULE

OH0100503 WEST UNION PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: WEST UNION, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	---------------------------------------------------------------------------------------	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH0100603 WINCHESTER PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule. Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: WINCHESTER, VILLAGE OF DISTRIBUTION	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	-----------------------------------------------------------	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 Not Required

ASBESTOS - 1094 Not Required

TOTAL COLIFORM (TCR) - 3100

2 Sample(s) Required between	1/1/2017	and	1/31/2017
2 Sample(s) Required between	2/1/2017	and	2/28/2017
2 Sample(s) Required between	3/1/2017	and	3/31/2017
2 Sample(s) Required between	4/1/2017	and	4/30/2017
2 Sample(s) Required between	5/1/2017	and	5/31/2017
2 Sample(s) Required between	6/1/2017	and	6/30/2017
2 Sample(s) Required between	7/1/2017	and	7/31/2017
2 Sample(s) Required between	8/1/2017	and	8/31/2017
2 Sample(s) Required between	9/1/2017	and	9/30/2017
2 Sample(s) Required between	10/1/2017	and	10/31/2017
2 Sample(s) Required between	11/1/2017	and	11/30/2017
2 Sample(s) Required between	12/1/2017	and	12/31/2017

TOTAL CHLORINE - 1000

2 Sample(s) Required between	1/1/2017	and	1/31/2017
2 Sample(s) Required between	2/1/2017	and	2/28/2017
2 Sample(s) Required between	3/1/2017	and	3/31/2017
2 Sample(s) Required between	4/1/2017	and	4/30/2017
2 Sample(s) Required between	5/1/2017	and	5/31/2017
2 Sample(s) Required between	6/1/2017	and	6/30/2017
2 Sample(s) Required between	7/1/2017	and	7/31/2017
2 Sample(s) Required between	8/1/2017	and	8/31/2017
2 Sample(s) Required between	9/1/2017	and	9/30/2017
2 Sample(s) Required between	10/1/2017	and	10/31/2017
2 Sample(s) Required between	11/1/2017	and	11/30/2017
2 Sample(s) Required between	12/1/2017	and	12/31/2017

Samples should be collected at the same time and place as the Total Coliform samples.

Sampling Location	Facility ID: DS1 SMP ID: DS201	Facility Name: WINCHESTER, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	---------------------------------------------------------------------------------------	--------------------------------

Chemicals Monitoring Requirements

DISINFECTION BYPRODUCTS Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS201

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



Effective Date: 01/01/2017

2017 DISTRIBUTION SCHEDULE

OH0100603 WINCHESTER PUBLIC WATER SYSTEM

System Type: Community

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

**** REMINDER: ** Consumer Confidence Report (CCR) is due July 1, 2017**

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS202	Facility Name: WINCHESTER, VILLAGE OF DISTRIBUTION ADDRESS NOT KNOWN	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	---------------------------------------------------------------------------------------	--------------------------------

Chemicals

Monitoring Requirements

DISINFECTION BYPRODUCTS

Dual Sample Required between 7/1/2017 and 9/30/2017 at: DS202

Sample for all the analytes listed below:

- 1) TOTAL HALOACETIC ACIDS (HAA5) – 2456
- 2) TTHM - 2950



OH0134112 DAYTON POWER AND LIGHT/JM STUART PWS

System Type: Nontransient Noncommunity

Operating Period: 1/1 to 12/31

ENTRY POINT MONITORING SCHEDULE

Sampling Location	Facility ID: 152626 SMP ID: EP001	Facility Name: DAYTON POWER & LIGHT CO JM STUART Facility Source: Ground Water	Facility Class: CLASS 1
--------------------------	----------------------------------------------------	-----------------------------------------------------------------------------------------------------	--------------------------------

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Monitoring Requirements
DIOXIN - 2063	Not Required
INORGANICS	1 Sample(s) Required between 1/1/2017 and 5/31/2017
<i>Sample for all the analytes listed below:</i>	
ANTIMONY, TOTAL - 1074 ARSENIC - 1005 BARIUM - 1010 BERYLLIUM, TOTAL - 1075 CADMIUM - 1015 CHROMIUM - 1020 CYANIDE - 1024 FLUORIDE - 1025 MERCURY - 1035 NICKEL - 1036 SELENIUM - 1045 THALLIUM, TOTAL - 1085	
NITRITE - 1041	Not Required
NITRATE - 1040	1 Sample(s) Required between 1/1/2017 and 5/31/2017
SYNTHETIC ORGANIC CHEMICALS (SOC) GROUP 1	1 Sample(s) Required between 1/1/2017 and 5/31/2017
<i>Sample for all the analytes listed below:</i>	
ALACHLOR (LASSO) - 2051 ATRAZINE - 2050 SIMAZINE - 2037	
VOLATILE ORGANIC CHEMICALS (VOC)	1 Sample(s) Required between 1/1/2017 and 5/31/2017



OH0134112 DAYTON POWER AND LIGHT/JM STUART PWS

System Type: Nontransient Noncommunity

Operating Period: 1/1 to 12/31

Ground Water Rule Substantial System

THIS SCHEDULE MAY NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for operating parameters, and/or other monitoring requirements not included on this schedule.

Also, monitoring schedules may be revised during the year based on sampling results.

For water emergencies that occur after hours, please call 800-282-9378

DISTRIBUTION MONITORING SCHEDULE

Sampling Location	Facility ID: DS1 SMP ID: DS000	Facility Name: DP&L/ JM STUART PLANT DISTRIBUTION	Facility Class: CLASS 1
--------------------------	-------------------------------------------------	--------------------------------------------------------------	--------------------------------

Chemicals Monitoring Requirements

LEAD - 1030 AND COPPER - 1022 5 Sample(s) Required between 6/1/2017 and 9/30/2017

Lead consumer notice must be completed no later than two business days after receipt of the sample results. The verification form for consumer notice must be submitted to Ohio EPA no later than five business days after receipt of the sample results. Form 5105 with appendix must be submitted to Ohio EPA within ten days from the end of the month(s) in which samples are collected. Forms are available online at: <http://epa.ohio.gov/ddagw/reporting.aspx>. For questions contact your Ohio EPA District Office representative.

TOTAL COLIFORM (TCR) - 3100

1 Sample(s) Required between 1/1/2017 and 3/31/2017

1 Sample(s) Required between 4/1/2017 and 6/30/2017

1 Sample(s) Required between 7/1/2017 and 9/30/2017

1 Sample(s) Required between 10/1/2017 and 12/31/2017