



RECEIVED  
OHIO EPA

PITS ✓

State of Ohio Environmental Protection Agency

MAR - 9 2007

Northeast District Office

DIV. OF HAZARDOUS  
WASTE MGT.

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

March 6, 2007

RE: HAZARDOUS WASTE PERMIT  
MODIFICATION  
CLASS 1A APPROVAL  
CHEMTRON CORPORATION  
OHD 066 060 609 / 02 47 0431

Mr. Ronald J. Guenther  
Chemtron Corporation  
35850 Schneider Ct.  
Avon, OH 44011

Dear Mr. Guenther:

On February 8, 2007, Ohio EPA received a request for a Class 1A hazardous waste permit modification (PITS tracking number 070212-1A-1) from Chemtron Corporation. With this letter, Ohio EPA approves the above referenced Class 1A modification submitted pursuant to Ohio Administrative Code (OAC) Rule 3745-50-51.

The following modification has been made to your December 31, 2003, Ohio Hazardous Waste Facility Installation and Operation Permit. Also, the records of Ohio EPA have been changed accordingly:

1. Non-appendix change for removal of Tank 10, which has been closed. Replacement of old Tank 1, which has been closed, with new Tank 1. New Tank 1 will be permitted to store D002 in addition to all the waste codes the old tank was permitted for. Capacity for Tank 1 will increase from 6,000 to 7,500 gallons. No new management practices due to adding D002.

In accordance with Ohio Administrative Code Rule 3745-50-51(D)(1)(a)(ii), Chemtron Corporation shall send a notice within 90 days of an approved Class 1A Modification to all persons on the Agency mailing list. An updated mailing list can be obtained by contacting Pamela Allen at (614) 644-2980, or by e-mail at [pamela.allen@epa.state.oh.us](mailto:pamela.allen@epa.state.oh.us).

If you have any questions concerning this action, please contact Edward D'Amato at the Ohio EPA Northeast District Office at (330) 963-1170.

Sincerely,

William T. Skowronski  
District Chief  
Northeast District Office

WTS/ED:ddw

- cc: Pamela Allen, Manager, RIS, DHWM, CO  
Jeremy Carroll, Supervisor, Engineering Unit, DHWM, CO
- ec: Edward D'Amato, DHWM, NEDO  
Frank Popotnik, DHWM, NEDO



State of Ohio Environmental Protection Agency

Northeast District Office

RECEIVED  
OHIO EPA

MAR 15 2007

DIV. OF HAZARDOUS  
WASTE MGT.

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

March 14, 2007

RE: HAZARDOUS WASTE PERMIT  
MODIFICATION  
CLASS 1A APPROVAL  
CHEMTRON CORPORATION  
OHD 066 060 609 / 02 47 0431

Mr. Ronald J. Guenther  
Chemtron Corporation  
35850 Schneider Ct.  
Avon, OH 44011

Dear Mr. Guenther:

On March 6, 2007, Ohio EPA approved a Class 1A hazardous waste permit modification (PITS tracking number 070212-1A-1) for removal of Tank 10 and the replacement of old Tank 1. I neglected to include the permit page that was updated as a result of the modification. The updated page is enclosed.

I apologize for any inconvenience.

Please feel free to contact me at (330) 963-1170 if you have any questions.

Sincerely,

Edward D'Amato  
Environmental Specialist  
Division of Hazardous Waste Management.

ED:ddw

cc: Pamela Allen, Manager, RIS, DHWM, CO  
Jeremy Carroll, Supervisor, Engineering Unit, DHWM, CO  
ec: Frank Popotnik, DHWM, NEDO

Tank No. Area of Location and Installation Year	Capacity (Gallons)	Dimensions of Tank	Secondary Containment Required	Description of Hazardous Waste	Hazardous Waste No.
Tank System W Area 6 1995 (installed, not used for hazardous waste)	5,200	8 ft. (diam) x 13.5 ft.	Yes - in place	Aqueous waste, waste organic solvents	Attachment II
Tank System X Area 6 1995 (installed, not used for hazardous waste)	5,200	8 ft. (diam) x 13.5 ft.	Yes - in place	Aqueous waste, waste organic solvents	Attachment II
Tank System Y Area 6 1995 (installed, not used for hazardous waste)	5,200	8 ft. (diam) x 13.5 ft.	Yes - in place	Aqueous waste, waste organic solvents	Attachment II

- (b) The Permittee shall store and treat in tanks only the hazardous waste codes specified in the approved Part B permit application and summarized in Attachment II.
- (c) The Permittee is prohibited from storing or treating hazardous waste that is not identified in this permit condition.
- (d) If the volume of waste in Tank 1 exceeds 6,000 gallons, the Permittee must prevent the total storage volume of Area 1 from exceeding 46,600 gallons.

**D.2 Design and Installation of New Tank Systems or Components**  
 OAC Rule 3745-55-92

- (a) The Permittee shall construct the tank system in accordance with Section D of the approved Part B application.
- (b) Prior to operation of the newly constructed tank system, the Permittee shall submit the certification of installation of the tank system in accordance with 3745-55-92(B) to ensure that proper handling procedures were adhered to in order to prevent damage to the system during installation.

MAR 6 2007  
 OHIO EPA NEDO