

Delaware County emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Ohio Wesleyan University" (OEPA premise number 0121010157) or any subsequent owner or operator of the "Ohio Wesleyan University" facility located at 41 Wilmer Street, Delaware, Ohio shall not cause or permit the emission of sulfur dioxide from boiler number 1 (OEPA source number B001) to exceed a maximum of 4.0 pounds of sulfur dioxide per MM Btu actual heat input.
- (C) The "Scioto Village" (OEPA premise number 0121009225) or any subsequent owner or operator of the "Scioto Village" facility located at 5993 Home Road, Powell, Ohio shall not cause or permit the emission of sulfur dioxide from boiler number 2 (OEPA source number B002) to exceed a maximum of 4.3 pounds of sulfur dioxide per MM Btu actual heat input.

R.C. 119.032 review dates: 10/28/2005 and 10/28/2010

CERTIFIED ELECTRONICALLY

Certification

10/28/2005

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03
Rule Amplifies: 3704.02
Prior Effective Dates: 12/28/79