

Greene County emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.4 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Central State University" (OEPA premise number 0829090062) or any subsequent owner or operator of the "Central State University" facility located at Wilberforce, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 3 (OEPA source numbers B003, B001 and B002) to exceed a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (C) The "Ohio Veterans Children's Home" (OEPA premise number 0829100113) or any subsequent owner or operator of the "Ohio Veterans Children's Home" facility located in Xenia, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 2 (OEPA source numbers B001 and B002) to exceed a maximum of 4.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler and shall operate said boilers such that the following combined average operating rates are not exceeded for any calendar day: first quarter, 26 MM Btu per hour; second quarter, 13 MM Btu per hour; third quarter, 13 MM Btu per hour; fourth quarter, 13 MM Btu per hour.
- (D) The "Antioch College" (OEPA premise number 0829110097) or any subsequent owner or operator of the "Antioch College" facility located in Yellow Springs, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amount indicated and shall limit the operation of said sources such that the indicated average operating rates are not exceeded for any calendar day:
- (1) Boiler number 1 (OEPA source number B001); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input and average operating rates as follows: first quarter, 13 MM Btu per hour; second quarter, 13 MM Btu per hour; third quarter, 34 MM Btu per hour; fourth quarter, 34 MM Btu per hour.
 - (2) Boiler number 2 (OEPA source number B002); a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input and average operating rates as follows: first quarter, 14 MM Btu per hour; second quarter, 14 MM Btu per hour; third quarter, 37 MM Btu per hour; fourth quarter, 37 MM Btu per hour.
- (E) The "Wright-Patterson Air Force Base" (OEPA premise number 0829700441); or any subsequent owner or operator of the "Wright-Patterson Air Force Base" facility located in building 20770, Bath, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 2 (OEPA source numbers B001 and B002) to exceed a maximum of 2.04 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

- (F) The "Wright-Patterson Air Force Base" (OEPA premise number 0829700441) or any subsequent owner or operator of the "Wright-Patterson Air Force Base" facility located in building 31240, Bath, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 2 to exceed a maximum of 2.04 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (G) The "CEMEX" (OEPA premise number 0829060018) or any subsequent owner or operator of the "CEMEX" facility located at 506 East Xenia Drive, Fairborn, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
- (1) Cement kiln numbers 1, 2, 3, and 4 (OEPA source numbers P010 through P013); a maximum of 0.0 pounds of sulfur dioxide per ton of cement produced.
 - (2) Cement kiln number 5 (OEPA source number P014); a maximum of 20.0 pounds of sulfur dioxide per ton of cement produced.
- (H) The "CEMEX - North Annex" (OEPA premise number 0829700088) or any subsequent owner or operator of the "CEMEX - North Annex" facility located on Route 444, Fairborn, Ohio shall not cause or permit the emission of sulfur dioxide from cement kiln numbers 2, 3, and 4 (OEPA source numbers P004 through P006) to exceed a maximum of 13.6 pounds of sulfur dioxide per ton of cement produced.
- (I) The "CEMEX" (OEPA premise number 0829810165) or any subsequent owner or operator of the "CEMEX" facility located at 3250 Linebaugh Rd, Xenia, Ohio shall not cause or permit the emission of sulfur dioxide from the quarry plant kiln (OEPA source number P003) to exceed a maximum of 9.0 pounds of sulfur dioxide per ton of product.

Effective: 01/23/2006

R.C. 119.032 review dates: 10/28/2005 and 01/23/2011

CERTIFIED ELECTRONICALLY
Certification

01/13/2006
Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A) and 3704.03(E)
Prior Effective Dates: 12/28/79