

3745-18-07

Adams county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Adams ccounty, unless otherwise specified ~~below~~ in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "~~Dayton Power and Light Company, DP&L, J. M. Stuart Electric~~ Generating Station" (OEPA premise number 0701000007) or any subsequent owner or operator of the "~~Dayton Power and Light Company DP&L, J. M. Stuart Electric~~ Generating Station," Aberdeen, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
- (1) Auxiliary boiler and diesel unit numbers 1 ~~through to~~ 4 (OEPA source numbers ~~B005 through B006 to~~ B009); a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each unit.
 - (2) Boiler numbers 1 ~~through to~~ 4 (OEPA source numbers B001 ~~through to~~ B004); a maximum of 3.16 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (C) The "Dayton Power and Light Company, Killen Electric Generating Station" (OEPA premise number 0701000060) or any subsequent owner or operator of the "Dayton Power and Light Company, Killen Electric Generating Station," Monroe Township, Ohio shall not cause or permit the emission of sulfur dioxide from boiler unit number 2 (OEPA source number B001) to exceed a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input.