

3745-18-13

**Belmont county emission limits.**

(A) No owner or operator of any coal-fired steam generating unit in Belmont county, unless otherwise specified ~~below~~ in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

~~(B) The "Ohio Edison Company, R.E. Burger Plant" (OEPA premise number 0607130015) or any subsequent owner or operator of the "Ohio Edison Company, R.E. Burger Plant" facility located in Shadyside, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:~~

~~(1) Diesel numbers A, B1, and B2 (OEPA source numbers B001, B002, and B003); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input from each diesel.~~

~~(2) Auxiliary heating boiler (OEPA source number B004); A maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(3) Boiler numbers 1 through 8 (OEPA source numbers B005 through B012); a maximum of 9.02 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

(B) [Reserved.]

(C) The "~~Wheeling-Pittsburgh Steel Corporation~~4K Industrial Park LLC" (OEPA premise number 0607090013) or any subsequent owner or operator of the "~~Wheeling-Pittsburgh Steel Corporation~~4K Industrial Park LLC" facility located in Martins Ferry, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated and shall limit the operation of said sources such that the indicated average operating rates are not exceeded for any calendar day:

(1) Boiler number 1 (OEPA source number B001); a maximum of 5.78 pounds of sulfur dioxide per MM Btu actual heat input.

(2) Boiler ~~numbers~~ number 2, ~~3, and 4~~ (OEPA source ~~numbers~~ number B002 ~~through B004~~); a maximum of 5.78 pounds of sulfur dioxide per MM Btu actual heat input.