

3745-18-17

Champaign county emission limits.

No owner or operator of any coal-fired steam generating unit in Champaign county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "Fox River Paper Co. Howard Mill" (OEPA premise number 0511010001) or any subsequent owner or operator of the "Fox River Paper Co. Howard Mill" facility located on West Church Street, Urbana, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:~~

~~(1) Boiler number 1 (OEPA source number B001); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(2) Boiler number 2 (OEPA source number B002); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input.~~