

3745-18-26

**Defiance county emission limits.**

- (A) No owner or operator of any coal-fired steam generating unit in Defiance county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
- ~~(B) The "Dinner Bell Foods" (OEPA premise number 0320010009) or any subsequent owner or operator of the "Dinner Bell Foods" facility located on West High street, Defiance, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 8 (OEPA source number B001) to exceed a maximum of 1.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~
- (B) [Reserved.]
- (C) The ~~"Toledo Edison Company~~Richland Substation Peaker Facility" (OEPA premise number 0320010006) or any subsequent owner or operator of the ~~"Toledo Edison Company~~Richland Substation Peaker Facility" facility located on Carpenter road, Defiance, Ohio shall not cause or permit the emission of sulfur dioxide from turbine numbers 1 ~~through to~~ 3 (OEPA source numbers B001 ~~through to~~ B003) to exceed a maximum of 0.7 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.

Effective: 02/16/2017

Five Year Review (FYR) Dates: 11/29/2016 and 11/29/2021

CERTIFIED ELECTRONICALLY

---

Certification

02/06/2017

---

Date

Promulgated Under: 119.03  
Statutory Authority: 3704.03(E)  
Rule Amplifies: 3704.03(A), 3704.03(E)  
Prior Effective Dates: 12/28/79, 2/17/11