

3745-18-35

Greene county emission limits.

(A) No owner or operator of any coal-fired steam generating unit [in Greene county](#), unless otherwise specified ~~below~~ [in this rule](#), shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.4 pounds of sulfur dioxide per MM Btu actual heat input.

(B) [\[Reserved.\]](#)

~~(C) The "Ohio Veterans Children's Home" (OEPA premise number 0829100113) or any subsequent owner or operator of the "Ohio Veterans Children's Home" facility located in Xenia, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 2 (OEPA source numbers B001 and B002) to exceed a maximum of 4.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler and shall operate said boilers such that the following combined average operating rates are not exceeded for any calendar day: first quarter, twenty six MM Btu per hour; second quarter, thirteen MM Btu per hour; third quarter, thirteen MM Btu per hour; fourth quarter, thirteen MM Btu per hour.~~

[\(C\) \[Reserved.\]](#)

(D) [\[Reserved.\]](#)

~~(E) The "Wright Patterson Air Force Base" (OEPA premise number 0829700441); or any subsequent owner or operator of the "Wright Patterson Air Force Base" facility located in building 20770, Bath, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 2 (OEPA source numbers B001 and B002) to exceed a maximum of 2.04 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

[\(E\) \[Reserved.\]](#)

(F) The "Wright-Patterson Air Force Base" (OEPA premise number 0829700441) or any subsequent owner or operator of the "Wright-Patterson Air Force Base" facility located in building 31240, Bath, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 2 to exceed a maximum of 2.04 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

(G) [\[Reserved.\]](#)

~~(H) The "CEMEX - North Annex" (OEPA premise number 0829700088) or any subsequent owner or operator of the "CEMEX - North Annex" facility located on Route 444, Fairborn, Ohio shall not cause or permit the emission of sulfur dioxide from cement kiln numbers 2, 3, and 4 (OEPA source numbers P004 through P006) to exceed a maximum of 13.6 pounds of sulfur dioxide per ton of cement produced.~~

[\(H\) \[Reserved.\]](#)

- (I) The "CEMEX" (OEPA premise number 0829810165) or any subsequent owner or operator of the "CEMEX" facility located at 3250 Linebaugh Rd, Xenia, Ohio shall not cause or permit the emission of sulfur dioxide from the quarry plant kiln (OEPA source number P003) to exceed a maximum of 9.0 pounds of sulfur dioxide per ton of product.