

3745-18-41

Henry county emission limits.

No owner or operator of any coal-fired steam generating unit in Henry county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "Campbell Soup Company" (OEPA premise number 0335010105) or any subsequent owner or operator of the "Campbell Soup Company" facility located in Napoleon, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:~~

~~(1) Boiler numbers 1 and 2 (OEPA source numbers B001 and B002); a maximum of 6.2 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(2) Boiler number 3 (OEPA source number B003); a maximum of 2.1 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(C) The "Municipal Electric Plant" (OEPA premise number 0335010014) or any subsequent owner or operator of the "Municipal Electric Plant" facility located in Napoleon, Ohio shall not cause or permit the emission of sulfur dioxide from unit number 5 (OEPA source number B001) to exceed a maximum of 5.88 pounds of sulfur dioxide per MM Btu actual heat input.~~