

3745-18-44

Holmes county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

- (B) The "Holmes By-Product, Incorporated" (OEPA premise number 0638000004) or any subsequent owner or operator of the "Holmes By-Product, Incorporated" facility located on route 5, Millersburg, Ohio shall not cause or permit the emission of sulfur dioxide from boiler number 1 (OEPA source number B001) to exceed a maximum of 4.0 pounds of sulfur dioxide per MM Btu actual heat input.

Effective: 02/17/2011

R.C. 119.032 review dates: 11/30/2010 and 11/30/2015

CERTIFIED ELECTRONICALLY
Certification

02/07/2011
Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79