

3745-18-45

**Huron county emission limits.**

No owner or operator of any coal-fired steam generating unit in Huron county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 8.0 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 8.0 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "Ohio Edison Company, Norwalk Plant" (OEPA premise number 0339020181) or any subsequent owner or operator of the "Ohio Edison Company, Norwalk Plant" facility located at 204 Woodlawn avenue, Norwalk Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 5 (OEPA source numbers B001 through B005) to exceed a maximum of 6.9 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(C) The "Central Soya Company, Incorporated" (OEPA premise number 0372010015) or any subsequent owner or operator of the "Central Soya Company, Incorporated" facility located on Goodrich road, Bellevue, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 3 (OEPA source numbers B001 through B003) to exceed a maximum of 5.9 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~