

3745-18-50

**Lawrence county emission limits.**

No owner or operator of any coal-fired steam generating unit in Lawrence county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) [Reserved]~~

~~(C) The "South Point Ethanol" (OEPA premise number 0744000009) or any subsequent owner or operator of the "South Point Ethanol" facility located in South Point, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 7 (OEPA source numbers B009, B006, B007, B002, B003, B005 and B004 to exceed a maximum of 5.1 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(D) The "Honeywell International, Inc." (OEPA premise number 0744010002) or any subsequent owner or operator of the "Honeywell International, Inc." facility located in Ironton, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1-09-833, 3-09-832, 2-09-836, 4-09-2144, 5-09-1937, 6-09-1938, 7-09-216, 8-09-217, 9-09-1383, and 10-09-1384 (OEPA source numbers B001 through B010) to exceed a maximum of 1.0 pounds of sulfur dioxide per MM Btu actual heat input from each unit.~~