

*** DRAFT - NOT YET FILED ***

3745-18-52

Logan county emission limits.

No owner or operator of any coal-fired steam generating unit [in Logan county](#) shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.