

3745-18-71

Pickaway county emission limits.

No owner or operator of any coal-fired steam generating unit in Pickaway county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "Columbus Southern Power Company, Pickaway Generating Plant" (OEPA premise number 0165000006) or any subsequent owner or operator of the "Columbus Southern Power Company, Pickaway Generating Plant" facility located in Lockbourne, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:~~

~~(1) Boiler numbers 7, 8 and 9 (OEPA source numbers B001, B002 and B004); a maximum of 5.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(2) Unit number 6 jet (OEPA source number B003); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(C) The "Orient State Institute" (OEPA premise number 0165000010) or any subsequent owner or operator of the "Orient State Institute" facility located in Orient, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 4 (OEPA source numbers B001 through B004) to exceed a maximum of 8.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~