

**Pike county emission limits.**

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 7.0 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "U.S. Enrichment Corporation" (OEPA premise number 0666000000) or any subsequent owner or operator of the "U.S. Enrichment Corporation," Piketon, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 3 (OEPA source numbers B001 through B003) to exceed a maximum of 6.16 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

Effective: 02/17/2011

R.C. 119.032 review dates: 11/30/2010 and 11/30/2015

CERTIFIED ELECTRONICALLY  
Certification

02/07/2011  
Date

Promulgated Under: 119.03  
Statutory Authority: 3704.03(E)  
Rule Amplifies: 3704.03(A), 3704.03(E)  
Prior Effective Dates: 12/28/79, 5/11/87, 1/23/06