

3745-18-76

Richland county emission limits.

No owner or operator of any coal-fired steam generating unit in Richland county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 7.1 pounds of sulfur dioxide per MM Btu actual heat input.

Replaces: 3745-18-76
Effective: 02/16/2017
Five Year Review (FYR) Dates: 11/29/2021

CERTIFIED ELECTRONICALLY

Certification

02/06/2017

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79, 1/23/06, 2/17/11