

3745-18-76

Richland county emission limits.

No owner or operator of any coal-fired steam generating unit in Richland county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 7.1 pounds of sulfur dioxide per MM Btu actual heat input.

~~(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 7.1 pounds of sulfur dioxide per MM Btu actual heat input.~~

~~(B) The "General Motors Corporation, Fisher Body Division, Mansfield Plant" (OEPA premise number 0370000140) or any subsequent owner or operator of the "General Motors Corporation, Fisher Body Division, Mansfield Plant" facility located at 2525 West Fourth street, Mansfield, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 3 (OEPA source numbers B001 through B003) to exceed a maximum of 3.1 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(C) [Reserved]~~

~~(D) [Reserved]~~

~~(E) The "Mansfield Products Company" (OEPA premise numbers 0370010182) or any subsequent owner or operator of the "Mansfield Products Company" facility located at 246 East Fourth street, Mansfield, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 4 (OEPA source numbers B001 and B004) to exceed 6.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler and shall operate said boilers such that their combined average operating rate shall not exceed one hundred ninety-seven MM Btu per hour for any calendar day.~~

~~(F) [Reserved]~~

~~(G) The "City of Shelby Municipal Light Plant" (OEPA premise number 0370020002) or any subsequent owner or operator of the "City of Shelby Municipal Light Plant" facility located at 34 Mansfield avenue, Shelby, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:~~

~~(1) Boiler numbers 1, 2, and 4 (OEPA source numbers B006, B007, and B008); a maximum of 8.1 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.~~

~~(2) Boiler number 3 (OEPA source number B003); a maximum of 0.0 pounds of sulfur dioxide per MM Btu actual heat input.~~