

Williams county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Toledo Edison Company, Stryker Substation" (OEPA premise number 0386000006) or any subsequent owner or operator of the "Toledo Edison Company, Stryker Substation" facility located on West Lynn street, Stryker, Ohio shall not cause or permit the emission of sulfur dioxide from turbine number 1 (OEPA source number B001) to exceed a maximum of 0.7 pounds of sulfur dioxide per MM Btu actual heat input.
- (C) The "Bryan Municipal Light and Water Utilities" (OEPA premise number 0386010200) or any subsequent owner or operator of the "Bryan Municipal Light and Water Utilities" facility located at 225 South Emmitt street, Bryan, Ohio shall not cause or permit the emission of sulfur dioxide from gas turbine numbers 5 and 6 (OEPA source numbers B002 and B003) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.

Effective: 02/17/2011

R.C. 119.032 review dates: 11/30/2010 and 11/30/2015

CERTIFIED ELECTRONICALLY
Certification

02/07/2011
Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79