

3745-18-92

**Williams county emission limits.**

- (A) No owner or operator of any coal-fired steam generating unit in Williams county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "~~Toledo Edison Company~~, Stryker Substation Peaker" (OEPA premise number 0386000006) or any subsequent owner or operator of the "~~Toledo Edison Company~~, Stryker Substation Peaker" facility located on ~~West Lynn~~ 101 Railroad street, Stryker, Ohio shall not cause or permit the emission of sulfur dioxide from turbine ~~number 1~~ W251G (OEPA source number ~~B001~~ P002) to exceed a maximum of 0.7 pounds of sulfur dioxide per MM Btu actual heat input.
- (C) The "Bryan Municipal Light and Water Utilities" (OEPA premise number 0386010200) or any subsequent owner or operator of the "Bryan Municipal Light and Water Utilities" facility located at 225 South Emmitt street, Bryan, Ohio shall not cause or permit the emission of sulfur dioxide from gas turbine numbers ~~5 and 6~~ and GT-1 (OEPA source numbers ~~B002 and B003~~ P004 and P005) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.