

Statement of Basis For Title V Permit

Part I - General

Company Name	AMP-Ohio Gas Turbines - Galion	
Premise Number	0317030060	
What makes this facility a Title V facility?	NOx and CO	
Has each insignificant emissions unit been reviewed to confirm it meets the definition in OAC rule 3745-77-01 (U)?	YES	
Were there any "common control" issues associated with this facility? If yes, provide a summary of those issues and explain how the DAPC decided to resolve them.	NO	
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a minor permit modification per OAC rule 3745-77-08(C)(1)	N/A	
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a significant permit modification per OAC rule 3745-77-08(C)(3)	N/A	
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a reopening per OAC rule 3745-77-08(D)	N/A	
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document resulting from a renewal per OAC rule 3745-77-08(E)	N/A	

Part II (State and Federally Enforceable Requirements)			
Term and Condition (paragraph)	Basis		Comments
	SIP (3745-)	Other	
N/A			

C

Instructions for Part II:

Each paragraph in Part II must be identified and the remainder of the table completed. If the SIP (not including 31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an "N" in the column under "SIP." If the basis for the term and condition is something other than the SIP, including 3745-31-05, NSPS or MACT, a "Y" should be noted in the "Other" column, and if not, an "N" should be noted. Whether the basis for the term and condition is the "SIP" or "Other," an explanation of each term and condition in Part II must be provided in the "Comments" section.

Part III (Requirements Within the State and Federally Enforceable Section)															
Any unusual requirements or aspects of the terms and conditions in Part III that are not self-explanatory should be explained in the appropriate comment field or in a paragraph following the table for Part III.															
EU(s)	Limitation	Basis		ND	OR	M	St	ENF	R	St	Rp	St	ET	Misc	Comments
		SIP (3745-)	Other												
P001, P002	NOx emissions shall not exceed 14 ppmvd at 15% Oxygen	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	Y	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. NOx CEMs will be used to ensure ongoing compliance. CAM is not currently applicable.

P001, P002	0.0140 lb PE/mmBtu heat input	N	31- 05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. CEMs are not economically justified. CAM is not currently applicable. ET-This limitation is based on the vendor's specifications and represents the worst case scenario emissions for this unit, therefore, no testing is required.
P001, P002	0.0057 lb SO ₂ /mmBtu heat input	N	31- 05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas and maximum sulfur content of natural gas not to exceed 0.068%, by weight. M and R includes type of fuel and fuel usage. CEMs are not economically justified. CAM is not currently applicable. ET-This limitation is based on the maximum sulfur content of natural gas allowed for this emission unit and represents the worst case scenario emissions, therefore, no testing is required.
P001, P002	0.1120 lbs CO/mmBtu heat input	N	31- 05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	Y	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable.
P001, P002	Visible PE from any stack shall not exceed 10% opacity as a six- minute average	N	31- 05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. COMs are not economically justified. CAM is not currently applicable. ET-The M, R & Rp requirements are sufficient to demonstrate compliance without requiring formal Method 9 readings being conducted.
P001	13.12 lbs NOx/hr	N	31- 05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	Y	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. NOx CEMs will be used to ensure ongoing compliance. CAM is not currently applicable.
P001	3.56 lbs PE/hr	N	31- 05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. Monitoring includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable. ET- The limitation is based on the unit's potential to emit, therefore, no testing is required.

P001	4.0 tons PE/yr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable. ET-Calculations based on maximum hourly potential to emit and actual annual hours of operation are sufficient to show compliance.
P001	1.45 lbs SO ₂ /hr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas and maximum sulfur content of natural gas not to exceed 0.068%, by weight. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable. ET-The limitation is based on the unit's potential to emit, therefore, no testing is required.
P001	1.6 tons SO ₂ /yr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas and maximum sulfur content of natural gas not to exceed 0.068%, by weight. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable. ET-Calculations based on maximum hourly potential to emit and actual annual hours of operation are sufficient to show compliance.
P001	28.47 lbs CO/hr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	Y	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable.
P001	2.29 lbs VOC/hr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. ACEM is not economically justified. CAM is not currently applicable. ET-ET-The limitation is based on the unit's potential to emit, therefore, no testing is required.
P001	2.6 tons VOC/yr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable. ET-Calculations based on maximum hourly potential to emit and actual annual hours of operation are sufficient to show compliance.

P001	0.18 lb formaldehy de/hr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable. ET-Calculations based on the maximum heat input of 254.2 mmBtu/hr and the emission factor of 0.00071 lb/mmBtu heat input (AP-42, Section 3.1) are sufficient to show compliance.
P001	0.2 tons formaldehy de/yr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A CEM is not economically justified. CAM is not currently applicable. ET-Calculations based on maximum hourly potential to emit and actual annual hours of operation are sufficient to show compliance.
P001	Startup and Shutdown Emissions: 2.5 tons NOx/yr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A NOx CEM will be used to ensure that the emission unit does not exceed the presumed hourly NOx emission rate, which is used to calculate the tons/yr limit. CAM is not currently applicable. ET-Calculations based on the maximum hourly rate of 38.0 lbs NOx/hr for startup and shutdown periods and the actual annual hours of startup and shutdowns are sufficient to show compliance.
P001	Startup and Shutdown Emissions: 1.0 tons CO/yr	N	31-05(A)(3)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas. M and R includes type of fuel and fuel usage. A CEM is are not economically justified. CAM is not currently applicable. ET-Calculations based on the maximum hourly rate of 13.0 lbs CO/hr for startup and shutdown periods and the actual annual hours of startup and shutdowns are sufficient to show compliance.
P001	14.8 tons NOx per rolling 12-month period	N	31-05(D)	N	Y	Y	N	N	Y	N	Y	N	N	N	OR- Combust only natural gas and annual operational restriction of 2250 hours based upon a rolling, 12-month period. M and R includes type of fuel and fuel usage. CAM is not currently applicable. ET-Calculations based on actual CEM data or the most recent emission test and annual operational restriction of 2250 hours based upon a rolling 12-month period are sufficient to show compliance.

EU = emissions unit ID

ND = negative declaration (i.e., term that indicates that a particular rule(s) is (are) not applicable to a specific emissions unit)

OR = operational restriction

M = monitoring requirements

St = streamlining term used to replace a PTI monitoring, record keeping, or reporting requirement with an equivalent or more stringent requirement

ENF = did noncompliance issues drive the monitoring requirements?

R = record keeping requirements

Rp = reporting requirements

ET = emission testing requirements (not including compliance method terms)

Misc = miscellaneous requirements

C Instructions for Part III:

- C All non-insignificant EUs must be included in this table. For each EU, or group of similar EUs, each emission limitation and control requirement specified in section A.I.1 and A.I.2 of the permit must be identified and the remainder of the table completed.
- C If the SIP (not including OAC rule 3745-31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an "N" in the column under "SIP." If the basis for the term and condition is something other than the SIP, including OAC rule 3745-31-05, NSPS or MACT, a "Y" should be noted in the "Other" column, and if not, an "N" should be noted. If the basis for the term and condition is "Other," an explanation of the basis must be provided in the "Comments" section. If OAC rule 3745-31-05 is cited in the "Other" column, please indicate in the "Comments" section whether or not all of the requirements have been transferred from the permit to install.
- To complete the remainder of the table after "Basis," except for the "Comments" section, simply specify a "Y" for yes or an "N" for no. For the "M," "R," "Rp," and "ET" columns, if "N" is specified, there should be a brief explanation in the "Comments" section as to why there are no requirements. If a brief explanation is provided in the "Comments" section, please do not simply indicate that monitoring or testing requirements are not necessary. An explanation of why a requirement is not necessary should be specified.

When periodic monitoring requirements are established to satisfy the provisions of OAC rule 3745-77-07(A)(3)(a)(ii), the basis for the requirements must be explained. Whenever Engineering Guides have been used to establish the periodic monitoring requirements, the applicable Engineering Guide may be referenced in the "Comments" section. An example that should be clarified would be the situation where it has been determined that control equipment parametric monitoring will be used to evaluate ongoing compliance in lieu of performing frequent emission tests. In this situation, Engineering Guide #65 would be referenced along with the fact that the parametric monitoring range (or minimum value) corresponded to the range (or minimum value) documented during the most recent emission tests that demonstrated that the emissions unit was in compliance. If streamlining language is included in the "Monitoring," "Record Keeping," or "Reporting" requirements sections of the permit, explain which requirements are being streamlined (mark appropriate column above) and provide a brief explanation of why the streamlined term is equal to or more stringent than the "Monitoring," "Record Keeping," or "Reporting" requirements specified in the permit to install. If Engineering Guide #16 was used as the basis for establishing an emission test frequency, a simple note referencing the Engineering Guide in the "Comments" section would be sufficient.

Also, if a "Y" is noted under "OR," "Misc," "St," "ND," or "ENF" an explanation of the requirements must be provided in the "Comments" section. In addition to a general explanation of the "OR," "Misc," "St," "ND," and/or "ENF" the following must be provided:

1. For an operational restriction, clarify if appropriate monitoring, record keeping, and reporting requirements have been specified for the operational restriction and indicate whether or not CAM is currently applicable.
2. If a control plan and schedule is included in the "Miscellaneous Requirements" section of the permit, provide an explanation in the "Comments" section of the violation, basis for the violation, and the company's proposed control plan and schedule.

3. If the "ND" column above is marked, please identify the particular rule(s) that is (are) not applicable to the specified emissions unit.
2. If the "ENF" column above is marked, please provide a brief explanation of the noncompliance issue(s) which prompted the use of the specified monitoring requirement.

An explanation is not required if an "N" is noted in the "OR," "Misc," "St," "ND," or "ENF" columns.

- **Additional information for modifications** - Several types of modifications, as defined by rule, may be processed concurrently. Please provide enough of a description for someone wishing to review the changes to the permit language to be able to identify where the change is made in the permit document. This brief description should be identified in the appropriate row in the first table of this form by replacing the "N/A" in the applicable row(s). Please also indicate if the modification is being initiated by an appeal by including the ERAC case number in the "Comments" area. Please update the term-specific text in the SOB as warranted (full insertion or replacement is acceptable; bold italic and strike out is not needed). Note all modification/reopening rows should remain "N/A" when developing the SOB during the initial permit development. Note: APA's and Off-permit changes do not need to be noted in the SOB.