



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center  
50 West Town Street, Suite 700  
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center  
P.O. Box 1049  
Columbus, OH 43216-1049

09/11/07

**CERTIFIED MAIL**

**RE: Preliminary Proposed Title V  
Chapter 3745-77 permit**

03-20-01-0169  
ANR Pipeline Company  
Corrie J Towns Ms.  
27725 Stansbury Blvd., Suite 200  
Farmington Hills, MI 48334

Dear Corrie J Towns:

Enclosed is the Ohio EPA Preliminary Proposed Title V permit that was issued in draft form on 04/18/07. The comment period for the Draft permit has ended. We are now ready to submit this permit to USEPA for approval.

We are submitting this for your review and comment. If you do not agree with the Preliminary Proposed Title V permit as written, you now have the opportunity to raise your concerns. **In order to facilitate our review of all the comments or concerns you may have with the enclosed preliminary proposed permit, please provide a hand marked-up copy of the permit showing the changes you think are necessary, along with any additional summary comments, within fourteen (14) days from your receipt of this letter to:**

**Andrew Hall  
Permit Review/Development Section  
Ohio EPA, Division of Air Pollution Control  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, Ohio 43215**

and

Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402  
(419) 352-8461

Also, if you believe that it is necessary to have an informal conference with us, then, as part of your written comments, you should request a conference concerning the written comments.

If comments are not submitted within fourteen (14) days of your receipt of this letter, we will forward the proposed permit to USEPA for approval. All comments received will be carefully considered before proceeding to the proposed permit.

Sincerely,

*Michael W. Ahern*  
Michael W. Ahern, Manager  
Permit Issuance and Data Management Section  
Division of Air Pollution Control

cc: Northwest District Office  
File, DAPC PIER



State of Ohio Environmental Protection Agency

PRELIMINARY PROPOSED TITLE V PERMIT

Issue Date: 09/11/07

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance of a Title V permit for Facility ID: 03-20-01-0169 to:

ANR Pipeline Company
6357 State Route 66 North
Defiance, OH 43512

Emissions Unit ID (Company ID)/Emissions Unit Activity Description

Table with 3 columns: Emissions Unit ID (Company ID), Emissions Unit Activity Description, and Emissions Unit Activity Description. Rows include units P001 through P010, detailing compressor engines and natural gas compression using internal combustion engines for transport via pipeline.

You will be contacted approximately eighteen (18) months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency listed below. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above.

Described below is the current Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402
(419) 352-8461

Ohio Environmental Protection Agency

Chris Korleski
Director

## PART I - GENERAL TERMS AND CONDITIONS

### A. State and Federally Enforceable Section

#### 1. Monitoring and Related Record Keeping and Reporting Requirements

a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, i.e., in Section A.III of Part III of this Title V permit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:

- i. The date, place (as defined in the permit), and time of sampling or measurements.
- ii. The date(s) analyses were performed.
- iii. The company or entity that performed the analyses.
- iv. The analytical techniques or methods used.
- v. The results of such analyses.
- vi. The operating conditions existing at the time of sampling or measurement.  
(Authority for term: OAC rule 3745-77-07(A)(3)(b)(i))

b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

(Authority for term: OAC rule 3745-77-07(A)(3)(b)(ii))

c. The permittee shall submit required reports in the following manner:

- i. **All reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations caused by malfunctions shall be submitted in the following manner:**

Any malfunction, as defined in OAC rule 3745-15-06(B)(1), shall be promptly reported to the Ohio EPA in accordance with OAC rule 3745-15-06. In addition, to fulfill the OAC rule 3745-77-07(A)(3)(c) deviation reporting requirements for malfunctions, written reports that identify each malfunction that occurred during each calendar quarter (including each malfunction reported only verbally in accordance with OAC rule 3745-15-06) shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year in accordance with General Term and Condition A.1.c.ii below; and each report shall cover the previous calendar quarter. (An exceedance of the visible emission limitations specified in OAC rule 3745-17-07(A)(1) that is caused by a malfunction is not a violation and does not need to be reported as a deviation if the owner or operator of the affected air contaminant source or air pollution control equipment complies with the requirements of OAC rule 3745-17-07(A)(3)(c).)

In accordance with OAC rule 3745-15-06, a malfunction reportable under OAC rule 3745-15-06(B) constitutes a violation of an emission limitation (or control requirement) and, therefore, is a deviation of the federally enforceable permit requirements. Even though verbal notifications and written reports are required for malfunctions pursuant to OAC rule 3745-15-06, the written reports required pursuant to this term must be submitted quarterly to satisfy the prompt reporting provision of OAC rule 3745-77-07(A)(3)(c).

In identifying each deviation caused by a malfunction, the permittee shall specify the emission limitation(s) (or control requirement(s)) for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. For a specific malfunction, if this information has been provided in a written report that was submitted in accordance with OAC rule 3745-15-06, the permittee may simply reference that written report to identify the deviation. Nevertheless, all malfunctions, including those

reported only verbally in accordance with OAC rule 3745-15-06, must be reported in writing on a quarterly basis.

Any scheduled maintenance, as referenced in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described above for malfunctions.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

- ii. **Except as may otherwise be provided in the terms and conditions for a specific emissions unit, i.e., in Section A.IV of Part III of this Title V permit or, in some cases, in Part II of this Title V permit, all reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations of the emission limitations, operational restrictions, and control device operating parameter limitations shall be submitted in the following manner:**

Written reports of (a) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. Except as provided below, the written reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

In identifying each deviation, the permittee shall specify the emission limitation(s), operational restriction(s), and/or control device operating parameter limitation(s) for which the deviation occurred, describe each deviation, and provide the estimated magnitude and duration of each deviation.

These written deviation reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations. Full compliance with OAC rule 3745-77-07(A)(3)(c) requires reporting of all other deviations of the federally enforceable requirements specified in the permit as required by such rule.

If an emissions unit has a deviation reporting requirement for a specific emission limitation, operational restriction, or control device operating parameter limitation that is not on a quarterly basis (e.g., within 30 days following the end of the calendar month, or within 30 or 45 days after the exceedance occurs), that deviation reporting requirement satisfies the reporting requirements specified in this General Term and Condition for that specific emission limitation, operational restriction, or control device parameter limitation. Following the provisions of that non-quarterly deviation reporting requirement will also satisfy (for the deviations so reported) the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations, and additional quarterly deviation reports for that specific emission limitation, operational restriction, or control device parameter limitation are not required pursuant to this General Term and Condition.

See B.6 below if no deviations occurred during the quarter.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

- iii. **All reporting required in accordance with the OAC rule 3745-77-07(A)(3)(c) for other deviations of the federally enforceable permit requirements which are not reported in accordance with General Term and Condition A.1.c.ii above shall be submitted in the following manner:**

Unless otherwise specified by rule, written reports that identify deviations of the following federally enforceable requirements contained in this permit; General Terms and Conditions: A.2, A.3, A.4, A.6.e, A.7, A.12, A.14, A.18, A.19, A.20, and A.22 of Part I of this Title V permit, as well as any deviations from the requirements in Section A.V or A.VI of Part III of this Title V permit, and any monitoring, record keeping, and reporting requirements, which are not reported in accordance with General Term and Condition A.1.c.ii above shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office or local air agency by January 31 and July 31 of each year; and each report shall cover the previous six calendar months. Unless otherwise specified by rule, all other deviations from federally enforceable requirements identified in this permit shall be submitted annually as part of the annual compliance certification, including deviations of federally enforceable requirements not specifically addressed by permit or rule for the insignificant activities or emissions levels (IEU) identified in Part II.A of this Title V

permit. Annual reporting of deviations is deemed adequate to meet the deviation reporting requirements for IEUs unless otherwise specified by permit or rule.

In identifying each deviation, the permittee shall specify the federally enforceable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation.

These semi-annual and annual written reports shall satisfy the reporting requirements of OAC rule 3745-77-07(A)(3)(c) for any deviations from the federally enforceable requirements contained in this permit that are not reported in accordance with General Term and Condition A.1.c.ii above.

If no such deviations occurred during a six-month period, the permittee shall submit a semi-annual report which states that no such deviations occurred during that period.

*(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i) and (ii) and OAC rule 3745-77-07(A)(13)(b))*

- iv. Each written report shall be signed by a responsible official certifying that, "based on information and belief formed after reasonable inquiry, the statements and information in the report (including any written malfunction reports required by OAC rule 3745-15-06 that are referenced in the deviation reports) are true, accurate, and complete."

*(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iv))*

- v. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

## 2. **Scheduled Maintenance**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. Except as provided in OAC rule 3745-15-06(A)(3), any scheduled maintenance necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s). Any scheduled maintenance, as defined in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described for malfunctions in General Term and Condition A.1.c.i above.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

## 3. **Risk Management Plans**

If applicable, the permittee shall develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. § 7401 et seq. ("Act"); and, pursuant to 40 C.F.R. 68.215(a), the permittee shall submit either of the following:

- a. a compliance plan for meeting the requirements of 40 C.F.R. Part 68 by the date specified in 40 C.F.R. 68.10(a) and OAC 3745-104-05(A); or
- b. as part of the compliance certification submitted under 40 C.F.R. 70.6(c)(5), a certification statement that the source is in compliance with all requirements of 40 C.F.R. Part 68 and OAC Chapter 3745-104, including the registration and submission of the risk management plan.

*(Authority for term: OAC rule 3745-77-07(A)(4))*

## 4. **Title IV Provisions**

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

*(Authority for term: OAC rule 3745-77-07(A)(5))*

## 5. **Severability Clause**

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

*(Authority for term: OAC rule 3745-77-07(A)(6))*

## 6. **General Requirements**

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause, in accordance with A.10 below. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.
- f. Except as otherwise indicated below, this Title V permit, or permit modification, is effective for five years from the original effective date specified in the permit. In the event that this facility becomes eligible for non-title V permits, this permit shall cease to be enforceable upon final issuance of all applicable OAC Chapter 3745-35 operating permits and/or registrations for all subject emissions units located at the facility and:
  - i. the permittee submits an approved facility-wide potential to emit analysis supporting a claim that the facility no longer meets the definition of a “major source” as defined in OAC rule 3745-77-01(W) based on the permanent shutdown and removal of one or more emissions units identified in this permit; or
  - ii. the permittee no longer meets the definition of a “major source” as defined in OAC rule 3745-77-01(W) based on obtaining restrictions on the facility-wide potential(s) to emit that are federally enforceable or legally and practically enforceable ; or
  - iii. a combination of i. and ii. above.

The permittee shall comply with any residual requirements, such as quarterly deviation reports, semi-annual deviation reports, and annual compliance certifications covering the period during which this Title V permit was enforceable. All records relating to this permit must be maintained in accordance with law.

*(Authority for term: OAC rule 3745-77-01(W), OAC rule 3745-77-07(A)(3)(b)(ii), OAC rule 3745-77(A)(7))*

**7. Fees**

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

*(Authority for term: OAC rule 3745-77-07(A)(8))*

**8. Marketable Permit Programs**

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.

*(Authority for term: OAC rule 3745-77-07(A)(9))*

**9. Reasonably Anticipated Operating Scenarios**

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these general terms and conditions shall apply to all operating scenarios authorized in this permit.

*(Authority for term: OAC rule 3745-77-07(A)(10))*

**10. Reopening for Cause**

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a. Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.
- b. This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c. The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.
- d. The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

*(Authority for term: OAC rules 3745-77-07(A)(12) and 3745-77-08(D))*

**11. Federal and State Enforceability**

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

*(Authority for term: OAC rule 3745-77-07(B))*

**12. Compliance Requirements**

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
  - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
  - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.
  - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
  - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
  - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.

- ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.
- d. Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) and the Administrator of the U.S. EPA in the following manner and with the following content:
  - i. Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted (i.e., postmarked) on or before April 30th of each year during the permit term.
  - ii. Compliance certifications shall include the following:
    - (a) An identification of each term or condition of this permit that is the basis of the certification.
    - (b) The permittee's current compliance status.
    - (c) Whether compliance was continuous or intermittent.
    - (d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.
    - (e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.
  - iii. Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

*(Authority for term: OAC rules 3745-77-07(C)(1),(2),(4) and (5) and ORC section 3704.03(L))*

**13. Permit Shield**

- a. Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.
  - b. This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.
- (Authority for term: OAC rule 3745-77-07(F))*

**14. Operational Flexibility**

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

*(Authority for term: OAC rules 3745-77-07(H)(1) and (2))*

**15. Emergencies**

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

*(Authority for term: OAC rule 3745-77-07(G))*

**16. Off-Permit Changes**

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a. The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition.
- b. The permittee provides contemporaneous written notice of the change to the Director and the Administrator of the U.S. EPA, except that no such notice shall be required for changes that qualify as insignificant emissions levels or activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change.
- c. The change shall not qualify for the permit shield under OAC rule 3745-77-07(F).
- d. The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.
- e. The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit to install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.

*(Authority for term: OAC rule 3745-77-07(I))*

**17. Compliance Method Requirements**

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.

*(This term is provided for informational purposes only.)*

**18. Insignificant Activities or Emissions Levels**

Each IEU that has one or more applicable requirements shall comply with those applicable requirements.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**19. Permit to Install Requirement**

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**20. Air Pollution Nuisance**

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**21. Permanent Shutdown of an Emissions Unit**

The permittee may notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification from the responsible official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the responsible official that the emissions unit was permanently shut down.

After the date on which an emissions unit is permanently shut down (i.e., that has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31 and therefore ceases to meet the definition of an "emissions unit" as defined in OAC rule 3745-77-01(O)), rendering existing permit terms and conditions irrelevant, the permittee shall not be required, after the date of the

certification and submission to Ohio EPA, to meet any Title V permit requirements applicable to that emissions unit, except for any residual requirements, such as the quarterly deviation reports, semi-annual deviation reports and annual compliance certification covering the period during which the emissions unit last operated. All records relating to the shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law.

No emissions unit certified by the responsible official as being permanently shut down may resume operation without first applying for and obtaining a permit to install pursuant to OAC Chapter 3745-31.  
(Authority for term: OAC rule 3745-77-01)

**22. Title VI Provisions**

If applicable, the permittee shall comply with the standards for recycling and reducing emissions of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:

- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices specified in 40 CFR 82.156.
- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment specified in 40 CFR 82.158.
- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

(Authority for term: OAC rule 3745-77-01(H)(11))

**B. State Only Enforceable Section**

**1. Reporting Requirements Related to Monitoring and Record Keeping Requirements**

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (i) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

**2. Records Retention Requirements**

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

**3. Inspections and Information Requests**

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

**4. Scheduled Maintenance/Malfunction Reporting**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

**5. Permit Transfers**

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

**6. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)**

If no emission limitation (or control requirement), operational restriction and/or control device parameter limitation deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

The permittee is not required to submit a quarterly report which states that no deviations occurred during that quarter for the following situations:

- a. where an emissions unit has deviation reporting requirements for a specific emission limitation, operational restriction, or control device parameter limitation that override the deviation reporting requirements specified in General Term and Condition A.1.c.ii; or
- b. where an uncontrolled emissions unit has no monitoring, record keeping, or reporting requirements and the emissions unit's applicable emission limitations are established at the potentials to emit; or
- c. where the company's responsible official has certified that an emissions unit has been permanently shut down.

## Part II - Specific Facility Terms and Conditions

### A. State and Federally Enforceable Section

None

### B. State Only Enforceable Section

1. The following insignificant emissions units located at this facility are exempt from permit requirements because they are not subject to any applicable requirements or because they meet the "de minimis" criteria established in OAC rule 3745-15-05:

T001 - Natural gas condensate storage tank, TK-4 (11,753 gallons);  
P015 - emergency natural gas fired electrical generator;  
Z012 - New engine oil storage tank, TK-1 (11,753 gallons);  
Z013 - New engine oil storage tank, TK-2 (11,753 gallons);  
Z014 - Ambient tank, TK-3A (7,520 gallons);  
Z015 - Used engine oil storage tank, TK-5 (11,753 gallons);  
Z016 - Ambient tank, TK-3B (4,260 gallons);  
Z017 - Used engine oil storage tank (Z), TK-6 (2,938 gallons);  
Z018 - Used engine oil storage tank (KVR), TK-7 (2,044 gallons);  
Z019 - Used engine oil storage tank (GMVH), TK-8 (370 gallons);  
Z020 - Ambient tank (GMVH), TK-9 (1,269 gallons);  
Z021 - Gasoline storage tank, TK-10 (367 gallons);  
Z022 - Diesel fuel storage tank, TK-11 (367 gallons);  
Z023 - Two (2) boilers (4.184 mmBtu/hr);  
Z024 - GMVH used engine oil tank (69 gallons);  
Z025 - KVS used engine oil tank-1 (529 gallons);  
Z026 - KVS used engine oil tank-2 (174 gallons);  
Z027 - KVR and Z330 used engine oil tank (441 gallons);  
Z028 - Safety klean parts washer;  
Z029 - Fugitives - component leaks; and,  
Z030 - Fugitives - blowdown emissions.

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 2,250 hp, ENG 1110 (P001)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Cooper-Bessemer engine, Model GMVH10C, 2250 hp, 2-stroke lean burn (2SLB) reciprocating internal combustion engine (RICE) (Engine 1110)	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.I.2.a).
	OAC rule 3745-31-05(A)(3) (PTI# 03-9399 issued February 28, 1996)	0.87 lb PE/hr, 3.83 tons PE/yr
		55.93 lbs nitrogen oxides (NOx)/hr, 244.97 tons NOx/yr
		7.0 lbs organic compounds (OC)/hr, 30.66 tons OC/yr
		0.02 lb sulfur dioxide (SO <sub>2</sub> )/hr, 0.10 ton SO <sub>2</sub> /yr
	11.51 lbs carbon monoxide (CO)/hr, 50.40 tons CO/yr	
		The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-11(B)(5)(b) and 3745-17-07(A).
	40 CFR, Part 63, Subpart ZZZZ	See A.I.2.b.

##### 2. Additional Terms and Conditions

- Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.

## **2. Additional Terms and Conditions (continued)**

- 2.b** This emissions unit is an existing spark ignition, 2SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).
- 2.c** The hourly allowable emission limitations for PE, NO<sub>x</sub>, OC, SO<sub>2</sub> and CO are established for PTI purposes to reflect the potentials to emit for this emissions unit. Therefore, no record keeping, monitoring and reporting requirements are necessary to ensure compliance with these limitations.

## **II. Operational Restrictions**

1. The permittee shall burn only natural gas in this emissions unit.  
[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 03-9399]

## **III. Monitoring and/or Record Keeping Requirements**

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.  
[Authority for term: OAC rule 3745-77-07(C)(1)]

## **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.  
[Authority for term: OAC rule 3745-77-07(C)(1)]

## **V. Testing Requirements**

1. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
- 1.a** The emission testing shall be conducted at least 6 months prior to permit expiration.
- 1.b** The emission testing shall be conducted to demonstrate compliance with the allowable mass emission rate for NO<sub>x</sub>.
- 1.c** The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):
- i. for NO<sub>x</sub>, Methods 1 through 4 and 7 of 40 CFR, Part 60, Appendix A.
- 1.d** The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency.

## V. Testing Requirements (continued)

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA District Office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA District Office's or local air agency's refusal to accept the results of the emission test(s).

Personnel from the appropriate Ohio EPA District Office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA District Office or local air agency.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 03-9399]

**2.** Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

**2.a** Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

**2.b** Emission Limitations: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the limitation above based on an emission factor from AP-42, Table 3.2-1 (revised 7/00) of 0.0384 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

**2.c** Emission Limitations: 0.87 lb PE/hr, 3.83 tons PE/yr

Applicable Compliance Method: The permittee may determine compliance with the hourly allowable PE limitation by multiplying the appropriate emission factor from AP-42, Table 3.2-1 (revised 7/00) by the maximum hourly heat input rate (mmBtu/hr).

If required, compliance with the hourly allowable PE limitation shall be determined in accordance with Methods 1 through 5 of 40 CFR, Part 60,, Appendix A.

Provided compliance is shown with the hourly allowable PE emission limitation, compliance with the annual limitation shall be ensured (the annual allowable limitation was developed by multiplying the hourly allowable limitation by 8760, and then dividing by 2000).

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 03-9399]

## V. Testing Requirements (continued)

### 2.d Emission Limitations: 55.93 lbs NO<sub>x</sub>/hr, 244.97 tons NO<sub>x</sub>/yr

Applicable Compliance Method: The permittee shall demonstrate compliance with the hourly emission limitation above based upon the results of emission testing conducted in accordance with 40 CFR, Part 60, Appendix A, Methods 1 through 4 and 7.

The annual emission limitation was determined by multiplying the hourly limitation by 8760, and then dividing by 2000. Therefore, provided compliance is shown with the hourly limitation, compliance shall also be shown with the annual limitation.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 03-9399]

### 2.e Emission Limitations: 7.0 lbs OC/hr, 30.66 tons OC/yr

Applicable Compliance Method: The permittee may determine compliance with the hourly allowable OC emission limitation by multiplying the appropriate emission factor from AP-42, Table 3.2-1 (revised 7/00) by the maximum hourly heat input rate (mmBtu/hr).

If required, compliance with the hourly allowable OC limitation shall be determined in accordance with Methods 1 through 4 and 18, 25 or 25A of 40 CFR, Part 60,, Appendix A.

Provided compliance is shown with the hourly allowable OC emission limitation, compliance with the annual limitation shall be ensured (the annual allowable limitation was developed by multiplying the hourly allowable limitation by 8760, and then dividing by 2000).

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 03-9399]

### 2.f Emission Limitations: 0.02 lb SO<sub>2</sub>/hr, 0.10 ton SO<sub>2</sub>/yr

Applicable Compliance Method: The permittee may determine compliance with the hourly allowable SO<sub>2</sub> emission limitation by multiplying the appropriate emission factor from AP-42, Table 3.2-1 (revised 7/00) by the maximum hourly heat input rate (mmBtu/hr).

If required, compliance with the hourly allowable SO<sub>2</sub> emission limitation shall be determined in accordance with the methods specified OAC rule 3745-18-04(F)(4).

Provided compliance is shown with the hourly allowable SO<sub>2</sub> emission limitation, compliance with the annual limitation shall be ensured (the annual allowable limitation was developed by multiplying the hourly allowable limitation by 8760, and then dividing by 2000).

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 03-9399]

### 2.g Emission Limitations: 11.51 lbs CO/hr, 50.40 ton CO/yr

Applicable Compliance Method: The permittee may determine compliance with the hourly allowable CO emission limitation by multiplying the appropriate emission factor from AP-42, Table 3.2-1 (revised 7/00) by the maximum hourly heat input rate (mmBtu/hr).

If required, compliance with the hourly allowable OC limitation shall be determined in accordance with Methods 1 through 4 and 10 of 40 CFR, Part 60, Appendix A.

Provided compliance is shown with the hourly allowable CO emission limitation, compliance with the annual limitation shall be ensured (the annual allowable limitation was developed by multiplying the hourly allowable limitation by 8760, and then dividing by 2000).

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 03-9399]

Facility Name: **ANR Pipeline Company**  
Facility ID: **03-20-01-0169**  
Emissions Unit: **Compressor Engine, 2,250 hp, ENG 1110 (P001)**

**VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Cooper-Bessemer engine, Model GMVH10C, 2250 hp, 2-stroke lean burn (2SLB) reciprocating internal combustion engine (RICE) (Engine 1110)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 2,000 hp, ENG 1101 (P002)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1101)	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.1.2.a).
	40 CFR, Part 63, Subpart ZZZZ	See A.1.2.b.

##### 2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.b This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **V. Testing Requirements**

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

- 1.a Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

- 1.b Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1101)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 2,000 hp, ENG 1102 (P003)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1102)	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.1.2.a).
	40 CFR, Part 63, Subpart ZZZZ	See A.1.2.b.

##### 2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.b This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **V. Testing Requirements**

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

- 1.a Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

- 1.b Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1102)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 2,000 hp, ENG 1103 (P004)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1103)	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.1.2.a).
	40 CFR, Part 63, Subpart ZZZZ	See A.1.2.b.

##### 2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.b This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **V. Testing Requirements**

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

- 1.a Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

- 1.b Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1103)	none	none

**2. Additional Terms and Conditions**

**None**

**II. Operational Restrictions**

**None**

**III. Monitoring and/or Record Keeping Requirements**

**None**

**IV. Reporting Requirements**

**None**

**V. Testing Requirements**

**None**

**VI. Miscellaneous Requirements**

**None**

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 2,000 hp, ENG 1104 (P005)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1104)	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.1.2.a).
	40 CFR, Part 63, Subpart ZZZZ	See A.1.2.b.

##### 2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.b This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **V. Testing Requirements**

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

- 1.a Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

- 1.b Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1104)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 2,000 hp, ENG 1105 (P006)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1105)	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.1.2.a).
	40 CFR, Part 63, Subpart ZZZZ	See A.1.2.b.

##### 2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.b This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **V. Testing Requirements**

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

- 1.a Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

- 1.b Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1105)	none	none

**2. Additional Terms and Conditions**

**None**

**II. Operational Restrictions**

**None**

**III. Monitoring and/or Record Keeping Requirements**

**None**

**IV. Reporting Requirements**

**None**

**V. Testing Requirements**

**None**

**VI. Miscellaneous Requirements**

**None**

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 2,000 hp, ENG 1106 (P007)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1106)	OAC rule 3745-17-07(A)	Visible particulate emissions PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.1.2.a).
	40 CFR, Part 63, Subpart ZZZZ	See A.1.2.b.

##### 2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.b This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **V. Testing Requirements**

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

- 1.a Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

- 1.b Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVS, 2,000 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1106)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 5,940 hp, ENG 1107 (P008)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVR, 5,940 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1107)	OAC rule 3745-14-12(B)	11.5 grams (g) nitrogen oxides (NOx)/horsepower (hp) -hour (hr) (See A.I.2.a.)
	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.I.2.b).
	40 CFR, Part 63, Subpart ZZZZ	See A.I.2.c.

##### 2. Additional Terms and Conditions

- 2.a The compliance plan approved by the Director of Ohio EPA on November 7, 2006 is the basis for the projected NOx emission rate in g/hp-hr established in this permit.
- 2.b Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.c This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. Pursuant to OAC rule 3745-14-12(C)(1) and (C)(2), the permittee shall comply with the following requirements:

### III. Monitoring and/or Record Keeping Requirements (continued)

#### 1.a Monitoring Requirements:

- i. Complete an initial performance test consistent with the requirements of 40 CFR, Part 60, Appendix A, following installation of emission controls required to achieve the emission rate limit specified in paragraph (B)(2) of this rule.
- ii. Perform periodic monitoring sufficient to yield reliable data from the relevant time period that is representative of a source's compliance with the emission rate limit specified in paragraph (B)(2) of this rule. Such periodic monitoring may include either:
  - (a) Performance tests consistent with the requirements of 40 CFR, Part 60, Appendix A, or portable monitors using ASTM D6522-00;
  - (b) A parametric monitoring program that specifies operating parameters, and their ranges, that will provide reasonable assurance that each engine's emissions are consistent with the requirements of paragraph (B)(2) of this rule;
  - (c) A predictive emissions measurement system that relies on automated data collection from instruments; or
  - (d) A continuous emission monitoring system that complies with 40 CFR, Part 60 or 75.

#### 1.b Record Keeping Requirements:

- i. Maintain all records necessary to demonstrate compliance with the requirements of this rule for a period of two calendar years at the plant at which the subject engine is located. The records shall be made available to the director and administrator upon request.
- ii. For each engine subject to the requirements of this rule, the owner or operator shall maintain records of:
  - (a) Identification and location of each engine subject to the requirements of this rule;
  - (b) Calendar date of record;
  - (c) The number of hours the unit is operated during each control period compared to the projected operating hours;
  - (d) Type and quantity of fuel used; and
  - (e) The results of all compliance tests.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-14-12]

2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

### IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

2. Pursuant to OAC rule 3745-14-12(C)(3), the permittee shall submit results of all compliance tests to the Director (when applicable).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-14-12]

## V. Testing Requirements

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

1.a Emission Limitation: 11.5 g NO<sub>x</sub>/hp-hr

Applicable Compliance Method: Compliance with the allowable NO<sub>x</sub> emission limitation above shall be based on the results of the emission testing required in accordance with OAC rule 3745-14-12(C)(1)(a).

The permittee shall also demonstrate compliance based on the monitoring and record keeping requirements established in Section A.III of this permit and OAC rule 3745-14-12(C).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-14-12]

1.b Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

1.c Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

## VI. Miscellaneous Requirements

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVR, 5,940 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1107)	none	none

**2. Additional Terms and Conditions**

**None**

**II. Operational Restrictions**

**None**

**III. Monitoring and/or Record Keeping Requirements**

**None**

**IV. Reporting Requirements**

**None**

**V. Testing Requirements**

**None**

**VI. Miscellaneous Requirements**

**None**

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 5,940 hp, ENG 1108 (P009)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Natural Gas Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVR, 5,940 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1108)	OAC rule 3745-14-12(B)	11.5 grams (g) nitrogen oxides (NOx)/horsepower (hp) -hour (hr) (See A.I.2.a.)
	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.I.2.b).
	40 CFR, Part 63, Subpart ZZZZ	See A.I.2.c.

##### 2. Additional Terms and Conditions

- 2.a The compliance plan approved by the Director of Ohio EPA on November 7, 2006 is the basis for the projected NOx emission rate in g/hp-hr established in this permit.
- 2.b Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.c This emissions unit is an existing spark ignition, 4SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

##### III. Monitoring and/or Record Keeping Requirements

1. Pursuant to OAC rule 3745-14-12(C)(1) and (C)(2), the permittee shall comply with the following requirements:

### III. Monitoring and/or Record Keeping Requirements (continued)

#### 1.a Monitoring Requirements:

- i. Complete an initial performance test consistent with the requirements of 40 CFR, Part 60, Appendix A, following installation of emission controls required to achieve the emission rate limit specified in paragraph (B)(2) of this rule.
- ii. Perform periodic monitoring sufficient to yield reliable data from the relevant time period that is representative of a source's compliance with the emission rate limit specified in paragraph (B)(2) of this rule. Such periodic monitoring may include either:
  - (a) Performance tests consistent with the requirements of 40 CFR, Part 60, Appendix A, or portable monitors using ASTM D6522-00;
  - (b) A parametric monitoring program that specifies operating parameters, and their ranges, that will provide reasonable assurance that each engine's emissions are consistent with the requirements of paragraph (B)(2) of this rule;
  - (c) A predictive emissions measurement system that relies on automated data collection from instruments; or
  - (d) A continuous emission monitoring system that complies with 40 CFR, Part 60 or 75.

#### 1.b Record Keeping Requirements:

- i. Maintain all records necessary to demonstrate compliance with the requirements of this rule for a period of two calendar years at the plant at which the subject engine is located. The records shall be made available to the director and administrator upon request.
- ii. For each engine subject to the requirements of this rule, the owner or operator shall maintain records of:
  - (a) Identification and location of each engine subject to the requirements of this rule;
  - (b) Calendar date of record;
  - (c) The number of hours the unit is operated during each control period compared to the projected operating hours;
  - (d) Type and quantity of fuel used; and
  - (e) The results of all compliance tests.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-14-12]

2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

### IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

2. Pursuant to OAC rule 3745-14-12(C)(3), the permittee shall submit results of all compliance tests to the Director (when applicable).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-14-12]

## V. Testing Requirements

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

1.a Emission Limitation: 11.5 g NO<sub>x</sub>/hp-hr

Applicable Compliance Method: Compliance with the allowable NO<sub>x</sub> emission limitation above shall be based on the results of the emission testing required in accordance with OAC rule 3745-14-12(C)(1)(a).

The permittee shall also demonstrate compliance based on the monitoring and record keeping requirements established in Section A.III of this permit and OAC rule 3745-14-12(C).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-14-12]

1.b Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

1.c Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the PE limitation above based on the emission factor, from AP-42, Table 3.2-2 (revised 7/00), of 7.71E-05 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

## VI. Miscellaneous Requirements

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Ingersoll-Rand engine, Model KVR, 5,940 hp, 4-stroke lean burn (4SLB), reciprocating internal combustion engine (RICE) (Engine 1108)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** Compressor Engine, 10,833 hp, ENG 1109 (P010)

**Activity Description:** Natural Gas Compression Using Internal Combustion Engine for Natural Gas Transport via Pipeline

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Cooper-Bessemer engine, Model 16Z-330, 10,833 hp, 2-stroke lean burn (2SLB), reciprocating internal combustion engine (RICE) (Engine 1109)	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
	OAC rule 3745-18-06(G)	None (see A.1.2.a).
	40 CFR, Part 63, Subpart ZZZZ	See A.1.2.b.

##### 2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-18-06(A), this emissions unit is exempt from the requirements of OAC rule 3745-18-06(G) since natural gas is the only fuel burned in this emissions unit.
- 2.b This emissions unit is an existing spark ignition, 2SLB stationary RICE. Therefore, pursuant to 40 CFR, Part 63.6590(b)(3), the unit does not have to meet the requirements of 40 CFR Part 63, Subpart ZZZZ, and 40 CFR Part 63, Subpart A, including the initial notification requirements specified in 40 CFR 63.6645(d).

##### II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.  
 [Authority for term: OAC rule 3745-77-07(A)(1) and PTI 03-9399]

##### III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.  
 [Authority for term: OAC rule 3745-77-07(C)(1)]

#### **IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

#### **V. Testing Requirements**

1. Compliance with the emission limitations in Section A.I. of these terms and conditions shall be determined in accordance with the following methods:

- 1.a Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: The permittee shall demonstrate compliance with the visible emissions limitations in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(1)]

- 1.b Emission Limitations: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine compliance with the limitation above based on an emission factor from AP-42, Table 3.2-1 (revised 7/00) of 0.0384 lb PE (filterable)/mmBtu of actual heat input.

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

[Authority for term: OAC rule 3745-77-07(C)(1) and OAC rule 3745-17-03(B)(10)]

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Cooper-Bessemer engine, Model 16Z-330, 10,833 hp, 2-stroke lean burn (2SLB), reciprocating internal combustion engine (RICE) (Engine 1109)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

\*\*\*\*\*

**THIS IS THE LAST PAGE OF THE PERMIT**

\*\*\*\*\*