



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

11/06/03

CERTIFIED MAIL

**RE: Proposed Title V Minor Permit Modification Chapter
3745-77 permit**

03-26-00-0079

Sauder Woodworking Cogeneration Facility

Attn: Genevieve Damico AR-18J
United States Environmental Protection Agency
Region V
77 West Jackson Blvd.
Chicago, IL 60604-3590

Dear Ms. Damico:

The proposed issuance of the Title V permit for Sauder Woodworking Cogeneration Facility, has been created in Ohio EPA's State Air Resources System (STARS) on 10/24/01, for review by USEPA. This proposed action is identified in STARS as  3-Title V Proposed Permit T+C covering the facility specific terms and conditions, and  Title V Proposed Permit covering the general terms and conditions. This proposed permit will be processed for issuance as a final action after forty-five (45) days from USEPA's electronic notification of this proposed action. Please contact me at (614) 644-3631 before the end of the forty-five (45) day review period if you wish to object to the proposed permit.

Very truly yours,

Michael W. Ahern, Supervisor
Field Operations and Permit Section
Division of Air Pollution Control

cc: Northwest District Office
File, DAPC PMU



State of Ohio Environmental Protection Agency

PROPOSED TITLE V MINOR PERMIT MODIFICATION

Original Effective Date: 10/24/01	Expiration Date: 10/24/06	Modification Effective Date: to be entered upon final issuance
-----------------------------------	---------------------------	---

This document constitutes issuance of a Title V permit for Facility ID: 03-26-00-0079 to:
The duration of this permit will be five years.
 Sauder Woodworking Cogeneration Facility
 502 Middle St.
 Archbold, OH 43502

Emissions Unit ID (Company ID)/Emissions Unit Activity Description

B008 (57 MM Btu/hr Boiler #1) Boiler that burns primarily wood waste with natural gas serving for backup (typically natural gas only used for start-up).	B009 (57 MM Btu/hr Boiler #2) Boiler that burns primarily wood waste with natural gas serving for backup (typically natural gas only used for start-up).
---	---

You will be contacted approximately eighteen (18) months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency listed below. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-08(E) and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the current Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

Northwest District Office
 347 North Dunbridge Road
 Bowling Green, OH 43402
 (419) 352-8461

OHIO ENVIRONMENTAL PROTECTION AGENCY

Christopher Jones
 Director

PART I - GENERAL TERMS AND CONDITIONS

A. *State and Federally Enforceable Section*

1. **Monitoring and Related Record Keeping and Reporting Requirements**

a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, i.e., in Section A.III of Part III of this Title V permit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:

- i. The date, place (as defined in the permit), and time of sampling or measurements.
- ii. The date(s) analyses were performed.
- iii. The company or entity that performed the analyses.
- iv. The analytical techniques or methods used.
- v. The results of such analyses.
- vi. The operating conditions existing at the time of sampling or measurement.

(Authority for term: OAC rule 3745-77-07(A)(3)(b)(i))

b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

(Authority for term: OAC rule 3745-77-07(A)(3)(b)(ii))

c. The permittee shall submit required reports in the following manner:

- i. **All reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations caused by malfunctions shall be submitted in the following manner:**

Any malfunction, as defined in OAC rule 3745-15-06(B)(1), shall be promptly reported to the Ohio EPA in accordance with OAC rule 3745-15-06. In addition, to fulfill the OAC rule 3745-77-07(A)(3)(c) deviation reporting requirements for malfunctions, written reports that identify each malfunction that occurred during each calendar quarter (including each malfunction reported only verbally in accordance with OAC rule 3745-15-06) shall be submitted by January 31, April 30, July 31, and October 31 of each year in accordance with General Term and Condition A.1.c.ii below; and each report shall cover the previous calendar quarter.

In accordance with OAC rule 3745-15-06, a malfunction constitutes a violation of an emission limitation (or control requirement) and, therefore, is a deviation of the federally enforceable permit requirements. Even though verbal notifications and written reports are required for malfunctions pursuant to OAC rule 3745-15-06, the written reports required pursuant to this term must be submitted quarterly to satisfy the prompt reporting provision of OAC rule 3745-77-07(A)(3)(c).

In identifying each deviation caused by a malfunction, the permittee shall specify the emission limitation(s) (or control requirement(s)) for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. For a specific malfunction, if this information has been provided in a written report that was submitted in accordance with OAC rule 3745-15-06, the permittee may simply reference that written report to identify the deviation. Nevertheless, all malfunctions, including

those reported only verbally in accordance with OAC rule 3745-15-06, must be reported in writing on a quarterly basis.

Any scheduled maintenance, as referenced in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described above for malfunctions.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

- ii. **Except as may otherwise be provided in the terms and conditions for a specific emissions unit, i.e., in Section A.IV of Part III of this Title V permit or, in some cases, in Part II of this Title V permit, all reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations of the emission limitations, operational restrictions, and control device operating parameter limitations shall be submitted in the following manner:**

Written reports of (a) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. Except as provided below, the written reports shall be submitted by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

In identifying each deviation, the permittee shall specify the emission limitation(s), operational restriction(s), and/or control device operating parameter limitation(s) for which the deviation occurred, describe each deviation, and provide the estimated magnitude and duration of each deviation.

These written reports shall satisfy the requirements (in part) of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations. OAC rule 3745-77-07(A)(3)(c) is not fully satisfied until the permittee addresses all other deviations of the federally enforceable requirements specified in the permit.

If an emissions unit has a deviation reporting requirement for a specific emission limitation, operational restriction, or control device operating parameter limitation that is not on a quarterly basis (e.g., within 30 days following the end of the calendar month, or within 30 or 45 days after the exceedance occurs), that deviation reporting requirement overrides the reporting requirements specified in this General Term and Condition for that specific emission limitation, operational restriction, or control device parameter limitation. Following the provisions of that non-quarterly deviation reporting requirement will also satisfy the requirements (in part) of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations, and additional quarterly deviation reports for that specific emission limitation, operational restriction, or control device parameter limitation are not required pursuant to this General Term and Condition.

See B.6 below if no deviations occurred during the quarter.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

- iii. **All reporting required in accordance with the OAC rule 3745-77-07(A)(3)(c) for other deviations of the federally enforceable permit requirements which are not**

reported in accordance with General Term and Condition A.1.c.ii above shall be submitted in the following manner:

Written reports that identify all other deviations of the federally enforceable requirements contained in this permit, including the monitoring, record keeping, and reporting requirements, which are not reported in accordance with General Term and Condition A.1.c.ii above shall be submitted to the appropriate Ohio EPA District Office or local air agency by January 31 and July 31 of each year; and each report shall cover the previous six calendar months.

In identifying each deviation, the permittee shall specify the federally enforceable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation.

These semi-annual written reports shall satisfy the reporting requirements of OAC rule 3745-77-07(A)(3)(c) for any deviations from the federally enforceable requirements contained in this permit that are not reported in accordance with General Term and Condition A.1.c.ii above.

If no such deviations occurred during a six-month period, the permittee shall submit a semi-annual report which states that no such deviations occurred during that period.
(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i) and (ii))

- iv. Each written report shall be signed by a responsible official certifying that, "based on information and belief formed after reasonable inquiry, the statements and information in the report (including any written malfunction reports required by OAC rule 3745-15-06 that are referenced in the deviation reports) are true, accurate, and complete."
(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iv))
- v. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
(Authority for term: OAC rule 3745-77-07(A)(3)(c))

2. Scheduled Maintenance

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. Except as provided in OAC rule 3745-15-06(A)(3), any scheduled maintenance necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s). Any scheduled maintenance, as defined in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described for malfunctions in General Term and Condition A.1.c.i above.
(Authority for term: OAC rule 3745-77-07(A)(3)(c))

3. Risk Management Plans

If applicable, the permittee shall develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. § 7401 et seq. ("Act"); and, pursuant to 40 C.F.R. 68.215(a), the permittee shall submit either of the following:

- a. a compliance plan for meeting the requirements of 40 C.F.R. Part 68 by the date specified in 40 C.F.R. 68.10(a) and OAC 3745-104-05(A); or

- b. as part of the compliance certification submitted under 40 C.F.R. 70.6(c)(5), a certification statement that the source is in compliance with all requirements of 40 C.F.R. Part 68 and OAC Chapter 3745-104, including the registration and submission of the risk management plan.

(Authority for term: OAC rule 3745-77-07(A)(4))

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

(Authority for term: OAC rule 3745-77-07(A)(5))

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

(Authority for term: OAC rule 3745-77-07(A)(6))

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause, in accordance with A.10 below. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

(Authority for term: OAC rule 3745-77-07(A)(7))

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

(Authority for term: OAC rule 3745-77-07(A)(8))

8. Marketable Permit Programs

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.
(Authority for term: OAC rule 3745-77-07(A)(9))

9. Reasonably Anticipated Operating Scenarios

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these general terms and conditions shall apply to all operating scenarios authorized in this permit.

(Authority for term: OAC rule 3745-77-07(A)(10))

10. Reopening for Cause

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a. Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.
- b. This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c. The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.
- d. The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

(Authority for term: OAC rules 3745-77-07(A)(12) and 3745-77-08(D))

11. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

(Authority for term: OAC rule 3745-77-07(B))

12. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:

- i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
- i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.
- d. Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) and the Administrator of the U.S. EPA in the following manner and with the following content:
- i. Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted on or before April 30th of each year during the permit term.
 - ii. Compliance certifications shall include the following:
 - (a) An identification of each term or condition of this permit that is the basis of the certification.
 - (b) The permittee's current compliance status.
 - (c) Whether compliance was continuous or intermittent.
 - (d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.
 - (e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.
 - iii. Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

(Authority for term: OAC rules 3745-77-07(C)(1),(2),(4) and (5) and ORC section 3704.03(L))

13. Permit Shield

- a. Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.

- b. This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.

(Authority for term: OAC rule 3745-77-07(F))

14. Operational Flexibility

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

(Authority for term: OAC rules 3745-77-07(H)(1) and (2))

15. Emergencies

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

(Authority for term: OAC rule 3745-77-07(G))

16. Off-Permit Changes

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a. The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition.
- b. The permittee provides contemporaneous written notice of the change to the Director and the Administrator of the U.S. EPA. Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change.
- c. The change shall not qualify for the permit shield under OAC rule 3745-77-07(F).
- d. The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.
- e. The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit to install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in

paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.
(Authority for term: OAC rule 3745-77-07(I))

17. Compliance Method Requirements

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.

(This term is provided for informational purposes only.)

18. Insignificant Activities

Each insignificant activity that has one or more applicable requirements shall comply with those applicable requirements.

(Authority for term: OAC rule 3745-77-07(A)(1))

19. Permit to Install Requirement

Prior to the “installation” or “modification” of any “air contaminant source,” as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

(Authority for term: OAC rule 3745-77-07(A)(1))

20. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

(Authority for term: OAC rule 3745-77-07(A)(1))

21. Permanent Shutdown of an Emissions Unit

The permittee may notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification by the responsible official of the date on which the emissions unit was permanently shut down. Authorization to operate the affected part or activity of the stationary source shall cease upon the date certified by the responsible official that the emissions unit was permanently shut down.

If an emissions unit is permanently shut down (i.e., that has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent “modification” or “installation” as defined in OAC Chapter 3745-31 and therefore ceases to meet the definition of an “emissions unit” as defined in OAC rule 3745-77-01(O)), rendering existing permit terms and conditions irrelevant, the permittee shall not be required, after the date of the certification and submission to Ohio EPA, to meet any monitoring, record keeping, reporting, or testing requirements, applicable to that emissions unit, except for any residual requirements, such as the quarterly deviation reports, semi-annual deviation reports and annual compliance certification covering the period during which the emissions unit last operated. All records relating to the shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law.

No emissions unit certified by the responsible official as being permanently shut down may resume operation without first applying for and obtaining a permit to install pursuant to OAC Chapter 3745-31.

B. State Only Enforceable Section

1. Reporting Requirements Related to Monitoring and Record Keeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (i) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

2. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

3. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

4. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

5. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

6. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no emission limitation (or control requirement), operational restriction and/or control device parameter limitation deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

The permittee is not required to submit a quarterly report which states that no deviations occurred during that quarter for the following situations:

- a. where an emissions unit has deviation reporting requirements for a specific emission limitation, operational restriction, or control device parameter limitation that override the deviation reporting requirements specified in General Term and Condition A.1.c.ii;
- b. where an uncontrolled emissions unit has no monitoring, record keeping, or reporting requirements and the emissions unit's applicable emission limitations are established at the potentials to emit; and
- c. where the company's responsible official has certified that an emissions unit has been permanently shut down.

Part II - Specific Facility Terms and Conditions

A. State and Federally Enforceable Section

None

B. State Only Enforceable Section

1. The following insignificant emissions unit is located at this facility:

P002 - wood waste handling system

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emission limitations and/or control requirements contained within a Permit to Install for the emissions unit.

57 MM Btu/hr Boiler #1 (B008)

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

Emissions Unit ID: 57 MM Btu/hr Boiler #1 (B008)

Activity Description: Boiler that burns primarily wood waste with natural gas serving for backup (typically natural gas only used for start-up).

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
57.0 mm Btu/hr, wood/natural gas (NG)-fired boiler, with cyclone, selective catalytic reduction (SCR), and electrostatic precipitator (ESP)	OAC Rule 3745-31-05 (PTI # 03-5740)	0.20 lb nitrogen oxides (NO _x)/mmBtu of actual heat input 0.45 lb carbon monoxide (CO)/mmBtu of actual heat input 0.01 lb sulfur dioxide (SO ₂)/mmBtu of actual heat input 0.15 lb volatile organic compounds (VOC)/mmBtu of actual heat input See A.II.1 & 2.
	40 CFR, Part 60, Subpart Dc	The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-10(B) and 40 CFR, Part 60, Subpart Dc. when burning wood, 0.10 lb particulate emissions(PE)/mmBtu of actual heat input Visible emissions shall not exceed 20% opacity, as a six-minute average.

57 MM Btu/hr Boiler #1 (B008)

OAC rule 3745-17-07(A)	See A.I.2.b.
OAC rule 3745-17-10(B)	when burning only natural gas, 0.020 lb PE/mmBtu of actual heat input when burning wood, see A.I.2.c.
OAC rule 3745-18-06(D)	See A.I.2.a.

2. Additional Terms and Conditions

- a. The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).
- b. The visible emissions limitation specified by this rule is less stringent than the visible emissions limitation established pursuant to 40 CFR, Part 60, Subpart Dc.
- c. The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to 40 CFR, Part 60, Subpart Dc.

II Operational Restrictions

- 1. The permittee shall operate the cyclone and the SCR systems during any operation of this emissions unit.
- 2. The permittee shall operate the ESP during any operation of this emissions unit, except during periods of startup and shutdown that are exempted pursuant to OAC 3745-17-07(A)(3)(a)(i) and 3745-17-07(A)(3)(b)(i), or during malfunctions that are exempted pursuant to OAC 3745-17-07(A)(3)(c).

III Monitoring and/or Recordkeeping

- 1. For the opacity monitor:
 - a. The permittee shall operate and maintain existing equipment to continuously monitor and record the opacity of the particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.
 - b. The permittee shall maintain records of all data obtained by the continuous opacity monitoring system including, but not limited to, percent opacity on an instantaneous

57 MM Btu/hr Boiler #1 (B008)

(one- minute) and 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

- c. A statement of certification of the existing continuous opacity monitoring system shall be maintained on site and shall consist of a letter from the Ohio EPA detailing the results of an Agency review of the certification tests and a statement by the Agency that the system is considered certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. Proof of certification shall be made available to the Director (the appropriate Ohio EPA District Office or local air agency) upon request.
2. For the NO_x monitor:
 - a. The permittee shall operate and maintain equipment to continuously monitor and record the NO_x emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.
 - b. The permittee shall maintain records of all data obtained by the continuous NO_x monitoring system including, but not limited to parts per million NO_x on an instantaneous (one-minute) basis, lbs NO_x per million Btu averaged over a 24-hour period, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.
 - c. A statement of certification of the continuous NO_x monitoring system shall be maintained on site and shall consist of a letter from the Ohio EPA detailing the results of an Agency review of the certification tests and a statement by the Agency that the system is considered certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. Proof of certification shall be made available to the Director (the appropriate Ohio EPA District Office or local air agency) upon request.

IV Reporting Requirements

1. For the opacity monitor:
 - a. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting all instances of opacity values in excess of the limitations specified in 40 CFR, Part 60, Subpart Dc, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective actions taken (if any) of each 6-minute block average above the applicable opacity limitation(s). This report shall also include the summary report described in Figure 1 of 40 CFR, Part 60.7.
 - b. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous opacity monitoring system downtime while the emissions unit was on line

57 MM Btu/hr Boiler #1 (B008)

(date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

- c. If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report. These quarterly excess emissions reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.
- d. The permittee shall submit a summary of the excess emission report pursuant to 40 CFR Part 60.7. The summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

2. For the NO_x monitor:

- a. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any) of all instances of NO_x values in excess of any applicable limitation(s) specified in the terms and conditions of this permit. These reports shall also contain the total NO_x emissions for the calendar quarter (in tons).
- b. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous NO_x monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.
- c. If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total

57 MM Btu/hr Boiler #1 (B008)

operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

- d. The permittee shall submit a summary of the excess emission report pursuant to 40 CFR Part 60.7. The summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

V Testing Requirements

1. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
 - a. The emission testing shall be conducted ~~within 3 months after permit issuance~~ approximately 2.5 years after issuance of this permit and within 6 months prior to permit ~~renewal~~ expiration.
 - b. The emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for particulates, NO_x, CO, and VOC.
 - c. The following test methods shall be employed to demonstrate compliance with the allowable mass emission rates: for particulates, Methods 1 through 5 of 40 CFR, Part 60, Appendix A; for NO_x, Methods 1 through 4 and 7 of 40 CFR, Part 60, Appendix A; for VOC, Methods 18, 25, or 25A, as appropriate, of 40 CFR, Part 60, Appendix A; and for CO, Methods 1 through 4 and 10 of 40 CFR, Part 60, Appendix A. Alternative U.S. EPA-approved test methods may be used with prior approval from the Ohio EPA.
 - d. The tests shall be conducted while the emissions unit is operating at or near its maximum capacity while burning wood, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency.
2. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA District Office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the tests may result in the Ohio EPA District Office's or local air agency's refusal to accept the results of the emissions test(s).

Personnel from the appropriate Ohio EPA District Office or local air agency shall be permitted to witness the tests, examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid

57 MM Btu/hr Boiler #1 (B008)

characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA District Office or local air agency.

3. Compliance with the emission limitations of this permit shall be determined in accordance with the following methods:

- a. Emission Limitations:
0.10 lb PE/mmBtu of actual heat input, when burning wood
0.20 lb NO_x/mmBtu of actual heat input
0.45 lb CO/mmBtu of actual heat input
0.15 lb VOC/mmBtu of actual heat input

Applicable Compliance Method: Compliance with the lb/mmBtu emission limitations above shall be based upon the results of emission testing conducted in accordance with the methods outlined in Section A.V.1 of this permit.

- b. Emission Limitation -
Visible emissions shall not exceed 20% opacity, as a six-minute average

Applicable Compliance Method:
If required, compliance with the visible emissions limitation above shall be determined in accordance with OAC rule 3745-17-03(B)(1).

- c. Emission Limitation -
0.020 lb PE/mmBtu of actual heat input, when burning only natural gas

Applicable Compliance Method:
Compliance with the 0.020 lb PE/mmBtu limitation may be demonstrated by multiplying the emission factor from AP-42, Table 1.4-2 (revised 7/98) of 1.9 lbs PE (filterable)/mm cu. ft by $[1/(\text{the heat content of natural gas (mmBtu/mm cu. ft)})]$.

If required, the permittee shall demonstrate compliance with the lb PE/mmBtu limitation above pursuant to OAC rule 3745-17-03(B)(9).

- d. Emission Limitation -
0.01 lb SO₂/mmBtu of actual heat input

Applicable Compliance Method:

Compliance with the 0.01 lb SO₂/mmBtu emission limitation may be demonstrated by multiplying the emission factor from AP-42, Table 1.6-2 (revised 2/99) of 0.075 lb SO₂/ton of wood burned by [1/(the heat content of wood (mmBtu/ton))].

If required, the permittee shall demonstrate compliance with the lb SO₂/mmBtu emission limitation above in accordance with Method 6 of 40 CFR, Part 60, Appendix A.

VI Miscellaneous Requirements

1. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous opacity monitoring system designed to ensure continuous valid and representative readings of opacity. The plan shall include, as a minimum, conducting and recording daily automatic zero/span checks, provisions for conducting a quarterly audit of the continuous opacity monitoring system, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring that the requirements of Performance Specification 1* are maintained on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.

* Performance Specification 1 as it was written when PTI #03 -5740 was issued (August 1992).

2. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous NO_x monitoring system designed to ensure continuous valid and representative readings of NO_x emissions. The plan shall follow the requirements of 40 CFR Part 60, Appendix F*. The quality assurance/quality control plan and a logbook dedicated to the continuous NO_x monitoring system must be kept on site and available for inspection during regular office hours.

* Appendix F as it was written when PTI #03 -5740 was issued (August 1992).

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--------------------------------------	--

2. **Additional Terms and Conditions**

None

II Operational Restrictions

None

III Monitoring and/or Recordkeeping

None

IV Reporting Requirements

None

V Testing Requirements

None

VI Miscellaneous Requirements

None

57 MM Btu/hr Boiler #2 (B009)

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

Emissions Unit ID: 57 MM Btu/hr Boiler #2 (B009)

Activity Description: Boiler that burns primarily wood waste with natural gas serving for backup (typically natural gas only used for start-up).

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
57.0 mm Btu/hr, wood/natural gas (NG)-fired boiler, with cyclone, selective catalytic reduction (SCR), and electrostatic precipitator (ESP)	OAC Rule 3745-31-05 (PTI # 03-5740)	0.20 lb nitrogen oxides (NOx)/mmBtu of actual heat input
		0.45 lb carbon monoxide (CO)/mmBtu of actual heat input
		0.01 lb sulfur dioxide (SO2)/mmBtu of actual heat input
		0.15 lb volatile organic compounds (VOC)/mmBtu of actual heat input
		See A.II.1 & 2.
		The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-10(B) and 40 CFR, Part 60, Subpart Dc.
	40 CFR, Part 60, Subpart Dc	when burning wood, 0.10 lb particulate emissions(PE)/mmBtu of actual heat input
	OAC rule 3745-17-07(A)	Visible emissions shall not exceed 20% opacity, as a six-minute average.

OAC rule 3745-17-10(B)	See A.I.2.b. when burning only natural gas, 0.020 lb PE/mmBtu of actual heat input
OAC rule 3745-18-06(D)	when burning wood, see A.I.2.c. See A.I.2.a.

2. Additional Terms and Conditions

- a. The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).
- b. The visible emissions limitation specified by this rule is less stringent than the visible emissions limitation established pursuant to 40 CFR, Part 60, Subpart Dc.
- c. The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to 40 CFR, Part 60, Subpart Dc.

II Operational Restrictions

1. The permittee shall operate the cyclone and the SCR systems during any operation of this emissions unit.
2. The permittee shall operate the ESP during any operation of this emissions unit, except during periods of startup and shutdown that are exempted pursuant to OAC 3745-17-07(A)(3)(a)(i) and 3745-17-07(A)(3)(b)(i), or during malfunctions that are exempted pursuant to OAC 3745-17-07(A)(3)(c).

III Monitoring and/or Recordkeeping

1. For the opacity monitor:
 - a. The permittee shall operate and maintain existing equipment to continuously monitor and record the opacity of the particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.
 - b. The permittee shall maintain records of all data obtained by the continuous opacity monitoring system including, but not limited to, percent opacity on an instantaneous

57 MM Btu/hr Boiler #2 (B009)

(one- minute) and 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

- c. A statement of certification of the existing continuous opacity monitoring system shall be maintained on site and shall consist of a letter from the Ohio EPA detailing the results of an Agency review of the certification tests and a statement by the Agency that the system is considered certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. Proof of certification shall be made available to the Director (the appropriate Ohio EPA District Office or local air agency) upon request.
2. For the NO_x monitor:
 - a. The permittee shall operate and maintain equipment to continuously monitor and record the NO_x emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.
 - b. The permittee shall maintain records of all data obtained by the continuous NO_x monitoring system including, but not limited to parts per million NO_x on an instantaneous (one-minute) basis, lbs NO_x per million Btu averaged over a 24-hour period, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.
 - c. A statement of certification of the continuous NO_x monitoring system shall be maintained on site and shall consist of a letter from the Ohio EPA detailing the results of an Agency review of the certification tests and a statement by the Agency that the system is considered certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. Proof of certification shall be made available to the Director (the appropriate Ohio EPA District Office or local air agency) upon request.

IV Reporting Requirements

1. For the opacity monitor:
 - a. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting all instances of opacity values in excess of the limitations specified in 40 CFR, Part 60, Subpart Dc, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective actions taken (if any) of each 6-minute block average above the applicable opacity limitation(s). This report shall also include the summary report described in Figure 1 of 40 CFR, Part 60.7.
 - b. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous opacity monitoring system downtime while the emissions unit was on line

57 MM Btu/hr Boiler #2 (B009)

(date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

- c. If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report. These quarterly excess emissions reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.
- d. The permittee shall submit a summary of the excess emission report pursuant to 40 CFR Part 60.7. The summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

2. For the NO_x monitor:

- a. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any) of all instances of NO_x values in excess of any applicable limitation(s) specified in the terms and conditions of this permit. These reports shall also contain the total NO_x emissions for the calendar quarter (in tons).
- b. The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous NO_x monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.
- c. If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total

operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

- d. The permittee shall submit a summary of the excess emission report pursuant to 40 CFR Part 60.7. The summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

V Testing Requirements

1. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
 - a. The emission testing shall be conducted ~~within 3 months after permit issuance~~ approximately 2.5 years after issuance of this permit and within 6 months prior to permit ~~renewal~~ expiration.
 - b. The emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for particulates, NO_x, CO, and VOC.
 - c. The following test methods shall be employed to demonstrate compliance with the allowable mass emission rates: for particulates, Methods 1 through 5 of 40 CFR, Part 60, Appendix A; for NO_x, Methods 1 through 4 and 7 of 40 CFR, Part 60, Appendix A; for VOC, Methods 18, 25, or 25A, as appropriate, of 40 CFR, Part 60, Appendix A; and for CO, Methods 1 through 4 and 10 of 40 CFR, Part 60, Appendix A. Alternative U.S. EPA-approved test methods may be used with prior approval from the Ohio EPA.
 - d. The tests shall be conducted while the emissions unit is operating at or near its maximum capacity while burning wood, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency.
2. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA District Office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the tests may result in the Ohio EPA District Office's or local air agency's refusal to accept the results of the emissions test(s).

Personnel from the appropriate Ohio EPA District Office or local air agency shall be permitted to witness the tests, examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid

57 MM Btu/hr Boiler #2 (B009)

characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA District Office or local air agency.

3. Compliance with the emission limitations of this permit shall be determined in accordance with the following methods:

a. Emission Limitations:

- 0.10 lb PE/mmBtu of actual heat input, when burning wood
- 0.20 lb NO_x/mmBtu of actual heat input
- 0.45 lb CO/mmBtu of actual heat input
- 0.15 lb VOC/mmBtu of actual heat input

Applicable Compliance Method: Compliance with the lb/mmBtu emission limitations above shall be based upon the results of emission testing conducted in accordance with the methods outlined in Section A.V.1 of this permit.

b. Emission Limitation -

Visible emissions shall not exceed 20% opacity, as a six-minute average

Applicable Compliance Method:

If required, compliance with the visible emissions limitation above shall be determined in accordance with OAC rule 3745-17-03(B)(1).

c. Emission Limitation -

0.020 lb PE/mmBtu of actual heat input, when burning only natural gas

Applicable Compliance Method:

Compliance with the 0.020 lb PE/mmBtu limitation may be demonstrated by multiplying the emission factor from AP-42, Table 1.4-2 (revised 7/98) of 1.9 lbs PE (filterable)/mm cu. ft by $[1/(\text{the heat content of natural gas (mmBtu/mm cu. ft)})]$.

If required, the permittee shall demonstrate compliance with the lb PE/mmBtu limitation above pursuant to OAC rule 3745-17-03(B)(9).

d. Emission Limitation -

0.01 lb SO₂/mmBtu of actual heat input

Applicable Compliance Method:

57 MM Btu/hr Boiler #2 (B009)

Compliance with the 0.01 lb SO₂/mmBtu emission limitation may be demonstrated by multiplying the emission factor from AP-42, Table 1.6-2 (revised 2/99) of 0.075 lb SO₂/ton of wood burned by [1/(the heat content of wood (mmBtu/ton))].

If required, the permittee shall demonstrate compliance with the lb SO₂/mmBtu emission limitation above in accordance with Method 6 of 40 CFR, Part 60, Appendix A.

VI Miscellaneous Requirements

1. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous opacity monitoring system designed to ensure continuous valid and representative readings of opacity. The plan shall include, as a minimum, conducting and recording daily automatic zero/span checks, provisions for conducting a quarterly audit of the continuous opacity monitoring system, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring that the requirements of Performance Specification 1* are maintained on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.

* Performance Specification 1 as it was written when PTI #03 -5740 was issued (August 1992).

2. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous NO_x monitoring system designed to ensure continuous valid and representative readings of NO_x emissions. The plan shall follow the requirements of 40 CFR Part 60, Appendix F*. The quality assurance/quality control plan and a logbook dedicated to the continuous NO_x monitoring system must be kept on site and available for inspection during regular office hours.

* Appendix F as it was written when PTI #03 -5740 was issued (August 1992).

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--------------------------------------	--

2. **Additional Terms and Conditions**

None

II Operational Restrictions

None

III Monitoring and/or Recordkeeping

None

IV Reporting Requirements

None

V Testing Requirements

None

VI Miscellaneous Requirements

None