



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
50 West Town Street, Suite 700
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

03/18/08

CERTIFIED MAIL

**RE: Draft Title V Chapter 3745-77
permit**

08-55-10-0041
Piqua Municipal Power System
Roger Wehrman
123 Bridge St.
Piqua, OH 45356-5001

Dear Roger Wehrman:

You are hereby notified that the Ohio Environmental Protection Agency has prepared the enclosed draft of the Title V permit for the facility referenced above. The purpose of this draft is to solicit public comments. A public notice concerning the draft will appear in the Ohio EPA Weekly Review and the major newspaper in the county where the facility is located. Comments and/or a request for a public hearing from the public and any affected parties will be accepted by RAPCA within 30 days of the date of publication in the newspaper. You will be notified in writing if a public hearing is scheduled. **In order to facilitate our review of all the comments or concerns you may have with the enclosed draft permit, please provide a hand marked-up copy of the draft permit showing the changes you think are necessary, along with any additional summary comments, by the end of the draft public comment period. The hard marked-up copy and any additional summary comments should be submitted to the Ohio EPA District Office or local air agency identified below and to the following address:**

**Andrew Hall
Permit Review/Development Section
Ohio EPA, Division of Air Pollution Control
122 South Front Street
Columbus, Ohio 43215**

A decision on processing the Title V permit will be made after consideration of written public comments and oral testimony (if a public hearing is conducted). After the comment period, you will be provided with a Preliminary Proposed Title V permit and an opportunity to comment prior to the Proposed Title V permit submittal to USEPA.

If you have any questions concerning this draft Title V permit, please contact RAPCA.

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section
Division of Air Pollution Control

cc: USEPA (electronically submitted)
File, DAPC PIER
RAPCA
Indiana



State of Ohio Environmental Protection Agency

DRAFT TITLE V PERMIT

Issue Date: 03/18/08	Effective Date: To be entered upon final issuance	Expiration Date: To be entered upon final issuance
----------------------	---	--

This document constitutes issuance of a Title V permit for Facility ID: 08-55-10-0041 to:
 Piqua Municipal Power System
 919 South Main St.
 Piqua, OH 45356-5001

Emissions Unit ID (Company ID)/Emissions Unit Activity Description

B007 (C.T. #8) #2 fuel oil fired combustion turbine used for peaking and emergencies.	B009 (Steam Generator) 600hp natural gas and #2 fuel oil fired steam generator for the steam and hot water distribution systems	distribution systems
B008 (Steam Generator) 300hp natural gas and #2 fuel oil fired steam generator for the steam and hot water distribution systems	B010 (Steam Generator) 600hp natural gas and #2 fuel oil fired steam generator for the steam and hot water	B011 (Steam Generator) 600hp natural gas and #2 fuel oil fired steam generator for the steam and hot water distribution systems

You will be contacted approximately eighteen (18) months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency listed below. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-08(E) and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the current Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
 117 South Main Street
 Dayton, OH 45422-1280
 (937) 225-4435

Ohio Environmental Protection Agency

Chris Korleski
 Director

PART I - GENERAL TERMS AND CONDITIONS

A. *State and Federally Enforceable Section*

1. **Monitoring and Related Record Keeping and Reporting Requirements**

a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, i.e., in Section A.III of Part III of this Title V permit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:

- i. The date, place (as defined in the permit), and time of sampling or measurements.
- ii. The date(s) analyses were performed.
- iii. The company or entity that performed the analyses.
- iv. The analytical techniques or methods used.
- v. The results of such analyses.
- vi. The operating conditions existing at the time of sampling or measurement.
(*Authority for term: OAC rule 3745-77-07(A)(3)(b)(i)*)

b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

(*Authority for term: OAC rule 3745-77-07(A)(3)(b)(ii)*)

c. The permittee shall submit required reports in the following manner:

- i. **All reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations caused by malfunctions shall be submitted in the following manner:**

Any malfunction, as defined in OAC rule 3745-15-06(B)(1), shall be promptly reported to the Ohio EPA in accordance with OAC rule 3745-15-06. In addition, to fulfill the OAC rule 3745-77-07(A)(3)(c) deviation reporting requirements for malfunctions, written reports that identify each malfunction that occurred during each calendar quarter (including each malfunction reported only verbally in accordance with OAC rule 3745-15-06) shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year in accordance with General Term and Condition A.1.c.ii below; and each report shall cover the previous calendar quarter. (An exceedance of the visible emission limitations specified in OAC rule 3745-17-07(A)(1) that is caused by a malfunction is not a violation and does not need to be reported as a deviation if the owner or operator of the affected air contaminant source or air pollution control equipment complies with the requirements of OAC rule 3745-17-07(A)(3)(c).)

In accordance with OAC rule 3745-15-06, a malfunction reportable under OAC rule 3745-15-06(B) constitutes a violation of an emission limitation (or control requirement) and, therefore, is a deviation of the federally enforceable permit requirements. Even though verbal notifications and written reports are required for malfunctions pursuant to OAC rule 3745-15-06, the written reports required pursuant to this term must be submitted quarterly to satisfy the prompt reporting provision of OAC rule 3745-77-07(A)(3)(c).

In identifying each deviation caused by a malfunction, the permittee shall specify the emission limitation(s) (or control requirement(s)) for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. For a specific malfunction, if this information has been provided

in a written report that was submitted in accordance with OAC rule 3745-15-06, the permittee may simply reference that written report to identify the deviation. Nevertheless, all malfunctions, including those reported only verbally in accordance with OAC rule 3745-15-06, must be reported in writing on a quarterly basis.

Any scheduled maintenance, as referenced in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described above for malfunctions.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

- ii. **Except as may otherwise be provided in the terms and conditions for a specific emissions unit, i.e., in Section A.IV of Part III of this Title V permit or, in some cases, in Part II of this Title V permit, all reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations of the emission limitations, operational restrictions, and control device operating parameter limitations shall be submitted in the following manner:**

Written reports of (a) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. Except as provided below, the written reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

In identifying each deviation, the permittee shall specify the emission limitation(s), operational restriction(s), and/or control device operating parameter limitation(s) for which the deviation occurred, describe each deviation, and provide the estimated magnitude and duration of each deviation.

These written deviation reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations. Full compliance with OAC rule 3745-77-07(A)(3)(c) requires reporting of all other deviations of the federally enforceable requirements specified in the permit as required by such rule.

If an emissions unit has a deviation reporting requirement for a specific emission limitation, operational restriction, or control device operating parameter limitation that is not on a quarterly basis (e.g., within 30 days following the end of the calendar month, or within 30 or 45 days after the exceedance occurs), that deviation reporting requirement satisfies the reporting requirements specified in this General Term and Condition for that specific emission limitation, operational restriction, or control device parameter limitation. Following the provisions of that non-quarterly deviation reporting requirement will also satisfy (for the deviations so reported) the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations, and additional quarterly deviation reports for that specific emission limitation, operational restriction, or control device parameter limitation are not required pursuant to this General Term and Condition.

See B.6 below if no deviations occurred during the quarter.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

- iii. **All reporting required in accordance with the OAC rule 3745-77-07(A)(3)(c) for other deviations of the federally enforceable permit requirements which are not reported in accordance with General Term and Condition A.1.c.ii above shall be submitted in the following manner:**

Unless otherwise specified by rule, written reports that identify deviations of the following federally enforceable requirements contained in this permit; General Terms and Conditions: A.2, A.3, A.4, A.6.e, A.7, A.12, A.14, A.18, A.19, A.20, and A.22 of Part I of this Title V permit, as well as any deviations from the requirements in Section A.V or A.VI of Part III of this Title V permit, and any monitoring, record keeping, and reporting requirements, which are not reported in accordance with General Term and Condition A.1.c.ii above shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office

or local air agency by January 31 and July 31 of each year; and each report shall cover the previous six calendar months. Unless otherwise specified by rule, all other deviations from federally enforceable requirements identified in this permit shall be submitted annually as part of the annual compliance certification, including deviations of federally enforceable requirements not specifically addressed by permit or rule for the insignificant activities or emissions levels (IEU) identified in Part II.A of this Title V permit. Annual reporting of deviations is deemed adequate to meet the deviation reporting requirements for IEUs unless otherwise specified by permit or rule.

In identifying each deviation, the permittee shall specify the federally enforceable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation.

These semi-annual and annual written reports shall satisfy the reporting requirements of OAC rule 3745-77-07(A)(3)(c) for any deviations from the federally enforceable requirements contained in this permit that are not reported in accordance with General Term and Condition A.1.c.ii above.

If no such deviations occurred during a six-month period, the permittee shall submit a semi-annual report which states that no such deviations occurred during that period.

(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i) and (ii) and OAC rule 3745-77-07(A)(13)(b))

- iv. Each written report shall be signed by a responsible official certifying that, "based on information and belief formed after reasonable inquiry, the statements and information in the report (including any written malfunction reports required by OAC rule 3745-15-06 that are referenced in the deviation reports) are true, accurate, and complete."

(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iv))

- v. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

2. **Scheduled Maintenance**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. Except as provided in OAC rule 3745-15-06(A)(3), any scheduled maintenance necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s). Any scheduled maintenance, as defined in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described for malfunctions in General Term and Condition A.1.c.i above.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

3. **Risk Management Plans**

If applicable, the permittee shall develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. § 7401 et seq. ("Act"); and, pursuant to 40 C.F.R. 68.215(a), the permittee shall submit either of the following:

- a. a compliance plan for meeting the requirements of 40 C.F.R. Part 68 by the date specified in 40 C.F.R. 68.10(a) and OAC 3745-104-05(A); or
- b. as part of the compliance certification submitted under 40 C.F.R. 70.6(c)(5), a certification statement that the source is in compliance with all requirements of 40 C.F.R. Part 68 and OAC Chapter 3745-104, including the registration and submission of the risk management plan.

(Authority for term: OAC rule 3745-77-07(A)(4))

4. **Title IV Provisions**

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

(Authority for term: OAC rule 3745-77-07(A)(5))

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

(Authority for term: OAC rule 3745-77-07(A)(6))

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause, in accordance with A.10 below. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.
- f. Except as otherwise indicated below, this Title V permit, or permit modification, is effective for five years from the original effective date specified in the permit. In the event that this facility becomes eligible for non-title V permits, this permit shall cease to be enforceable upon final issuance of all applicable OAC Chapter 3745-35 operating permits and/or registrations for all subject emissions units located at the facility and:
 - i. the permittee submits an approved facility-wide potential to emit analysis supporting a claim that the facility no longer meets the definition of a “major source” as defined in OAC rule 3745-77-01(W) based on the permanent shutdown and removal of one or more emissions units identified in this permit; or
 - ii. the permittee no longer meets the definition of a “major source” as defined in OAC rule 3745-77-01(W) based on obtaining restrictions on the facility-wide potential(s) to emit that are federally enforceable or legally and practically enforceable ; or
 - iii. a combination of i. and ii. above.

The permittee shall comply with any residual requirements, such as quarterly deviation reports, semi-annual deviation reports, and annual compliance certifications covering the period during which this Title V permit was enforceable. All records relating to this permit must be maintained in accordance with law.

(Authority for term: OAC rule 3745-77-01(W), OAC rule 3745-77-07(A)(3)(b)(ii), OAC rule 3745-77(A)(7))

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

(Authority for term: OAC rule 3745-77-07(A)(8))

8. Marketable Permit Programs

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.

(Authority for term: OAC rule 3745-77-07(A)(9))

9. Reasonably Anticipated Operating Scenarios

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these general terms and conditions shall apply to all operating scenarios authorized in this permit.

(Authority for term: OAC rule 3745-77-07(A)(10))

10. Reopening for Cause

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a. Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.
- b. This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c. The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.
- d. The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

(Authority for term: OAC rules 3745-77-07(A)(12) and 3745-77-08(D))

11. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

(Authority for term: OAC rule 3745-77-07(B))

12. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.

- iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
- i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.
- d. Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) and the Administrator of the U.S. EPA in the following manner and with the following content:
- i. Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted (i.e., postmarked) on or before April 30th of each year during the permit term.
 - ii. Compliance certifications shall include the following:
 - (a) An identification of each term or condition of this permit that is the basis of the certification.
 - (b) The permittee's current compliance status.
 - (c) Whether compliance was continuous or intermittent.
 - (d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.
 - (e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.
 - iii. Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

(Authority for term: OAC rules 3745-77-07(C)(1),(2),(4) and (5) and ORC section 3704.03(L))

13. Permit Shield

- a. Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.
 - b. This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.
- (Authority for term: OAC rule 3745-77-07(F))*

14. Operational Flexibility

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed

under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

(Authority for term: OAC rules 3745-77-07(H)(1) and (2))

15. Emergencies

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

(Authority for term: OAC rule 3745-77-07(G))

16. Off-Permit Changes

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a. The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition.
- b. The permittee provides contemporaneous written notice of the change to the Director and the Administrator of the U.S. EPA, except that no such notice shall be required for changes that qualify as insignificant emissions levels or activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change.
- c. The change shall not qualify for the permit shield under OAC rule 3745-77-07(F).
- d. The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.
- e. The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit to install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.

(Authority for term: OAC rule 3745-77-07(I))

17. Compliance Method Requirements

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.

(This term is provided for informational purposes only.)

18. Insignificant Activities or Emissions Levels

Each IEU that has one or more applicable requirements shall comply with those applicable requirements.

(Authority for term: OAC rule 3745-77-07(A)(1))

19. Permit to Install Requirement

Prior to the “installation” or “modification” of any “air contaminant source,” as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

(Authority for term: OAC rule 3745-77-07(A)(1))

20. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

(Authority for term: OAC rule 3745-77-07(A)(1))

21. Permanent Shutdown of an Emissions Unit

The permittee may notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification from the responsible official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the responsible official that the emissions unit was permanently shut down.

After the date on which an emissions unit is permanently shut down (i.e., that has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent “modification” or “installation” as defined in OAC Chapter 3745-31 and therefore ceases to meet the definition of an “emissions unit” as defined in OAC rule 3745-77-01(O)), rendering existing permit terms and conditions irrelevant, the permittee shall not be required, after the date of the certification and submission to Ohio EPA, to meet any Title V permit requirements applicable to that emissions unit, except for any residual requirements, such as the quarterly deviation reports, semi-annual deviation reports and annual compliance certification covering the period during which the emissions unit last operated. All records relating to the shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law.

No emissions unit certified by the responsible official as being permanently shut down may resume operation without first applying for and obtaining a permit to install pursuant to OAC Chapter 3745-31.

(Authority for term: OAC rule 3745-77-01)

22. Title VI Provisions

If applicable, the permittee shall comply with the standards for recycling and reducing emissions of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:

- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices specified in 40 CFR 82.156.
- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment specified in 40 CFR 82.158.
- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

(Authority for term: OAC rule 3745-77-01(H)(11))

B. State Only Enforceable Section

1. Reporting Requirements Related to Monitoring and Record Keeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (i) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

2. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

3. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

4. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

5. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

6. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no emission limitation (or control requirement), operational restriction and/or control device parameter limitation deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations

occurred during that quarter. The reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

The permittee is not required to submit a quarterly report which states that no deviations occurred during that quarter for the following situations:

- a. where an emissions unit has deviation reporting requirements for a specific emission limitation, operational restriction, or control device parameter limitation that override the deviation reporting requirements specified in General Term and Condition A.1.c.ii; or
- b. where an uncontrolled emissions unit has no monitoring, record keeping, or reporting requirements and the emissions unit's applicable emission limitations are established at the potentials to emit; or
- c. where the company's responsible official has certified that an emissions unit has been permanently shut down.

Part II - Specific Facility Terms and Conditions

A. State and Federally Enforceable Section

1. NOx emissions from emissions units B007, B008, B009, B010 and B011 shall not exceed 561.98 tons per rolling 12-month period.

[Authority for term: OAC rule 3745-31-05(C) and PTI 08-03566]

2. The permittee shall maintain monthly records of the following information for emissions units B007, B008, B009, B010 and B011:

- a. The monthly NOx emissions rate, in tons.
- b. The rolling, 12-month summation of the NOx emissions rate, in tons.

[Authority for term: OAC rule 3745-31-05(C) and PTI 08-03566]

3. The permittee shall submit quarterly deviation (excursion) reports that identify all exceedances of the rolling, 12-month NOx emissions limitation for emissions units B007, B008, B009, B010 and B011.

[Authority for term: OAC rule 3745-31-05(C) and PTI 08-03566]

The permittee shall submit quarterly deviation (excursion) reports in accordance with the General Terms and Conditions of this permit.

4. Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation -
NOx emissions from emissions units B007, B008, B009, B010 and B011 shall not exceed 561.98 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.3 and shall be determined by:

- i. for B008, B009, B010 and B011, multiplying the natural gas usage for the month by the emission factor 0.13 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
- ii. for B008, B009, B010 and B011, multiplying the No. 2 fuel oil usage for the month by the emission factor 0.14 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
- iii. for B007, multiplying the No. 2 fuel oil usage for the month by the emission factor 0.88 lb NOx/mmBtu (AP-42, Table 3.1-1, 4/00), by 140 mmBtu/1000 gal and dividing by 2000 lbs/ton.
- iv. the rolling, 12-month NOx rate shall be the sum of i through iii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-31-05(C) and PTI 08-03566]

B. State Only Enforceable Section

1. The following insignificant emissions units located at this facility are exempt from permit requirements because they are not subject to any applicable requirements (as defined in OAC rule 3745-77-01(H)) or because they meet the "de minimis" criteria established in OAC rule 3745-15-05:

F002 - Parking & Roadways
T002 - Fuel Oil Tank
T003 - Fuel Oil Tank
Z005 - Boiler Fuel Oil Tank

[Authority for term: OAC rule 3745-77-07(A)(13)]

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: C.T. #8 (B007)

Activity Description: #2 fuel oil fired combustion turbine used for peaking and emergencies.

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B007 - 293 mmBtu/hr, emergency, No. 2 fuel oil-fired, stationary combustion turbine; C.T. #8	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(4)	PE shall not exceed 0.040 lb/mmBtu actual heat input.
	OAC rule 3745-18-61(B)(2)	Sulfur dioxide emissions shall not exceed 0.5 lb/mmBtu actual heat input.

2. Additional Terms and Conditions

None

II. Operational Restrictions

- The quality of the oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation specified in section A.I above.

[Authority for term: OAC rule 3745-77-07(A)(1)]

- The permittee shall burn only No. 2 fuel oil in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

- a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F). A shipment may be comprised of multiple tank truck loads from the same supplier's batch, or may be represented by single or multiple pipeline deliveries from the same supplier's batch, and the quality of the oil for those loads or pipeline deliveries may be represented by a single batch analysis from the supplier.

- b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods, such as ASTM methods D240 Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter and D4294, Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry, or equivalent methods as approved by the director.

[Authority for term: OAC rules 3745-18-04(E)(3) and 3745-77-07(C)(1)]

2. On each day during which the permittee burns a fuel other than No. 2 fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1)]

IV. Reporting Requirements

1. The permittee shall notify the director (the appropriate District Office or local air agency) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated sulfur dioxide emission rates from Section A.III of this permit. The notification shall include a copy of such record and shall be sent to the director (the appropriate District Office or local air agency) within 45 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

2. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than No. 2 fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1)]

V. Testing Requirements

1. Compliance with the emission limitation(s) in section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

V. Testing Requirements (continued)

- a. Emission limitation-
Visible PE shall not exceed 20% opacity as a 6-minute average.

Applicable Compliance Method-

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rules 3745-17-03(B)(1) and 3745-77-07(C)(1)]

- b. Emission limitation-
PE shall not exceed 0.040 lb/mmBtu actual heat input.

Applicable Compliance Method-

Compliance shall be based upon an emission factor of 0.012 lb/mmBtu. This emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1 (4/2000), Table 3.1-2a. If required, the permittee shall demonstrate compliance with this emission limitation in accordance with the methods and procedures specified in OAC rule 3745-17-03(B)(10).

[Authority for term: OAC rules 3745-17-03(B)(10) and 3745-77-07(C)(1)]

- c. Emission limitation-
Sulfur dioxide emissions shall not exceed 0.5 lb/mmBtu actual heat input.

Applicable Compliance Method-

Compliance with the allowable sulfur dioxide emission limitation may be demonstrated by documenting that the sulfur content of each shipment of oil received or each daily sample collected during a calendar month meets the limitation. If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

[Authority for term: OAC rules 3745-18-04(F) and 3745-77-07(C)(1)]

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Steam Generator (B008)

Activity Description: 300hp natural gas and #2 fuel oil fired steam generator for the steam and hot water distribution systems

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B008 - 12.553 mmBtu/hr (300 hp) natural gas and No. 2 oil fired steam generator	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	<p>Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 0.13 lb/mmBtu of actual heat input while combusting natural gas and 0.14 lb/mmBtu of actual heat input while combusting No. 2 fuel oil.</p> <p>NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.</p> <p>Sulfur dioxide (SO₂) emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.</p> <p>Organic compound (OC) emissions from this emissions unit shall not exceed 0.14 lb/hr.</p> <p>OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.</p> <p>Carbon monoxide (CO) emissions from this emissions unit shall not exceed 1.05 lbs/hr.</p> <p>CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.</p>

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	<p>Particulate emissions (PE) from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period.</p> <p>Visible PE from any stack shall not exceed 5% opacity as a six-minute average.</p> <p>The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-10(B)(1) 40 CFR Part 60, Subpart Dc.</p>
	OAC rule 3745-17-07(A) OAC rule 3745-18-06(D)	The emissions limitations specified by these rules are less stringent than the emissions limitations established pursuant to OAC rule 3745-31-05(C).
	OAC rule 3745-17-10(B)(1)	PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.
	OAC rule 3745-21-08(B) 40 CFR Part 60, Subpart Dc	<p>See Section A.I.2.b below.</p> <p>SO2 emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.</p>

2. Additional Terms and Conditions

- 2.a** The 1.05 lbs CO/hour and 0.14 lb OC/hour emissions limitations were established for PTI purposes to reflect the potential to emit for this emissions unit. Therefore, it is not necessary to develop monitoring, record keeping and/or reporting requirements to ensure compliance with these emissions limitations.
- 2.b** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(C) in this Permit to Install.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. However, that rule revision has not yet been submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

- 1.** The permittee shall burn only natural gas and/or No. 2 fuel oil in this emissions unit.
 [Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]
- 2.** The annual natural gas usage for emissions units B008, B009, B010 and B011 shall not exceed 693 million cubic feet (mmcf) based upon a rolling, 12-month summation of the natural gas usage rates.
 [Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

II. Operational Restrictions (continued)

3. The annual No. 2 fuel oil usage for emissions units B008, B009, B010 and B011 shall not exceed 536,462 gallons based upon a rolling, 12-month summation of the No. 2 fuel oil usage rates.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

4. The quality of oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable SO₂ emissions limitation specified in Section A.I.1 above.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain monthly records of the following information for emissions units B008, B009, B010 and B011:

- a. The total combined quantity of natural gas burned, in mmcf.
- b. The total combined quantity of No. 2 fuel oil burned, in gallons.
- c. The rolling, 12-month summation of natural gas usage, in mmcf.
- d. The rolling, 12-month summation of the No. 2 fuel oil usage, in gallons.
- e. The monthly PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.
- f. The rolling, 12-month summation of the PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

- a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F). A shipment may be comprised of multiple tank truck loads from the same supplier's batch, or may be represented by single or multiple pipeline deliveries from the same supplier's batch, and the quality of the oil for those loads or pipeline deliveries may be represented by a single batch analysis from the supplier.

III. Monitoring and/or Record Keeping Requirements (continued)

b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods, such as ASTM methods D240 Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter and D4294, Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry, or equivalent methods as approved by the director.

[Authority for term: OAC rules 3745-18-04(E)(3) and 3745-77-07(C)(1) and PTI 08-3566]

3. On each day during which the permittee burns a fuel other than natural gas or No. 2 fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

IV. Reporting Requirements

1. The permittee shall submit quarterly deviation (excursion) reports that identify all exceedances of the following
- The rolling, 12-month natural gas usage limitation for emissions units B008, B009, B010 and B011.
 - The rolling, 12-month No. 2 fuel oil usage limitation for emissions units B008, B009, B010 and B011.
 - The rolling, 12-month PE, NO_x, SO₂, CO, and VOC emissions limitations for emissions units B008, B009, B010 and B011.

The permittee shall submit quarterly deviation (excursion) reports in accordance with the General Terms and Conditions of this permit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall notify the director (the appropriate District Office or local air agency) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated sulfur dioxide emission rates from Section A.III of this permit. The notification shall include a copy of such record and shall be sent to the director (the appropriate District Office or local air agency) within 45 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas and/or No. 2 fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.13 lb NOx/mmBtu of actual heat input while combusting natural gas.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- b. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.14 lb NOx/mmBtu of actual heat input while combusting No. 2 fuel oil.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- c. Emission Limitation -

NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.13 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.14 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - iii. the rolling, 12-month NOx emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- d. Emission Limitation -

SO2 emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 0.6 lb SO2/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation shall be determined by the monitoring and record keeping requirements specified in A.III.1 of this permit.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 6.

[Authority for term: OAC rules 3745-18-04(F) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

e. Emission Limitation -

SO₂ emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.6 lb SO₂/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor determined by the monitoring and record keeping requirements specified in A.III.1 of this permit and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month SO₂ emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

f. Emission Limitation -

OC emissions from this emissions unit shall not exceed 0.14 lb/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (12.553 mmBtu/hr) by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (12.553 mmBtu/hr) by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Methods 18, 25 or 25A, as appropriate.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

g. Emission Limitation -

OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month OC emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

h. Emission Limitation -

CO emissions from this emissions unit shall not exceed 1.05 lbs/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (12.553 mmBtu/hr) by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (12.553 mmBtu/hr) by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 10.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

i. Emission Limitation -

CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month CO emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

j. Emission Limitation -

PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by dividing the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 5.

[Authority for term: OAC rules 3745-17-03(B)(9) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

k. Emission Limitation -

PE from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

i. multiplying the natural gas usage for the month by the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.

ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.

iii. the rolling, 12-month PE rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

l. Emission Limitation -

Visible PE from any stack shall not exceed 5% opacity as a six-minute average.

Applicable Compliance Method -

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rules 3745-17-03(B)(1) and 3745-77-07(C)(1) and PTI 08-3566]

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Steam Generator (B009)

Activity Description: 600hp natural gas and #2 fuel oil fired steam generator for the steam and hot water distribution systems

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B009 - 25.106 mmBtu/hr (600 hp) natural gas and No. 2 oil fired steam generator	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	<p>Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 0.13 lb/mmBtu of actual heat input while combusting natural gas and 0.14 lb/mmBtu of actual heat input while combusting No. 2 fuel oil.</p> <p>NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.</p> <p>Sulfur dioxide (SO₂) emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.</p> <p>Organic compound (OC) emissions from this emissions unit shall not exceed 0.28 lb/hr.</p> <p>OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.</p> <p>Carbon monoxide (CO) emissions from this emissions unit shall not exceed 2.11 lbs/hr.</p> <p>CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.</p>

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	<p>Particulate emissions (PE) from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period.</p> <p>Visible PE from any stack shall not exceed 5% opacity as a six-minute average.</p> <p>The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-10(B)(1) 40 CFR Part 60, Subpart Dc.</p>
	OAC rule 3745-17-07(A) OAC rule 3745-18-06(D)	The emissions limitations specified by these rules are less stringent than the emissions limitations established pursuant to OAC rule 3745-31-05(C).
	OAC rule 3745-17-10(B)(1)	PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.
	OAC rule 3745-21-08(B) 40 CFR Part 60, Subpart Dc	<p>See Section A.I.2.b below.</p> <p>SO₂ emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.</p>

2. Additional Terms and Conditions

- 2.a** The 2.11 lbs CO/hour and 0.28 lb OC/hour emissions limitations were established for PTI purposes to reflect the potential to emit for this emissions unit. Therefore, it is not necessary to develop monitoring, record keeping and/or reporting requirements to ensure compliance with these emissions limitations.
- 2.b** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(C) in this Permit to Install.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. However, that rule revision has not yet been submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

- 1.** The permittee shall burn only natural gas and/or No. 2 fuel oil in this emissions unit.
 [Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]
- 2.** The annual natural gas usage for emissions units B008, B009, B010 and B011 shall not exceed 693 million cubic feet (mmcf) based upon a rolling, 12-month summation of the natural gas usage rates.
 [Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

II. Operational Restrictions (continued)

3. The annual No. 2 fuel oil usage for emissions units B008, B009, B010 and B011 shall not exceed 536,462 gallons based upon a rolling, 12-month summation of the No. 2 fuel oil usage rates.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

4. The quality of oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable SO₂ emissions limitation specified in Section A.I.1 above.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain monthly records of the following information for emissions units B008, B009, B010 and B011:

- a. The total combined quantity of natural gas burned, in mmcf.
- b. The total combined quantity of No. 2 fuel oil burned, in gallons.
- c. The rolling, 12-month summation of natural gas usage, in mmcf.
- d. The rolling, 12-month summation of the No. 2 fuel oil usage, in gallons.
- e. The monthly PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.
- f. The rolling, 12-month summation of the PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

- a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F). A shipment may be comprised of multiple tank truck loads from the same supplier's batch, or may be represented by single or multiple pipeline deliveries from the same supplier's batch, and the quality of the oil for those loads or pipeline deliveries may be represented by a single batch analysis from the supplier.

III. Monitoring and/or Record Keeping Requirements (continued)

b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods, such as ASTM methods D240 Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter and D4294, Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry, or equivalent methods as approved by the director.

[Authority for term: OAC rules 3745-18-04(E)(3) and 3745-77-07(C)(1) and PTI 08-3566]

3. On each day during which the permittee burns a fuel other than natural gas or No. 2 fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

IV. Reporting Requirements

1. The permittee shall submit quarterly deviation (excursion) reports that identify all exceedances of the following
- a. The rolling, 12-month natural gas usage limitation for emissions units B008, B009, B010 and B011.
 - b. The rolling, 12-month No. 2 fuel oil usage limitation for emissions units B008, B009, B010 and B011.
 - c. The rolling, 12-month PE, NO_x, SO₂, CO, and VOC emissions limitations for emissions units B008, B009, B010 and B011.

The permittee shall submit quarterly deviation (excursion) reports in accordance with the General Terms and Conditions of this permit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall notify the director (the appropriate District Office or local air agency) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated sulfur dioxide emission rates from Section A.III of this permit. The notification shall include a copy of such record and shall be sent to the director (the appropriate District Office or local air agency) within 45 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas and/or No. 2 fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.13 lb NOx/mmBtu of actual heat input while combusting natural gas.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- b. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.14 lb NOx/mmBtu of actual heat input while combusting No. 2 fuel oil.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- c. Emission Limitation -

NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.13 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.14 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - iii. the rolling, 12-month NOx emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- d. Emission Limitation -

SO2 emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 0.6 lb SO2/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation shall be determined by the monitoring and record keeping requirements specified in A.III.1 of this permit.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 6.

[Authority for term: OAC rules 3745-18-04(F) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

e. Emission Limitation -

SO₂ emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.6 lb SO₂/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor determined by the monitoring and record keeping requirements specified in A.III.1 of this permit and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month SO₂ emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

f. Emission Limitation -

OC emissions from this emissions unit shall not exceed 0.28 lb/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Methods 18, 25 or 25A, as appropriate.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

g. Emission Limitation -

OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month OC emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

h. Emission Limitation -

CO emissions from this emissions unit shall not exceed 2.11 lbs/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 10.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

i. Emission Limitation -

CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month CO emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

j. Emission Limitation -

PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by dividing the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 5.

[Authority for term: OAC rules 3745-17-03(B)(9) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

k. Emission Limitation -

PE from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

i. multiplying the natural gas usage for the month by the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.

ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.

iii. the rolling, 12-month PE rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

l. Emission Limitation -

Visible PE from any stack shall not exceed 5% opacity as a six-minute average.

Applicable Compliance Method -

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rules 3745-17-03(B)(1) and 3745-77-07(C)(1) and PTI 08-3566]

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Steam Generator (B010)

Activity Description: 600hp natural gas and #2 fuel oil fired steam generator for the steam and hot water distribution systems

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B010 - 25.106 mmBtu/hr (600 hp) natural gas and No. 2 oil fired steam generator	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	<p>Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 0.13 lb/mmBtu of actual heat input while combusting natural gas and 0.14 lb/mmBtu of actual heat input while combusting No. 2 fuel oil.</p> <p>NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.</p> <p>Sulfur dioxide (SO₂) emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.</p> <p>Organic compound (OC) emissions from this emissions unit shall not exceed 0.28 lb/hr.</p> <p>OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.</p> <p>Carbon monoxide (CO) emissions from this emissions unit shall not exceed 2.11 lbs/hr.</p> <p>CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.</p>

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	<p>Particulate emissions (PE) from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period.</p> <p>Visible PE from any stack shall not exceed 5% opacity as a six-minute average.</p> <p>The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-10(B)(1) 40 CFR Part 60, Subpart Dc.</p>
	OAC rule 3745-17-07(A) OAC rule 3745-18-06(D)	The emissions limitations specified by these rules are less stringent than the emissions limitations established pursuant to OAC rule 3745-31-05(C).
	OAC rule 3745-17-10(B)(1)	PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.
	OAC rule 3745-21-08(B) 40 CFR Part 60, Subpart Dc	<p>See Section A.I.2.b below.</p> <p>SO2 emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.</p>

2. Additional Terms and Conditions

- 2.a** The 2.11 lbs CO/hour and 0.28 lb OC/hour emissions limitations were established for PTI purposes to reflect the potential to emit for this emissions unit. Therefore, it is not necessary to develop monitoring, record keeping and/or reporting requirements to ensure compliance with these emissions limitations.
- 2.b** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(C) in this Permit to Install.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. However, that rule revision has not yet been submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

- 1.** The permittee shall burn only natural gas and/or No. 2 fuel oil in this emissions unit.
[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]
- 2.** The annual natural gas usage for emissions units B008, B009, B010 and B011 shall not exceed 693 million cubic feet (mmcf) based upon a rolling, 12-month summation of the natural gas usage rates.
[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

II. Operational Restrictions (continued)

3. The annual No. 2 fuel oil usage for emissions units B008, B009, B010 and B011 shall not exceed 536,462 gallons based upon a rolling, 12-month summation of the No. 2 fuel oil usage rates.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

4. The quality of oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable SO₂ emissions limitation specified in Section A.I.1 above.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain monthly records of the following information for emissions units B008, B009, B010 and B011:

- a. The total combined quantity of natural gas burned, in mmcf.
- b. The total combined quantity of No. 2 fuel oil burned, in gallons.
- c. The rolling, 12-month summation of natural gas usage, in mmcf.
- d. The rolling, 12-month summation of the No. 2 fuel oil usage, in gallons.
- e. The monthly PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.
- f. The rolling, 12-month summation of the PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

- a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F). A shipment may be comprised of multiple tank truck loads from the same supplier's batch, or may be represented by single or multiple pipeline deliveries from the same supplier's batch, and the quality of the oil for those loads or pipeline deliveries may be represented by a single batch analysis from the supplier.

III. Monitoring and/or Record Keeping Requirements (continued)

b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods, such as ASTM methods D240 Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter and D4294, Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry, or equivalent methods as approved by the director.

[Authority for term: OAC rules 3745-18-04(E)(3) and 3745-77-07(C)(1) and PTI 08-3566]

3. On each day during which the permittee burns a fuel other than natural gas or No. 2 fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

IV. Reporting Requirements

1. The permittee shall submit quarterly deviation (excursion) reports that identify all exceedances of the following
- The rolling, 12-month natural gas usage limitation for emissions units B008, B009, B010 and B011.
 - The rolling, 12-month No. 2 fuel oil usage limitation for emissions units B008, B009, B010 and B011.
 - The rolling, 12-month PE, NO_x, SO₂, CO, and VOC emissions limitations for emissions units B008, B009, B010 and B011.

The permittee shall submit quarterly deviation (excursion) reports in accordance with the General Terms and Conditions of this permit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall notify the director (the appropriate District Office or local air agency) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated sulfur dioxide emission rates from Section A.III of this permit. The notification shall include a copy of such record and shall be sent to the director (the appropriate District Office or local air agency) within 45 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas and/or No. 2 fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.13 lb NOx/mmBtu of actual heat input while combusting natural gas.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- b. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.14 lb NOx/mmBtu of actual heat input while combusting No. 2 fuel oil.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- c. Emission Limitation -

NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.13 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.14 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - iii. the rolling, 12-month NOx emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- d. Emission Limitation -

SO2 emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 0.6 lb SO2/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation shall be determined by the monitoring and record keeping requirements specified in A.III.1 of this permit.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 6.

[Authority for term: OAC rules 3745-18-04(F) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

e. Emission Limitation -

SO₂ emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.6 lb SO₂/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor determined by the monitoring and record keeping requirements specified in A.III.1 of this permit and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month SO₂ emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

f. Emission Limitation -

OC emissions from this emissions unit shall not exceed 0.28 lb/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Methods 18, 25 or 25A, as appropriate.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

g. Emission Limitation -

OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month OC emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

h. Emission Limitation -

CO emissions from this emissions unit shall not exceed 2.11 lbs/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 10.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

i. Emission Limitation -

CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month CO emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

j. Emission Limitation -

PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by dividing the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 5.

[Authority for term: OAC rules 3745-17-03(B)(9) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

k. Emission Limitation -

PE from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

i. multiplying the natural gas usage for the month by the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.

ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.

iii. the rolling, 12-month PE rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

l. Emission Limitation -

Visible PE from any stack shall not exceed 5% opacity as a six-minute average.

Applicable Compliance Method -

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rules 3745-17-03(B)(1) and 3745-77-07(C)(1) and PTI 08-3566]

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Steam Generator (B011)

Activity Description: 600hp natural gas and #2 fuel oil fired steam generator for the steam and hot water distribution systems

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B011 - 25.106 mmBtu/hr (600 hp) natural gas and No. 2 oil fired steam generator	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	<p>Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 0.13 lb/mmBtu of actual heat input while combusting natural gas and 0.14 lb/mmBtu of actual heat input while combusting No. 2 fuel oil.</p> <p>NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.</p> <p>Sulfur dioxide (SO2) emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.</p> <p>Organic compound (OC) emissions from this emissions unit shall not exceed 0.28 lb/hr.</p> <p>OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.</p> <p>Carbon monoxide (CO) emissions from this emissions unit shall not exceed 2.11 lbs/hr.</p> <p>CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.</p>

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
	OAC rule 3745-31-05(C) (Netting to avoid PSD) PTI 08-03566	Particulate emissions (PE) from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period. Visible PE from any stack shall not exceed 5% opacity as a six-minute average. The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-10(B)(1) 40 CFR Part 60, Subpart Dc.
	OAC rule 3745-17-07(A) OAC rule 3745-18-06(D)	The emissions limitations specified by these rules are less stringent than the emissions limitations established pursuant to OAC rule 3745-31-05(C).
	OAC rule 3745-17-10(B)(1)	PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.
	OAC rule 3745-21-08(B) 40 CFR Part 60, Subpart Dc	See Section A.I.2.b below. SO ₂ emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.

2. Additional Terms and Conditions

- 2.a** The 2.11 lbs CO/hour and 0.28 lb OC/hour emissions limitations were established for PTI purposes to reflect the potential to emit for this emissions unit. Therefore, it is not necessary to develop monitoring, record keeping and/or reporting requirements to ensure compliance with these emissions limitations.
- 2.b** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(C) in this Permit to Install.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. However, that rule revision has not yet been submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

- 1. The permittee shall burn only natural gas and/or No. 2 fuel oil in this emissions unit.
[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]
- 2. The annual natural gas usage for emissions units B008, B009, B010 and B011 shall not exceed 693 million cubic feet (mmcf) based upon a rolling, 12-month summation of the natural gas usage rates.
[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

II. Operational Restrictions (continued)

3. The annual No. 2 fuel oil usage for emissions units B008, B009, B010 and B011 shall not exceed 536,462 gallons based upon a rolling, 12-month summation of the No. 2 fuel oil usage rates.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

4. The quality of oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable SO₂ emissions limitation specified in Section A.I.1 above.

[Authority for term: OAC rule 3745-77-07(A)(1) and PTI 08-3566]

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain monthly records of the following information for emissions units B008, B009, B010 and B011:

- a. The total combined quantity of natural gas burned, in mmcf.
- b. The total combined quantity of No. 2 fuel oil burned, in gallons.
- c. The rolling, 12-month summation of natural gas usage, in mmcf.
- d. The rolling, 12-month summation of the No. 2 fuel oil usage, in gallons.
- e. The monthly PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.
- f. The rolling, 12-month summation of the PE, NO_x, SO₂, CO, and VOC emissions rates, in tons.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

- a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F). A shipment may be comprised of multiple tank truck loads from the same supplier's batch, or may be represented by single or multiple pipeline deliveries from the same supplier's batch, and the quality of the oil for those loads or pipeline deliveries may be represented by a single batch analysis from the supplier.

III. Monitoring and/or Record Keeping Requirements (continued)

b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods, such as ASTM methods D240 Standard Test Method for Heat of Combustion of Liquid Hydrocarbon Fuels by Bomb Calorimeter and D4294, Standard Test Method for Sulfur in Petroleum and Petroleum Products by Energy-Dispersive X-Ray Fluorescence Spectrometry, or equivalent methods as approved by the director.

[Authority for term: OAC rules 3745-18-04(E)(3) and 3745-77-07(C)(1) and PTI 08-3566]

3. On each day during which the permittee burns a fuel other than natural gas or No. 2 fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

IV. Reporting Requirements

1. The permittee shall submit quarterly deviation (excursion) reports that identify all exceedances of the following
- The rolling, 12-month natural gas usage limitation for emissions units B008, B009, B010 and B011.
 - The rolling, 12-month No. 2 fuel oil usage limitation for emissions units B008, B009, B010 and B011.
 - The rolling, 12-month PE, NO_x, SO₂, CO, and VOC emissions limitations for emissions units B008, B009, B010 and B011.

The permittee shall submit quarterly deviation (excursion) reports in accordance with the General Terms and Conditions of this permit.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

2. The permittee shall notify the director (the appropriate District Office or local air agency) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated sulfur dioxide emission rates from Section A.III of this permit. The notification shall include a copy of such record and shall be sent to the director (the appropriate District Office or local air agency) within 45 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas and/or No. 2 fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.13 lb NOx/mmBtu of actual heat input while combusting natural gas.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- b. Emission Limitation -

NOx emissions from this emissions unit shall not exceed 0.14 lb NOx/mmBtu of actual heat input while combusting No. 2 fuel oil.

Applicable Compliance Method -

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 7.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- c. Emission Limitation -

NOx emissions from emissions units B008, B009, B010 and B011 shall not exceed 50.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.13 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.14 lb NOx/mmBtu, by 1000 mmBtu/mmcf and dividing by 2000 lbs/ton.
 - iii. the rolling, 12-month NOx emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

- d. Emission Limitation -

SO2 emissions from this emissions unit shall not exceed 0.50 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 0.6 lb SO2/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation shall be determined by the monitoring and record keeping requirements specified in A.III.1 of this permit.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 6.

[Authority for term: OAC rules 3745-18-04(F) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

e. Emission Limitation -

SO₂ emissions from emissions units B008, B009, B010 and B011 shall not exceed 19.3 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 0.6 lb SO₂/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor determined by the monitoring and record keeping requirements specified in A.III.1 of this permit and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month SO₂ emission rate shall be the sum of i and ii above for the rolling, 12-month period

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

f. Emission Limitation -

OC emissions from this emissions unit shall not exceed 0.28 lb/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Methods 18, 25 or 25A, as appropriate.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

g. Emission Limitation -

OC emissions from emissions units B008, B009, B010 and B011 shall not exceed 4.0 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 11 lbs OC/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 0.556 lb OC/1000 gal (AP-42, Table 1.3-3, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month OC emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

h. Emission Limitation -

CO emissions from this emissions unit shall not exceed 2.11 lbs/hr.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by multiplying the maximum hourly heat input of the emissions unit (25.106 mmBtu/hr) by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 10.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

i. Emission Limitation -

CO emissions from emissions units B008, B009, B010 and B011 shall not exceed 30.4 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

- i. multiplying the natural gas usage for the month by the emission factor 84 lbs CO/mmcf (AP-42, Table 1.4-1, 7/98) and dividing by 2000 lbs/ton.
- ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 5 lbs CO/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.
- iii. the rolling, 12-month CO emission rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

j. Emission Limitation -

PE from this emissions unit shall not exceed 0.020 lb/mmBtu of actual heat input.

Applicable Compliance Method -

When firing natural gas, compliance with the emissions limitation may be determined by dividing the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) by 1000 mmBtu/mmcf.

When firing No. 2 fuel oil, compliance with the emissions limitation may be determined by dividing the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) by 140 mmBtu/1000 gal.

The permittee may demonstrate compliance with this emission limitation in accordance 40 CFR, Part 60, Appendix A, Method 5.

[Authority for term: OAC rules 3745-17-03(B)(9) and 3745-77-07(C)(1) and PTI 08-3566]

V. Testing Requirements (continued)

k. Emission Limitation -

PE from emissions units B008, B009, B010 and B011 shall not exceed 7.7 tons per rolling 12-month period.

Applicable Compliance Method -

Compliance with the emissions limitation shall be based upon record keeping specified in A.III.1 and shall be determined by:

i. multiplying the natural gas usage for the month by the emission factor 7.6 lbs PE/mmcf (AP-42, Table 1.4-2, 7/98) and dividing by 2000 lbs/ton.

ii. multiplying the No. 2 fuel oil usage for the month by the emission factor 2 lbs PE/1000 gal (AP-42, Table 1.3-1, 9/98) and dividing by 2000 lbs/ton.

iii. the rolling, 12-month PE rate shall be the sum of i and ii above for the rolling, 12-month period.

[Authority for term: OAC rule 3745-77-07(C)(1) and PTI 08-3566]

l. Emission Limitation -

Visible PE from any stack shall not exceed 5% opacity as a six-minute average.

Applicable Compliance Method -

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rules 3745-17-03(B)(1) and 3745-77-07(C)(1) and PTI 08-3566]

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

THIS IS THE LAST PAGE OF THE PERMIT

Statement of Basis For Title V Permit

Part I - General	
Company Name	Piqua Municipal Power System
Premise Number	0855100041
What makes this facility a Title V facility?	NOx and SO2
Has each insignificant emissions unit been reviewed to confirm it meets the definition in OAC rule 3745-77-01 (U)?	Yes
Were there any "common control" issues associated with this facility? If yes, provide a summary of those issues and explain how the DAPC decided to resolve them.	No
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a minor permit modification per OAC rule 3745-77-08(C)(1)	Not Applicable
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a significant permit modification per OAC rule 3745-77-08(C)(3)	Not Applicable
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a reopening per OAC rule 3745-77-08(D)	Not Applicable
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document resulting from a renewal per OAC rule 3745-77-08(E)	<p>PTI 08-03566 was administratively modified on 9/27/2007 as follows:</p> <ol style="list-style-type: none"> 1. The original PTI contained individual short term and annual emissions limits. It also included a term that allowed the emissions limits for all four to be combined into a group limit. The PTI was revised to remove the individual limits and retain the group limits only. 2. Revised the OC and CO lb/hr and annual emissions limits because AP-42 emissions factors have changed. 3. Removed lb/hr emissions limits for SO2 and PE. The limits are not needed since there are lb/mmBtu short term emissions limits. 4. Replaced the daily fuel record-keeping requirement with a monthly requirement.

Part II (State and Federally Enforceable Requirements)			
Term and Condition (paragraph)	Basis		Comments
	SIP (3745-)	Other	
A.1	N	Y	Restart requirements for inactive emissions units.
A.2	N	Y	NOx emissions limit for emissions units B007, B008, B009, B010 and B011.
A.3	N	Y	Record keeping requirements for NOx emissions limit for emissions units B007, B008, B009, B010 and B011.
A.4	N	Y	Reporting requirements for NOx emissions limit for emissions units B007, B008, B009, B010 and B011.
A.5	N	Y	Testing requirements for NOx emissions limit for emissions units B007, B008, B009, B010 and B011.

C **Instructions for Part II:**
Each paragraph in Part II must be identified and the remainder of the table completed. If the SIP (not including 31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an "N" in the column under "SIP." If the basis for the term and condition is something other than the SIP, including 3745-31-05, NSPS or MACT, a "Y" should be noted in the "Other" column, and if not, an "N" should be noted. Whether the basis for the term and condition is the "SIP" or "Other," an explanation of each term and condition in Part II must be provided in the "Comments" section.

Part III (Requirements Within the State and Federally Enforceable Section)															
Any unusual requirements or aspects of the terms and conditions in Part III that are not self-explanatory should be explained in the appropriate comment field or in a paragraph following the table for Part III.															
EU(s)	Limitation	Basis		ND	OR	M	St	ENF	R	St	Rp	St	ET	Misc	Comments
		SIP (3745-)	Other												
B007	20% opacity	17-07(A)		N	N	N	N	N	N	N	N	N	N	N	M: Monitoring is not necessary. The sources comply with the particulate emission limitation based on emission factors. Since they comply with the particulate standard, compliance with the opacity standard can be assumed. CAM does not apply. R: Record keeping is not necessary. See discussion in "Monitoring" above. Rp: Reporting is not necessary. See discussion in "Monitoring" above. ET: Visible emissions evaluations in accordance with Method 9.

EU(s)	Limitation	Basis		ND	OR	M	St	ENF	R	St	Rp	St	ET	Misc	Comments
		SIP (3745-)	Other												
B007	0.040 lb particulate/ mmBtu heat input	17-11(B)(4)		N	N	N	N	N	N	N	N	N	N	N	M: Compliance is based on emission factor. Monitoring is not necessary. CAM does not apply. R: Compliance is based on emission factor. Record keeping is not necessary. Rp: Compliance is based on emission factor. Reporting is not necessary. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B007	0.5 lb SO2/ mmBtu heat input	18-61(B)(2)		N	Y	Y	N	N	Y	N	Y	N	N	N	OR: The quality of the oil burned shall meet a sulfur content that is sufficient to comply with the allowable SO2 emission limitation. M: Note CAM does not apply. ET: Emissions testing is not necessary. Compliance is determined using a mass balance.
B008-B011	0.13 lb NOx/mmBtu (natural gas); 0.14 lb NOx/mmBtu (fuel oil)	31-05(C)	PTI 08-03566	N	N	N	N	N	N	N	N	N	N	N	M: Compliance is based on emission factor. Monitoring is not necessary. CAM does not apply. R: Compliance is based on emission factor. Record keeping is not necessary. Rp: Compliance is based on emission factor. Reporting is not necessary. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B008-B011	50.4 tons NOx/rolling 12-month period combined for B008-B011	31-05(C)	PTI 08-03566	N	Y	Y	N	N	Y	N	Y	N	N	N	OR: Natural gas usage for B008-B011 shall not exceed 693 mmcf/rolling 12-month period. Also, fuel oil usage for B008-B011 shall not exceed 536,462 gal/rolling 12-month period. M: CAM does not apply. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B008-B011	19.3 tons SO2/rolling 12-month period combined for B008-B011	31-05(C)	PTI 08-03566	N	Y	Y	N	N	Y	N	Y	N	N	N	OR: Natural gas usage for B008-B011 shall not exceed 693 mmcf/rolling 12-month period. Also, fuel oil usage for B008-B011 shall not exceed 536,462 gal/rolling 12-month period. M: CAM does not apply. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.

EU(s)	Limitation	Basis		ND	OR	M	St	ENF	R	St	Rp	St	ET	Misc	Comments
		SIP (3745-)	Other												
B008	0.14 lb OC/hr	31-05(C)	PTI 08- 03566	N	N	N	N	N	N	N	N	N	N	N	M: Compliance is based on emission factor. Monitoring is not necessary. CAM does not apply. R: Compliance is based on emission factor. Record keeping is not necessary. Rp: Compliance is based on emission factor. Reporting is not necessary. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B009- B011	0.28 lb OC/hr	31-05(C)	PTI 08- 03566	N	N	N	N	N	N	N	N	N	N	N	M: Compliance is based on emission factor. Monitoring is not necessary. CAM does not apply. R: Compliance is based on emission factor. Record keeping is not necessary. Rp: Compliance is based on emission factor. Reporting is not necessary. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B008- B011	4.0 tons OC/rolling 12-month period combined for B008- B011	31-05(C)	PTI 08- 03566	N	Y	Y	N	N	Y	N	Y	N	N	N	OR: Natural gas usage for B008-B011 shall not exceed 693 mmcf/rolling 12-month period. Also, fuel oil usage for B008-B011 shall not exceed 536,462 gal/rolling 12-month period. M: CAM does not apply. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B008	1.05 lb CO/hr	31-05(C)	PTI 08- 03566	N	N	N	N	N	N	N	N	N	N	N	M: Compliance is based on emission factor. Monitoring is not necessary. CAM does not apply. R: Compliance is based on emission factor. Record keeping is not necessary. Rp: Compliance is based on emission factor. Reporting is not necessary. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B009- B011	2.11 lb CO/hr	31-05(C)	PTI 08- 03566	N	N	N	N	N	N	N	N	N	N	N	M: Compliance is based on emission factor. Monitoring is not necessary. CAM does not apply. R: Compliance is based on emission factor. Record keeping is not necessary. Rp: Compliance is based on emission factor. Reporting is not necessary. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.

EU(s)	Limitation	Basis		ND	OR	M	St	ENF	R	St	Rp	St	ET	Misc	Comments
		SIP (3745-)	Other												
B008-B011	7.7 tons PE/rolling 12-month period combined for B008-B011	31-05(C)	PTI 08-03566	N	Y	Y	N	N	Y	N	Y	N	N	N	OR: Natural gas usage for B008-B011 shall not exceed 693 mmcf/rolling 12-month period. Also, fuel oil usage for B008-B011 shall not exceed 536,462 gal/rolling 12-month period. M: CAM does not apply. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B008-B011	20% opacity	31-05(C)	PTI 08-03566	N	N	N	N	N	N	N	N	N	N	N	M: Monitoring is not necessary. The sources comply with the particulate emission limitation based on emission factors. Since they comply with the particulate standard, compliance with the opacity standard can be assumed. CAM does not apply. R: Record keeping is not necessary. See discussion in "Monitoring" above. Rp: Reporting is not necessary. See discussion in "Monitoring" above. ET: Visible emissions evaluations in accordance with Method 9.
B008-B011	0.020 lb particulate/MMBtu heat input	17-10(B)(1)		N	N	N	N	N	N	N	N	N	N	N	M: Compliance is based on emission factor. Monitoring is not necessary. CAM does not apply. R: Compliance is based on emission factor. Record keeping is not necessary. Rp: Compliance is based on emission factor. Reporting is not necessary. ET: Compliance is based on emission factor. If required, demonstrate compliance through emissions test.
B008-B011	0.50 lb SO2/mmBtu heat input		40 CFR Part 60, Subpart Dc	N	Y	Y	N	N	Y	N	Y	N	N	N	OR: The quality of the oil burned shall meet a sulfur content that is sufficient to comply with the allowable SO2 emission limitation. M: Note CAM does not apply. ET: Emissions testing is not necessary. Compliance is determined using a mass balance.

EU = emissions unit ID

ND = negative declaration (i.e., term that indicates that a particular rule(s) is (are) not applicable to a specific emissions unit)

OR = operational restriction

M = monitoring requirements

St = streamlining term used to replace a PTI monitoring, record keeping, or reporting requirement with an equivalent or more stringent requirement

ENF = did noncompliance issues drive the monitoring requirements?

R = record keeping requirements

Rp = reporting requirements

ET = emission testing requirements (not including compliance method terms)

Misc = miscellaneous requirements

C Instructions for Part III:

- C All non-insignificant EUs must be included in this table. For each EU, or group of similar EUs, each emission limitation and control requirement specified in section A.I.1 and A.I.2 of the permit must be identified and the remainder of the table completed.
- C If the SIP (not including OAC rule 3745-31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an "N" in the column under "SIP." If the basis for the term and condition is something other than the SIP, including OAC rule 3745-31-05, NSPS or MACT, a "Y" should be noted in the "Other" column, and if not, an "N" should be noted. If the basis for the term and condition is "Other," an explanation of the basis must be provided in the "Comments" section. If OAC rule 3745-31-05 is cited in the "Other" column, please indicate in the "Comments" section whether or not all of the requirements have been transferred from the permit to install.
- To complete the remainder of the table after "Basis," except for the "Comments" section, simply specify a "Y" for yes or an "N" for no. For the "M," "R," "Rp," and "ET" columns, if "N" is specified, there should be a brief explanation in the "Comments" section as to why there are no requirements. If a brief explanation is provided in the "Comments" section, please do not simply indicate that monitoring or testing requirements are not necessary. An explanation of why a requirement is not necessary should be specified.

When periodic monitoring requirements are established to satisfy the provisions of OAC rule 3745-77-07(A)(3)(a)(ii), the basis for the requirements must be explained. Whenever Engineering Guides have been used to establish the periodic monitoring requirements, the applicable Engineering Guide may be referenced in the "Comments" section. An example that should be clarified would be the situation where it has been determined that control equipment parametric monitoring will be used to evaluate ongoing compliance in lieu of performing frequent emission tests. In this situation, Engineering Guide #65 would be referenced along with the fact that the parametric monitoring range (or minimum value) corresponded to the range (or minimum value) documented during the most recent emission tests that demonstrated that the emissions unit was in compliance. If streamlining language is included in the "Monitoring," "Record Keeping," or "Reporting" requirements sections of the permit, explain which requirements are being streamlined (mark appropriate column above) and provide a brief explanation of why the streamlined term is equal to or more stringent than the "Monitoring," "Record Keeping," or "Reporting" requirements specified in the permit to install. If Engineering Guide #16 was used as the basis for establishing an emission test frequency, a simple note referencing the Engineering Guide in the "Comments" section would be sufficient.

Also, if a "Y" is noted under "OR," "Misc," "St," "ND," or "ENF" an explanation of the requirements must be provided in the "Comments" section. In addition to a general explanation of the "OR," "Misc," "St," "ND," and/or "ENF" the following must be provided:

1. For an operational restriction, clarify if appropriate monitoring, record keeping, and reporting requirements have been specified for the operational restriction and indicate whether or not CAM is currently applicable.
2. If a control plan and schedule is included in the "Miscellaneous Requirements" section of the permit, provide an explanation in the "Comments" section of the violation, basis for the violation, and the company's proposed control plan and schedule.
3. If the "ND" column above is marked, please identify the particular rule(s) that is (are) not applicable to the specified emissions unit.
2. If the "ENF" column above is marked, please provide a brief explanation of the noncompliance issue(s) which prompted the use of the specified monitoring requirement.

An explanation is not required if an "N" is noted in the "OR," "Misc," "St," "ND," or "ENF" columns.

C Additional information for modifications - Several types of modifications, as defined by rule, may be processed concurrently. Please provide enough of a description for someone wishing to review the changes to the permit language to be able to identify where the change is made in the permit document. This brief description should be identified in the appropriate row in the

first table of this form by replacing the "N/A" in the applicable row(s). Please also indicate if the modification is being initiated by an appeal by including the ERAC case number in the "Comments" area. Please update the term-specific text in the SOB as warranted (full insertion or replacement is acceptable; bold italic and strike out is not needed). Note all modification/reopening rows should remain "N/A" when developing the SOB during the initial permit development. Note: APA's and Off-permit changes do not need to be noted in the SOB.