

## Statement of Basis For Title V Permit

Company Name	AEP, Gavin Power Plant	
Premise Number	0627010056	
Number of Non-insignificant Emissions Units	9	
What makes this facility a Title V facility?	Potential emissions of particulates, sulfur dioxide, nitrogen oxides, carbon monoxide, volatile organic compounds and hydrochloric acid.	
Has each insignificant emissions unit been reviewed to confirm it meets the definition in 3745-77-01 (U)?	Yes	

<b>Part II (State and Federally Enforceable Requirements)</b>			
Term and Condition (paragraph)	Basis		Comments
	SIP (3745- )	Other	
A.1	N	Y	Clarification that emissions units B001-4 are not subject to NSPS, Subparts D or Da.

- **Instructions for Part II:**

Each paragraph in Part II must be identified and the remainder of the table completed. If the SIP (not including 31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an “N” in the column under “SIP.” If the basis for the term and condition is something other than the SIP, including 3745-31-05, NSPS or MACT, a “Y” should be noted in the “Other” column, and if not, an “N” should be noted. Whether the basis for the term and condition is the “SIP” or “Other,” an explanation of each term and condition in Part II must be provided in the “Comments” section.

- If there were any “common control” issues associated with this facility, after the table for Part II, provide a summary of those issues and explain how the DAPC decided to resolve them.

**Part III (Requirements Within the State & Federally Enforceable Section)**

EU(s)	Limitation	Basis		OR	M	R	Rp	ET	Misc	Comments
		SIP (3745- )	O t h e r							
B001 and B002	20% opacity as a 6-minute average	17-07(A)		Y	Y	Y	Y	Y	N	OR - This is an inherently clean emissions unit based upon our knowledge and experience in regulating these types of emissions units. The emissions unit shall only be fired with number two fuel oil. ET- If required, Method 9 shall be employed to demonstrate compliance with this emission limitation.
B001 and B002	0.020 lb/mmBtu	17-10(B)(1)		Y	Y	Y	Y	Y	N	OR - This is an inherently clean emissions unit based upon our knowledge and experience in regulating these types of emissions units. The emissions unit shall only be fired with number two fuel oil. ET- Compliance can be determined through emission calculations using fuel records and an AP-42 emission factor. If required, Method 5 shall be employed to demonstrate compliance with this emission limitation.
B001 and B002	1.6 lbs/mmBtu	18-06(D)		Y	Y	Y	Y	N	N	OR - The quality of oil must meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation. ET - No emission testing is required - compliance will be based upon fuel analyses
B003 and B004	20% opacity as a 6-minute average	17-07(A)		N	Y	Y	Y	Y	N	The continuous opacity monitoring system will be used to ensure ongoing compliance with the visible particulate emission limitations.
B003 and B004	0.10 lb/mmbtu	17-10(C)(1)		N	Y	Y	Y	Y	N	The continuous opacity monitoring system will be used to ensure ongoing compliance with the particulate emission limitations.
B003 and B004	7.41 lbs/mmBtu	40 CFR Part 52.1881(b)(28)(i)		N	Y	Y	Y	Y	N	Compliance with the mass emission limitation is based on the monitoring and record keeping requirements. Emission testing, if required.
F001-F005	None	N	N							This facility is not located in an Appendix A area as described in OAC rule 3745-17-08; therefore, OAC rules 3745-17-07 and 3745-17-08 do not apply to these fugitive emissions units.

EU = emissions unit id

OR = operational restriction

M = monitoring requirements

R = recordkeeping requirements

Rp = reporting requirements

ET = emission testing requirements (not including compliance method terms)

Misc = miscellaneous requirements

- **Instructions for Part III:**

- All non-insignificant EUs must be included in this table. For each EU, or group of similar EUs, each emission limitation and control requirement specified in section A.I.1 and A.I.2 of the permit must be identified and the remainder of the table completed.
- If the SIP (not including 31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an “N” in the column under “SIP.” If the basis for the term and condition is something other than the SIP, including 3745-31-05, NSPS or MACT, a “Y” should be noted in the “Other” column, and if not, an “N” should be noted. If the basis for the term and condition is “Other,” an explanation of the basis must be provided in the “Comments” section.

To complete the remainder of the table after “Basis,” except for the “Comments” section, simply specify a “Y” for yes or an “N” for no. For the “M”, “R”, “Rp” and “ET” columns, if “N” is specified, there should be a brief explanation in the “Comments” section as to why there are no requirements. Also, if a “Y” is noted under “OR” or “Misc,” an explanation of the requirements should be provided in the “Comments” section. In addition to a general explanation of the “OR” and/or “Misc,” the following should be provided:

1. For an operational restriction, clarify if appropriate monitoring, recordkeeping, reporting requirements have been specified for the operational restriction and indicate whether or not CAM is currently applicable.
2. If a control plan and schedule is included in the “Miscellaneous Requirements” section of the permit, provide an explanation in the “Comments” section of the violation, basis for the violation, and the company’s proposed control plan and schedule.
3. If superseding language is included in the “Miscellaneous Requirements” section of the permit, explain which requirements are being superseded and which requirements are being superseded on the State-only side of the permit and why they are on the State-only side.

An explanation is not required if an “N” is noted in the “OR” column or in the “Misc” column.

- Any unusual requirements or aspects of the terms and conditions in Part III that are not self-explanatory should be explained in a paragraph following the table for Part III.