

Statement of Basis For Title V Permit

Version 2. - 3/27/98

Company Name	Oberlin College		
Premise Number	02-47-10-0408		
Number of Non-insignificant Emissions Units	3		
What makes this facility a Title V facility?	Facility emits more than 100 TPY of a criteria pollutant		
Has each insignificant emissions unit been reviewed to confirm it meets the definition in 3745-77-01 (U)?	Yes		

Part II (State and Federally Enforceable Requirements)			
Term and Condition (paragraph)	Basis		Comments
	SIP (3745-)	Other	
n/a			

- **Instructions for Part II:**

Each paragraph in Part II must be identified and the remainder of the table completed. If the SIP (not including 31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an “N” in the column under “SIP.” If the basis for the term and condition is something other than the SIP, including 3745-31-05, NSPS or MACT, a “Y” should be noted in the “Other” column, and if not, an “N” should be noted. Whether the basis for the term and condition is the “SIP” or “Other,” an explanation of each term and condition in Part II must be provided in the “Comments” section.

- If there were any “common control” issues associated with this facility, after the table for Part II, provide a summary of those issues and explain how the DAPC decided to resolve them.

Part III (Requirements Within the State & Federally Enforceable Section)

EU(s)	Limitation	Basis		OR	M	R	Rp	ET	Misc	Comments
		SIP (3745-)	Other							
B001	Sulfur dioxide emissions shall not exceed 7.19 lbs/mmBtu actual heat input	3745-18-53	N	Y	Y	Y	Y	Y	N	OR - The quality of the coal must allow the facility to meet the sulfur dioxide limits.
B001	20% opacity as a six-minute average, except as provided by rule.	3745-17-07	N	Y	Y	Y	Y	Y	N	OR - Maintaining the secondary voltage of the electrostatic precipitator to ensure that it is operating at a voltage equivalent to the voltage at which the last compliance test was conducted.
B001	0.20 pound of particulate emissions per mmBtu actual heat input.	3745-17-10	N	Y	Y	Y	Y	Y	N	OR - Maintaining the secondary voltage of the electrostatic precipitator to ensure that it is operating at a voltage equivalent to the voltage at which the last compliance test was conducted.
B002	Sulfur dioxide emissions shall not exceed 7.19 lbs/mmBtu actual heat input	N	N	Y	Y	Y	Y	Y	N	OR - The quality of the coal must allow the facility to meet the sulfur dioxide limits.
B002	20% opacity as a six-minute average, except as provided by rule.	3745-17-07	N	Y	Y	Y	Y	Y	N	OR - Maintaining the secondary voltage of the electrostatic precipitator to ensure that it is operating at a voltage equivalent to the voltage at which the last compliance test was conducted.

B002	0.20 pound of particulate emissions per mmBtu actual heat input.	3745-17-08	N	N	Y	Y	Y	Y	N	OR - Maintaining the secondary voltage of the electrostatic precipitator to ensure that it is operating at a voltage equivalent to the voltage at which the last compliance test was conducted.
B003	0.020 lb particulate per mmBtu input.	3745-17-10	N	N	Y	Y	Y	Y	N	
B003	Sulfur dioxide emissions shall not exceed 0.36 lb/mmBtu actual heat input.	3745-18-53	N	Y	Y	Y	Y	Y	N	OR - The sulfur content of the oil must be low enough to ensure the facility meets the SO2 limit.
B003	20% opacity as a six-minute average, except as provided by rule.	3745-17-07	N	N	Y	Y	Y	Y	N	

EU = emissions unit id

OR = operational restriction

M = monitoring requirements

R = recordkeeping requirements

Rp = reporting requirements

ET = emission testing requirements (not including compliance method terms)

Misc = miscellaneous requirements

• **Instructions for Part III:**

- All non-insignificant EUs must be included in this table. For each EU, or group of similar EUs, each emission limitation and control requirement specified in section A.I.1 and A.I.2 of the permit must be identified and the remainder of the table completed.
- If the SIP (not including 31-05) is the basis for the term and condition, identify the specific rule. If the SIP is not the basis for the term and condition, place an “N” in the column under “SIP.” If the basis for the term and condition is something other than the SIP, including 3745-31-05, NSPS or MACT, a “Y” should be noted in the “Other” column, and if not, an “N” should be noted. If the basis for the term and condition is “Other,” an explanation of the basis must be provided in the “Comments” section.

To complete the remainder of the table after “Basis,” except for the “Comments” section, simply specify a “Y” for yes or an “N” for no. For the “M”, “R”, “Rp” and “ET” columns, if “N” is specified, there should be a brief explanation in the “Comments” section as to why there are no requirements. Also, if a

“Y” is noted under “OR” or “Misc,” an explanation of the requirements should be provided in the “Comments” section. In addition to a general explanation of the “OR” and/or “Misc,” the following should be provided:

1. For an operational restriction, clarify if appropriate monitoring, recordkeeping, reporting requirements have been specified for the operational restriction and indicate whether or not CAM is currently applicable.
2. If a control plan and schedule is included in the “Miscellaneous Requirements” section of the permit, provide an explanation in the “Comments” section of the violation, basis for the violation, and the company’s proposed control plan and schedule.
3. If superseding language is included in the “Miscellaneous Requirements” section of the permit, explain which requirements are being superseded and which requirements are being superseded on the State-only side of the permit and why they are on the State-only side.

An explanation is not required if an “N” is noted in the “OR” column or in the “Misc” column.

- Any unusual requirements or aspects of the terms and conditions in Part III that are not self-explanatory should be explained in a paragraph following the table for Part III.