



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center  
122 S. Front Street  
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center  
P.O. Box 1049  
Columbus, OH 43216-1049

01/31/01

**CERTIFIED MAIL**

**RE: Proposed Title V Chapter 3745-77 permit**

02-47-10-0408

OBERLIN COLLEGE

Attn: Genevieve Damico AR-18J  
United States Environmental Protection Agency  
Region V  
77 West Jackson Blvd.  
Chicago, IL 60604-3590

Dear Ms. Damico:

The proposed issuance of the Title V permit for OBERLIN COLLEGE, has been created in Ohio EPA's State Air Resources System (STARS) on 01/31/01, for review by USEPA. This proposed action is identified in STARS as  3-Title V Proposed Permit T+C covering the facility specific terms and conditions, and  Title V Proposed Permit covering the general terms and conditions. This proposed permit will be processed for issuance as a final action after forty-five (45) days from USEPA's receipt of this certified letter if USEPA does not object to the proposed permit. Please contact Mike Ahern, DAPC Permit Management Unit supervisor at (614) 644-3631 by the end of the forty-five (45) day review period if you wish to object to the proposed permit.

Very truly yours,



Thomas G. Rigo, Manager  
Field Operations and Permit Section  
Division of Air Pollution Control

cc: Northeast District Office  
Becky Castle, DAPC PMU



## Ohio EPA

State of Ohio Environmental Protection Agency

### TITLE V PERMIT

Date: 01/31/01

### PROPOSED

Effective Date:

Expiration Date:

This document constitutes issuance to:

OBERLIN COLLEGE  
173 W. Lorain St.  
Service Building  
OBERLIN, OH 44074-1092

of a Title V permit for Facility ID: 02-47-10-0408

Emissions Unit ID (Company ID)/  
Emissions Unit Activity Description:

B001 (BOILER #1)  
BOILER #1

B002 (BOILER #2)  
BOILER #2

B003 (BOILER #3)  
BOILER #3

You will be contacted approximately eighteen (18) months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency listed below. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-04(A) and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the current Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

Northeast District Office  
2110 East Aurora Road  
Twinsburg, OH 44087  
(330) 425-9171

OHIO ENVIRONMENTAL PROTECTION AGENCY

---

Christopher Jones  
Director

# PART I - GENERAL TERMS AND CONDITIONS

## A. State and Federally Enforceable Section

### 1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
  - i. The date, place (as defined in the permit), and time of sampling or measurements.
  - ii. The date(s) analyses were performed.
  - iii. The company or entity that performed the analyses.
  - iv. The analytical techniques or methods used.
  - v. The results of such analyses.
  - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
  - i. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
  - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. These quarterly written reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c)(i) and (ii) pertaining to the submission of monitoring reports every six months and OAC rule 3745-77-07(A)(3)(c)(iii) pertaining to the prompt reporting of all deviations except malfunctions, which shall be reported in accordance with OAC rule 3745-15-06. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.) See B.8 below if no deviations occurred during the quarter.
  - iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. These semi-annual written reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c)(i) and (ii) pertaining to the reporting of any deviations related to the monitoring, recordkeeping, and reporting requirements. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.

- iv. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

## **2. Scheduled Maintenance/Malfunction Reporting**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports submitted pursuant to OAC rule 3745-15-06 shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c)(iii) pertaining to the prompt reporting of deviations caused by malfunctions or upsets.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

## **3. Risk Management Plans**

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

## **4. Title IV Provisions**

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

## **5. Severability Clause**

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

## **6. General Requirements**

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.

- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

**7. Fees**

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

**8. Marketable Permit Programs**

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.

**9. Reasonably Anticipated Operating Scenarios**

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these general terms and conditions shall apply to all operating scenarios authorized in this permit.

**10. Reopening for Cause**

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a. Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.
- b. This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c. The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.

- d. The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

## 11. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

## 12. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
  - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
  - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.
  - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
  - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
  - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
  - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.
- d. Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the appropriate Ohio EPA District Office or local air agency in the following manner and with the following content:
  - i. Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted on or before April 30th of each year during the permit term.
  - ii. Compliance certifications shall include the following:
    - (a) An identification of each term or condition of this permit that is the basis of the certification.
    - (b) The permittee's current compliance status.

- (c) Whether compliance was continuous or intermittent.
  - (d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.
  - (e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.
- iii. Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

### **13. Permit Shield**

- a. Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.
- b. This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.

### **14. Operational Flexibility**

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

### **15. Emergencies**

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

### **16. Off Permit Changes**

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a. The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition;
- b. The permittee provides contemporaneous written notice of the change to the director and the administrator, except that no such notice shall be required for changes that qualify as insignificant emission levels or

activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change;

- c. The change shall not qualify for the permit shield under OAC rule 3745-77-07(F);
- d. The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes; and
- e. The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit to install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.

(For further clarification, the permittee can refer to Engineering Guide #63 that is available in their STARSHIP software package.)

#### **17. Compliance Method Requirements**

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.

#### **18. Insignificant Activity**

Each insignificant activity that has one or more applicable requirements shall comply with those applicable requirements.

## **B. State Only Enforceable Section**

### **1. Permit to Install Requirement**

Prior to the “installation” or “modification” of any “air contaminant source,” as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

### **2. Reporting Requirements Related to Monitoring and Recordkeeping Requirements**

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

### **3. Records Retention Requirements**

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

### **4. Inspections and Information Requests**

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

**5. Scheduled Maintenance/Malfunction Reporting**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

**6. Permit Transfers**

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

**7. Air Pollution Nuisance**

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

**8. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)**

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

## Part II - Specific Facility Terms and Conditions

### A. State and Federally Enforcable Section

None

### B. State Only Enforceable Section

1. The following insignificant emissions units are located at this facility:

P001 - 55 kW emergency generator, natural gas-fired engine for the East Hall;

P002 - 55 kW emergency generator, natural gas-fired engine for Warner Gym;

P003 - 100 kW emergency generator, natural gas-fired engine for the Music Conservatory;

Z001 - 30,000-gallon underground diesel fuel storage tank;

Z002 - 30,000-gallon underground diesel fuel storage tank;

Z003 - 1,000-gallon above ground diesel storage tank;

Z004 - 2,000-gallon above ground gasoline storage tank;

Z006 - 38 hp natural gas-fired internal combustion engine at Peters Hall;

Z007 - 144 hp natural gas-fired internal combustion engine at South Hall;

Z008 - 5.44 million Btu per hour water heater at Dascomb Hall;

Z009 - 4.8 million Btu per hour water heater at Oberlin Inn;

Z010 - Service Building paint booth; and

Z011 - 18 kW natural gas-fired internal combustion engine at Fairchild Dorm.

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emissions limitations and/or control requirements contained within a Permit to Install for the emissions unit.

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** BOILER #1 (B001)  
**Activity Description:** BOILER #1

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock and Wilcox coal-fired boiler, having a rated heat input capacity of 50.0 million Btu per hour and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.20 pound per million Btu actual heat input.
	OAC rule 3745-18-53(F)(1)	See Section A.I.2.a below. Sulfur dioxide emissions shall not exceed 7.19 pounds per million Btu actual heat input.

##### 2. Additional Terms and Conditions

- 2.a The particulate emission limitation is based upon the total heat input from emissions units B001 and B002, pursuant to OAC rule 3745-17-10(B).

##### II. Operational Restrictions

- The quality of the coal burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation of 7.19 pounds per million Btu actual heat input.
- The average total combined power input (in kilowatts) to all fields of the ESP, for any 3-hour block of time when the emissions unit is in operation, shall be no less than 90% of the total combined power input, as a 3-hour average, during the most recent emissions test that demonstrated the emissions unit was in compliance with the particulate emission limitation.
- The permittee shall operate the ESP during any operation of this emissions unit, except the ESP may not be operated during periods of start up until the exhaust gases have achieved a temperature of 250 degrees Fahrenheit at the inlet of the ESP or during periods of shutdown when the temperature of the exhaust gases has dropped below 250 degrees Fahrenheit at the inlet of the ESP.

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect or require the coal supplier to collect a representative sample of coal for each shipment of coal which is received for burning in this emissions unit. The coal sampling shall be performed in accordance with ASTM method D2234, Collection of a Gross Sample of Coal.

Each sample of coal shall be analyzed for sulfur content (percent) and heat content (Btu/pound of coal). The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with the most recent version of the following ASTM methods: ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isotherm Bomb Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Northeast District Office.

2. The permittee shall maintain records of the total quantity of coal received and the results of the analyses for sulfur content and heat content for each shipment of coal received for burning in this emissions unit and the calculated weighted average sulfur dioxide emission rate (in lbs/mmBtu) for all shipments of coal during a calendar month.
3. The permittee shall properly operate and maintain equipment to continuously monitor the secondary voltage, in kilovolts and the secondary current, in amps, in all fields of the ESP while the emissions unit is in operation. The secondary voltage and secondary current monitors shall be calibrated, operated and maintained in accordance with the manufacturer's recommendations, instructions and operating manuals.

The permittee shall monitor and record the following on an hourly basis during any operation of the ESP:

- a. the secondary voltage, in kilovolts (kV), and the secondary current in amps, for each transformer rectifier (TR) set in the ESP;
  - b. the power input (in kilowatts) of each TR set for each hour (calculated by multiplying the secondary voltage (in kV) by the secondary current (in amps) for each TR set); and
  - c. the total power input to the ESP for each hour (add together the power inputs for the TR sets operating during the hour).
4. The permittee shall record the following information for each day:
    - a. all 3-hour blocks of time during which the average total combined power input to the ESP, when the emissions unit was in operation, was less than 90% of the total combined power input, as a 3-hour average, during the most recent emissions test that demonstrated the emissions unit was in compliance with the particulate emission limitation; and
    - b. the duration of the downtime for the monitoring equipment specified in Section A.III.3 above, the ESP sections that are out of service, and the duration of the downtime for each section, when the associated emissions unit was in operation.

### III. Monitoring and/or Record Keeping Requirements (continued)

5. If exemptions from the visible particulate emission limitations are requested during start up or shutdown of this emissions unit, the permittee shall operate and maintain a temperature monitor and recorder that measures and records the temperature of the boiler exhaust gases entering the ESP as follows:
  - a. during all periods of start up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i); and
  - b. during all periods of shutdown until the inlet temperature to the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i).

The temperature monitor and recorder shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in degrees Fahrenheit.

### IV. Reporting Requirements

1. The permittee shall notify the Director (the Ohio EPA, Northeast District Office) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated weighted average sulfur dioxide emission rates from Section A.III above. The notification shall include a copy of such record and shall be sent to the Director (the Ohio EPA, Northeast District Office) within 45 days after the deviation occurs.
2. The permittee shall submit deviation (excursion) reports which identify the following:
  - a. all 3-hour blocks of time during which the average total combined power input to all fields of the ESP does not comply with the operational restriction specified in Section A.II.2 of this permit; and
  - b. all periods of time during start up and shutdown of the emissions unit when the ESP was not in operation and the temperature of the boiler exhaust gases exceeded the temperature levels specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b)(i).

The deviation (excursion) reports shall be submitted in accordance with the General Terms and Conditions of this permit.

3. The permittee shall also submit quarterly reports which identify the sections of the ESP that were out of service along with the time period(s) involved.

### V. Testing Requirements

1. Compliance with the emission limitations in Section A.I of these terms and conditions shall be determined in accordance with the following methods:
2. Emission Limitation:  
Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method:

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

## V. Testing Requirements (continued)

3. Emission Limitation:  
Particulate emissions shall not exceed 0.20 pound per million Btu actual heat input.

Applicable Compliance Method:

The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate for particulate matter in accordance with the following requirements:

The emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Ohio EPA, Northeast District Office.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Northeast District Office.

4. Emission Limitation:  
Sulfur dioxide emissions shall not exceed 7.19 pounds per million Btu actual heat input.

Applicable Compliance Method:

Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

## VI. Miscellaneous Requirements

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock and Wilcox coal-fired boiler, having a rated heat input capacity of 50.0 million Btu per hour and controlled with an ESP.	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: BOILER #2 (B002)  
 Activity Description: BOILER #2

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock and Wilcox coal-fired boiler, having a rated heat input capacity of 50.0 million Btu per hour and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.20 pound per million Btu actual heat input.
	OAC rule 3745-18-53(F)(1)	See Section A.I.2.a below. Sulfur dioxide emissions shall not exceed 7.19 pounds per million Btu actual heat input.

##### 2. Additional Terms and Conditions

- The particulate emission limitation is based upon the total heat input from emissions units B001 and B002, pursuant to OAC rule 3745-17-10(B).

##### II. Operational Restrictions

- The quality of the coal burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation of 7.19 pounds per million Btu actual heat input.
- The average total combined power input (in kilowatts) to all fields of the ESP, for any 3-hour block of time when the emissions unit is in operation, shall be no less than 90% of the total combined power input, as a 3-hour average, during the most recent emissions test that demonstrated the emissions unit was in compliance with the particulate emission limitation.
- The permittee shall operate the ESP during any operation of this emissions unit, except the ESP may not be operated during periods of start up until the exhaust gases have achieved a temperature of 250 degrees Fahrenheit at the inlet of the ESP or during periods of shutdown when the temperature of the exhaust gases has dropped below 250 degrees Fahrenheit at the inlet of the ESP.

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect or require the coal supplier to collect a representative sample of coal for each shipment of coal which is received for burning in this emissions unit. The coal sampling shall be performed in accordance with ASTM method D2234, Collection of a Gross Sample of Coal.

Each sample of coal shall be analyzed for sulfur content (percent) and heat content (Btu/pound of coal). The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with the most recent version of the following ASTM methods: ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isotherm Bomb Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Northeast District Office.

2. The permittee shall maintain records of the total quantity of coal received and the results of the analyses for sulfur content and heat content for each shipment of coal received for burning in this emissions unit and the calculated weighted average sulfur dioxide emission rate (in lbs/mmBtu) for all shipments of coal during a calendar month.
3. The permittee shall properly operate and maintain equipment to continuously monitor the secondary voltage, in kilovolts and the secondary current, in amps, in all fields of the ESP while the emissions unit is in operation. The secondary voltage and secondary current monitors shall be calibrated, operated and maintained in accordance with the manufacturer's recommendations, instructions and operating manuals.

The permittee shall monitor and record the following on an hourly basis during any operation of the ESP:

- a. the secondary voltage, in kilovolts (kV), and the secondary current in amps, for each transformer rectifier (TR) set in the ESP;
  - b. the power input (in kilowatts) of each TR set for each hour (calculated by multiplying the secondary voltage (in kV) by the secondary current (in amps) for each TR set); and
  - c. the total power input to the ESP for each hour (add together the power inputs for the TR sets operating during the hour).
4. The permittee shall record the following information for each day:
    - a. all 3-hour blocks of time during which the average total combined power input to the ESP, when the emissions unit was in operation, was less than 90% of the total combined power input, as a 3-hour average, during the most recent emissions test that demonstrated the emissions unit was in compliance with the particulate emission limitation; and
    - b. the duration of the downtime for the monitoring equipment specified in Section A.III.3 above, the ESP sections that are out of service, and the duration of the downtime for each section, when the associated emissions unit was in operation.

### III. Monitoring and/or Record Keeping Requirements (continued)

5. If exemptions from the visible particulate emission limitations are requested during start up or shutdown of this emissions unit, the permittee shall operate and maintain a temperature monitor and recorder that measures and records the temperature of the boiler exhaust gases entering the ESP as follows:
  - a. during all periods of start up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i); and
  - b. during all periods of shutdown until the inlet temperature to the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i).

The temperature monitor and recorder shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in degrees Fahrenheit.

### IV. Reporting Requirements

1. The permittee shall notify the Director (the Ohio EPA, Northeast District Office) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated weighted average sulfur dioxide emission rates from Section A.III above. The notification shall include a copy of such record and shall be sent to the Director (the Ohio EPA, Northeast District Office) within 45 days after the deviation occurs.
2. The permittee shall submit deviation (excursion) reports which identify the following:
  - a. all 3-hour blocks of time during which the average total combined power input to all fields of the ESP does not comply with the operational restriction specified in Section A.II.2 of this permit; and
  - b. all periods of time during start up and shutdown of the emissions unit when the ESP was not in operation and the temperature of the boiler exhaust gases exceeded the temperature levels specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b)(i).

The deviation (excursion) reports shall be submitted in accordance with the General Terms and Conditions of this permit.

3. The permittee shall also submit quarterly reports which identify the sections of the ESP that were out of service along with the time period(s) involved.

### V. Testing Requirements

1. Compliance with the emission limitations in Section A.I of these terms and conditions shall be determined in accordance with the following methods:
2. Emission Limitation:  
Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method:

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

## V. Testing Requirements (continued)

3. Emission Limitation:  
Particulate emissions shall not exceed 0.20 pound per million Btu actual heat input.

Applicable Compliance Method:

The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate for particulate matter in accordance with the following requirements:

The emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Ohio EPA, Northeast District Office.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Northeast District Office.

4. Emission Limitation:  
Sulfur dioxide emissions shall not exceed 7.19 pounds per million Btu actual heat input.

Applicable Compliance Method:

Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

## VI. Miscellaneous Requirements

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock and Wilcox coal-fired boiler, having a rated heat input capacity of 50.0 million Btu per hour and controlled with an ESP.	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** BOILER #3 (B003)  
**Activity Description:** BOILER #3

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock and Wilcox natural gas and/or number two fuel oil-fired boiler, having a rated heat input capacity of 61.5 million Btu per hour.	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-18-53(F)(2)	Sulfur dioxide emissions shall not exceed 0.36 pound per million Btu actual heat input.
	OAC rule 3745-17-10(B)(1)	Particulate emissions shall not exceed .020 pound per million Btu actual heat input.

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

- The permittee shall burn only natural gas and/or number two fuel oil in this emissions unit.
- The quality of the oil burned in this emissions unit shall meet a sulfur content which is sufficient to comply with the allowable sulfur dioxide emission limitation of 0.36 pound per million Btu of actual heat input.

**III. Monitoring and/or Record Keeping Requirements**

- For each day during which the permittee burns a fuel other than natural gas and/or number two fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
- The permittee shall collect or require the oil supplier to collect a representative grab sample for each shipment of oil that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analysis for sulfur content and heat content in accordance with the most recent versions of the following ASTM methods: ASTM method D4294, ASTM method D240, or ASTM method 6010 for sulfur content; and ASTM method D240 for heat content. Alternative, equivalent methods may be used upon written approval by the Ohio EPA, Northeast District Office.

### III. Monitoring and/or Record Keeping Requirements (continued)

3. For each shipment of oil received for burning in this emissions unit, the permittee shall maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). (The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).) Also, if necessary, the permittee shall maintain monthly records of the calculated sulfur dioxide emission rate based upon a volume-weighted average of the calculated sulfur dioxide emission rates for all shipments of oil during a calendar month.

### IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas and/or number two fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. The permittee shall notify the Director (the Ohio EPA, Northeast District Office) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon a volume-weighted average of the calculated sulfur dioxide emission rates from section A.III above. The notification shall include a copy of such record and shall be sent to the Director (the Ohio EPA, Northeast District Office) within 45 days after the deviation occurs.

### V. Testing Requirements

1. Compliance with the emission limitations in Section A.I of these terms and conditions shall be determined in accordance with the following methods:
2. Emission Limitation:  
Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule

Applicable Compliance Method:

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

3. Emission Limitation:  
Particulate emissions shall not exceed .020 pound per million Btu actual heat input.

Applicable Compliance Method:

When firing number two fuel oil, compliance shall be determined by multiplying an emission factor of 2.0 lbs of particulates/1000 gallons of oil fired by the emissions unit's maximum hourly fuel oil firing capacity (439.28 gallons/hr) and dividing by the emissions unit's rated heat input capacity (61.5 mmBtu/hr). This emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.3, Table 1.3-1 (9/98).

When firing only natural gas, compliance shall be determined by multiplying an emission factor of 1.9 lbs of particulates/mm standard cu. ft. by the emissions unit's maximum hourly natural gas firing capacity (.0615 mm standard cu. ft./hr) and dividing by the emissions unit's rated heat input capacity (61.5 mmBtu/hr). This emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(9), while firing number two fuel oil.

## **V. Testing Requirements (continued)**

4. Emission Limitation:  
Sulfur dioxide emissions shall not exceed 0.36 pound per million Btu actual heat input.

Applicable Compliance Method:

When firing fuel oil, except as provided below, compliance with the allowable sulfur dioxide emission limitation shall be demonstrated by documenting that the sulfur content of each shipment of oil received during a calendar month meets the limitation.

If the sulfur content of each shipment of oil received during a calendar month does not comply with the allowable emission limitation on an "as-received" basis, compliance with the allowable sulfur dioxide emission limitation shall be based upon a volume-weighted average of the calculated sulfur dioxide emission rates for all of the shipments of oil during the calendar month.

When firing only natural gas, compliance with this limitation will be assumed due to the negligible percent sulfur, by weight, in the fuel.

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6, while firing number two fuel oil.

## **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock and Wilcox natural gas and/or number two fuel oil-fired boiler, having a rated heat input capacity of 61.5 million Btu per hour.	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

\*\*\*\*\*

**THIS IS THE LAST PAGE OF THE PERMIT**

\*\*\*\*\*