



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 22, 2006

RE: Geauga County
Federated Church Family Life Center
Transient, Non-Community
PWSID#: 2868812

Federated Church Family Life Center
Attn: Ms. Toni A. Cirino
76 Bell Street
PO Box 60
Chagrin Falls, Ohio 44022-0060

Dear Ms. Cirino :

Hand Delivery

Federated Church Family Life Center public water system has violated Ohio's safe drinking water laws. Specifically, Federated Church Family Life Center exceeded the maximum contaminant level (MCL) for nitrate (as nitrogen).

Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.

To resolve your drinking water violations and avoid possible legal action and civil penalties:

- 1) Within fourteen (14) days of receipt of a "chemical letter" concerning chemical well analysis along with detailed plan information from Ohio Environmental Protection Agency (signifying approval of the designated option outlined in your letter to Corey Kurjian on May 11, 2006), submit detail plans to address nitrate in drinking water.
- 2) Within thirty (30) days of detail plan approval, initiate and install said plan.
- 3) Within thirty (30) days of completion of installation of detail plan, Federated Church Family Life Center will be in compliance with the MCL and monitoring requirements for nitrate in accordance with Ohio Administrative Code (OAC) Rules 3745-81-11(A) and 3745-81-23(H)(1).
- 4) Within three hundred sixty (360) days of the effective date of this agreement, contract the services of a Class A or higher classification operator as required by OAC Rule 3745-7-02.

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director



Sincerely,

Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Ken Baughman at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Ken Baughman at (614) 644-2752.

Toni A. Cirino
Director of Operations

6-22-06
Date

- 1) Within fourteen (14) days of receipt of a "chemical letter" concerning chemical well analysis along with detailed plan information from Ohio Environmental Protection Agency (signifying approval of the designated option outlined in your letter to Cory Kujala on May 17, 2006), submit detail plans to address nitrate in drinking water.
- 2) Within thirty (30) days of detail plan approval, install and install said plan.
- 3) Within thirty (30) days of completion of installation of detail plan, Federated Church Family Life Center will be in compliance with the MCL and monitoring requirements for nitrate in accordance with Ohio Administrative Code (OAC) Rules 3745-81-1(A) and 3745-81-23(H)(1).
- 4) Within three hundred sixty (360) days of the effective date of this agreement, contract the services of a Class A or higher classification operator as required by OAC Rule 3745-T-02.