



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 22, 2006

Re: Summit County
Mogadore Baptist Church and
Christian Academy
Non-Transient, Non-Community
PWSID: 7728012

Mr. Lewis A. Hayslip, Head Trustee
3750 Albrecht Ave.
Mogadore, Ohio 44260

Hand Delivery

Dear Mr. Hayslip:

Mogadore Baptist Church and Christian Academy's public water system has violated Ohio's safe drinking water laws. Specifically, Mogadore Baptist Church and Christian Academy exceeded the monthly and acute maximum contaminant level (MCL) for total coliform bacteria, failed to conduct routine and repeat total coliform bacteria monitoring, failed to develop a total coliform bacteria sample siting plan and failed to issue public notices for many of these violations.

Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code (ORC) Section 6109.33.

To resolve your drinking water violations and avoid possible legal action and civil penalties:

- 1) Immediately comply with the MCL requirements for total coliform bacteria, in accordance with Ohio Administrative Code (OAC) Rule 3745-81-14.
- 2) Monitor for total coliform bacteria with a minimum of one routine sample per calendar quarter from the distribution system and perform any required repeat monitoring, in accordance with OAC Rule 3745-81-21.
- 3) Comply with the monitoring and reporting requirements in accordance with the 2006 chemical monitoring schedules.
- 4) By March 8, 2006, post a public notice for past total coliform and volatile organic chemical monitoring violations and submit a copy of the public notices and verification forms to Ohio Environmental Protection Agency (Ohio EPA), Northeast District Office (NEDO), Division of Drinking and Ground Waters (DDAGW), Attn: Ursula Mussleman, 2110 E. Aurora Road, Twinsburg, Ohio 44087-1969, in accordance with OAC Rule 3745-81-32.

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

- 5) By March 8, 2006, develop a total coliform bacteria sample siting plan and submit a copy to Ohio EPA, NEDO, DDAGW, in accordance with OAC Rule 3745-81-21.

Sincerely,



Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Larry Reeder at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Larry Reeder at (614) 644-2752.



Lewis Hayslip
Head Trustee

2-22-06
Date