



State of Ohio Environmental Protection Agency

RECEIVED
DDAGP

05 NOV 14 11:10:28

STREET ADDRESS:

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 3, 2004

RE: Athens County
Sunday Creek Valley
Water District
Community
PWSID#: 0501503

Milton Cooksey

~~Gary Young~~, President
Sunday Creek Valley Water District
15945 Second Street
Millfield, Ohio 45761

Dear Mr. *Cooksey* ~~Young~~:

Hand Delivery

The Sunday Creek Valley Water District (Sunday Creek) public water system has violated Ohio's safe drinking water laws. Specifically, Sunday Creek has exceeded the total trihalomethanes (TTHM) maximum contaminant level (MCL), has failed to monitor for TTHM and haloacetic acids five (HAA5), has failed to monitor for asbestos, has failed to monitor for total coliform bacteria, and has failed to notify the public of violations.

Owners or operators of public water systems that fail to comply with Ohio's safe drinking water laws and regulations are subject to civil penalties of up to \$25,000 per day per violation under Ohio Revised Code Section 6109.33.

To resolve your drinking water violations and avoid possible legal action and civil penalties:


- 1) Monitor for total coliform bacteria with a minimum of one routine sample per month from the distribution system and perform any required repeat monitoring, in accordance with Ohio Administrative Code (OAC) Rule 3745-81-21.
- 2) Monitor for TTHM and HAA5 with a frequency of one sample per calendar quarter at locations(s) representing maximum residence time (MR001) in accordance with OAC Rule 3745-81-78(C)(2).
- 3) By December 1, 2005, post public notices for the total coliform monitoring violations, for the asbestos monitoring violation, for the failure to monitor for TTHM and HAA5, and for exceeding the TTHM MCL. Notices should be posted for no less than seven (7) days in accordance with OAC Rule 3745-81-32. Send the public notices to:

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

Ohio Environmental Protection Agency (EPA), Southeast District
Office (SEDO), Division of Drinking and Ground Waters, Attn: Jeff
Crisler, 2195 Front Street, Logan, Ohio, 43138.


- 4) By January 1, 2006, submit a Distribution System Optimization Plan to Ohio EPA, SEDO. Within thirty (30) days of receipt, respond to comments from SEDO on the Distribution System Optimization Plan.
- 5) By April 1, 2006, implement the agreed upon Distribution System Optimization Plan in accordance with OAC Rule 3745-81-78(G)(2).
- 6) After being supplied with water from Burr Oak Regional Water District (Burr Oak), monitor quarterly for TTHM and haloacetic acids five (HAA5) until the running annual average (RAA) is below the MCL. Take the sample at the PWS's MR001 location to confirm the lowering of TTHM and HAA5. After TTHM and HAA5 RAA's are below the MCL, continue monitoring for TTHM and HAA5 in accordance with OAC Rule 3745-81-24, unless notified otherwise.
- 7) No later than twelve (12) months from the date that Burr Oak begins supplying water from its ground water plant, Sunday Creek will be in compliance with the TTHM MCL.

Sincerely,



Michael G. Baker, Chief
Division of Drinking and Ground Waters

If it is your intent to comply with the safe drinking water laws and regulations in the manner specified, please sign this document and return it to the attention of Emily Cushman at Ohio EPA, DDAGW, Lazarus Government Center, P.O. Box 1049, Columbus, Ohio 43216-1049, within fourteen (14) days. Your signature is not considered an admission of guilt, only an indication of your intention to address the violations noted. Ohio EPA reserves its right to seek civil penalties pursuant to Revised Code 6109.33 for the violations described in this letter. If you have any questions concerning this letter, please call Emily Cushman at (614) 644-2752.


Mr. Gary Young, President
Sunday Creek Valley Water District

10-8-05
Date

Milton Cooksey