

**3745-54-33 Testing and maintenance of equipment.**

All facility communications or alarm systems, fire protection equipment, spill control equipment, and decontamination equipment, where required, shall be tested and maintained as necessary to assure its proper operation in time of emergency.

Effective: 04/15/1981  
119.032 review dates: Exempt  
Promulgated under: 119.03  
Statutory authority: 3734.12  
Rule amplifies: 3734.12  
Prior effective dates: None