

3745-55-76 Special requirements for ignitable or reactive waste.

Containers holding ignitable or reactive waste must be located at least fifteen meters (fifty feet) from the facility's property line.

[Comment: See paragraph (A) of rule 3745-54-17 of the Administrative Code for additional requirements.]

Effective: 01/07/1983
119.032 review dates: Exempt
Promulgated under: 119.03
Statutory authority: 3734.12
Rule amplifies: 3734.12
Prior effective dates: None