

ACTION: No Change

(no-change
filed 2011)

DATE: 11/30/2011 9:09 AM

3745-65-33

Testing and maintenance of equipment.

All facility communications or alarm systems, fire protection equipment, spill control equipment, and decontamination equipment, where required, must be tested and maintained as necessary to assure its proper operation in time of emergency. The owner or operator must record the inspections in a log or summary.

R.C. 119.032 review dates: 11/30/2011 and 08/25/2016

CERTIFIED ELECTRONICALLY

Certification

11/30/2011

Date

Promulgated Under: 119.03
Statutory Authority: 3734.12
Rule Amplifies: 3734.12 (D)(2), (D)(3), (D)(9)
Prior Effective Dates: 04/15/1981, 01/07/1983, 04/01/1990, 02/11/1992,
10/20/1998, 03/13/2002, 05/13/2007

*current effective
date, per LSC*