

3745-66-76 Special requirements for ignitable or reactive waste.

Containers holding ignitable or reactive waste shall be located at least fifteen meters (fifty feet) from the facility's property line.

Effective: 01/07/1983

119.032 Review dates: Exempt

Promulgated under: 119.03

Statutory authority: 3734.12

Rule amplifies: 3734.12

Prior effective dates: 04/15/1981