

**USED OIL INSPECTION CHECKLIST
GENERATORS, COLLECTION CENTERS AND AGGREGATION POINTS**

NOTE: A facility is subject to the federal SPCC regulations (40 CFR 112) if it is non-transportation related (e.g., fixed) and has an aggregate above ground storage capacity greater than 1,320 gallons or a total underground storage capacity greater than 42,000 gallons of oil (including used oil), and there is reasonable expectation of a discharge to navigable waters.

PROHIBITIONS

1.	Does the generator manage used oil in a surface impoundment or waste pile? If yes:	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
a.	Is the surface impoundment or waste pile regulated as a hazardous waste management unit? [3745-279-12(A)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>

NOTE: For example, used oil contaminated scrap metal stored in a pile.

2.	Is used oil used as a dust suppressant? [3745-279-12(B)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
3.	Is off-specification used oil fuel burned for energy recovery in devices specified in 3745-279-12(C)?	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>

NOTE: Multiple used oil checklists may be applicable if used oil handler is performing multiple tasks (e.g., If generating used oil and shipping directly to a burner, complete generator and marketer checklists at a minimum).

GENERATOR STANDARDS

4.	Does the generator mix hazardous waste with used oil? If so,	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
a.	Is the mixture managed as specified in 3745-279-10(B)? [3745-279-21(A)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>

NOTE: Used Oil mixed with listed (3745-51-30 to 3745-51-35) or characteristic (3745-51-20 to 3745-51-24) hazardous waste are subject to regulation as a hazardous waste, unless the listed hazardous waste is listed solely because it exhibits a hazardous characteristic, and the resultant mixtures do not exhibit a characteristic. Mixtures of used oil and CESQG hazardous waste are subject to OAC Chapter 3745-279.

5.	Does the generator of a used oil containing greater than 1,000 ppm total halogens manage the used oil as a hazardous waste unless the presumption is rebutted successfully? [3745-279-21(B)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
----	--	---

NOTE: If used oil contains greater than 1000 ppm total halogens, it is presumed to be listed hazardous waste until the presumption is successfully rebutted.

6.	Does the generator store used oil in tanks; or containers; or a unit(s) subject to regulation as a hazardous waste management unit? [3745-279-22(A)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
7.	Are containers and aboveground tanks used to store used oil in good condition with no visible leaks? [3745-279-22(B)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
8.	Are containers, above ground tanks, and fill pipes used for underground tanks clearly labeled or marked "Used Oil?" [3745-279-22(C)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
9.	Has the generator, upon detection of a release of used oil, done the following: [3745-279-22(D)]	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
a.	Stopped the release?	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
b.	Contained the release?	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
c.	Cleaned up and properly managed the used oil and other materials?	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>
d.	Repaired or replaced the containers or tanks prior to returning them to service, if necessary?	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>

ON-SITE BURNING IN SPACE HEATER

10.	Does the generator burn used oil in used-oil fired space heaters? [3745-279-23] If so:	
a.	Does the heater burn only used oil that owner/operator generates or used oil received from household do-it-yourself (DIY) used oil generators?	Yes <input type="checkbox"/> No <input type="checkbox"/> N/A <input type="checkbox"/>

	b.	Is the heater designed to have a maximum capacity of not more than 0.5 million BTU per hour?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>
	c.	Are the combustion gases from heater vented to the ambient air?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>

NOTE: Ash accumulated in a space heater must be managed in accordance with 3745-279-10(E).

GENERATOR TRANSPORTATION

11.		Does the generator have the used oil hauled only by transporters that have obtained a U.S. EPA ID#? [3745-279-24]	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>
12.		If the generator self-transport used oil to an approved collection site or to an aggregation point owned by the generator: [3745-279-24]			
	a.	Does the generator transport used oil in a vehicle owned by the generator or an employee of the generator? [3745-279-24]	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>
	b.	Does the generator transport more than 55 gallons of used oil at any time? [3745-279-24]	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>

NOTE: Used oil generators may arrange for used oil to be transported by a transporter without a U.S. EPA ID # if the used oil is reclaimed under a contractual agreement (i.e., tolling arrangement).

COLLECTION CENTERS AND AGGREGATION POINTS

13.		Is the DIY used oil collection center in compliance with the generator standards in 3745-279-20 to 3745-279-24? [3745-279-30]	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>
14.		Is the non-DIY used oil collection center registered with Ohio EPA? [3745-279-31]	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>
15.		Is the used oil aggregation point in compliance with the generator standards in 3745-279-20 to 3745-279-24? [3745-279-32]	Yes <input type="checkbox"/>	No <input type="checkbox"/>	N/A <input type="checkbox"/>

NOTE: Complete Used Oil Generator and any other applicable used oil handler checklist (e.g., marketer, burner, etc.) for used oil collection centers and aggregation points.