

*** DRAFT – NOT FOR FILING ***

3745-511-460 Leachate holding tanks.

[Comment: Pursuant to rule 3745-42-11 of the Administrative Code, industrial waste holding tanks, including leachate holding tanks, are also required to obtain a permit through Ohio EPA, division of surface water.]

- (A) Leachate holding tanks shall be designed to have a minimum storage capacity of ten times the anticipated daily amount of leachate to be removed during normal operations. The anticipated daily amount does not include surface water diverted to the leachate collection system during construction of the contiguous leachate management system engineered components.

- (B) Metal leachate holding tanks shall incorporate cathodic protection.

- (C) The foundation of an above-ground holding tank shall be capable of supporting the holding tank when the tank is full of leachate without compromising the integrity of any engineered component.

- (D) Leachate load-out facilities shall be designed to meet the following:
 - (1) Be protected from damage caused by freezing and facility operations.

 - (2) Prevent releases of leachate from load-out facilities.

 - (3) Contain spills and facilitate spill cleanup.