



General Storage of Scrap Tires Inspection Checklist

Facility Name		
Address		
Date	Time	Weather
Inspection Representatives		
Facility		
Health District		
Ohio EPA		
Other		
Inspection Type	Reason for Inspection	
<input type="checkbox"/> Comprehensive	<input type="checkbox"/> Required	<input type="checkbox"/> Other
<input type="checkbox"/> Focused	<input type="checkbox"/> Re-Inspection	

Is the above site being operated in compliance with the following regulations? Please mark the box in the appropriate column to denote compliance status. Marking the box in the NO column indicates that a violation has been noted. Please mark the N/A box if not applicable to this location. This checklist is not all inclusive of regulations applicable to scrap tires.

Y	N	N/A		Y	N	N/A	
			3745-27-05 Prohibited disposal methods				(c) Piles of ≤ 500 ST are ≥ 25 ft away from buildings and other tire piles
			(B) No open burning				(d) Piles of ≥ 500 ST separated by fire lanes ≥56 ft.
			3745-27-60 Storage standards				(e) Fire lanes passable to emergency vehicles
			(B) Storage standards				(8) Inside storage of whole and processed ST:
			(1) Sufficient drainage				(a) Pile size ≤ 2500 ft ² and total # of tires < amt. in OAC 3745-27-61(A)
			(2) Sufficient separation from ignition sources ≥50 ft				(b) Aisles between piles ≥ 8 ft
			(3) Sufficient separation of portable containers				(c) At least 3 ft between top of pile and sprinklers
			(4) Sufficient separation of multiple portable containers from the following:				(d) At least 3 ft between top of pile and roof
			(a) Buildings owned/leased by person storing ST ≥15 ft				(e) At least 3 ft between top of pile and ductwork
			(b) Other buildings not owned by person storing ST:				(9) ST not stored under bridges, elevated trestles, elevated roadways, elevated RR or under power lines with > 750 volts or that supply power to fire emergency system
			(i) Portable containers >51 yd ³ separation of >56 ft				(11) Fire breaks free of combustible material
			(ii) Roll off containers >25 ft				(C) Mosquito control
			(5) No storage by submergence				(1) Do one or more of the following:
			(6) ST not covered by soil unless at a beneficial use site per OAC 3745-27-78				(a) Remove liquids within 24 hrs of accepting ST
			(7) Outside storage of whole and processed ST:				(b) ST stored not to allow water accumulation
			(a) Pile size ≤ 2500 ft ² and total # of tires < amt. in OAC 3745-27-61(A)				(c) If ST contain water, arrange for pesticide application
			(b) Pile height ≤ 8 ft				

