

Ohio EPA Policy	Permits to Install; Policy for Addressing Wastewater Facilities at Camp Sites	
DSW-0200.007 Removed	Statutory reference: Rule reference:	Ohio EPA, Division of Surface Water Revision 0, August 1, 1988 Removed, April 30, 2003
THIS POLICY DOES NOT HAVE THE FORCE OF LAW Pursuant to Section 3745.30 of the Revised Code, this policy was reviewed and removed.		

This policy does not meet the definition of policy contained in Section 3745.30 of the Ohio Revised Code. Ohio EPA is removing this document from the Division of Surface Water Policy Manual and is considering addressing this topic in a future rulemaking.

For more information contact:

Ohio EPA, Division of Surface Water
Permits & Compliance Section
P.O. Box 1049
Columbus, OH 43216-1049
(614) 644-2001

THIS POLICY DOES NOT HAVE THE FORCE OF LAW

NUMBER: DSW-0200.007
ISSUED: 8-1-88
STATUS: FINAL
DIVISION: DSW
PAGE: 1 OF 2

Permits to Install: Policy For Addressing Wastewater Facilities At Camp Sites

APPLICABLE

REGULATIONS: ORC 6111.04, 44, 45, 46

ATTACHMENTS: 1 (1 pg.)

PURPOSE: To provide guidelines for determining whether Ohio EPA involvement is required in reviewing proposals and/or issuing permits to install.

POLICY: The following shall be applied in determining whether Ohio EPA involvement is required in reviewing proposals and/or issuing permits to install.

1. If a recreation camp, recreational vehicle park, or a combined park/camp proposes a wastewater system hookup to each site, Ohio EPA must approve the wastewater system.
2. If a recreation camp, recreational vehicle park, or combined park/camp does not provide a water supply to the individual site, privies with a minimum of 1,000 gallon water-tight vaults of portable toilets with specified cleaning schedules would be acceptable. An installation designed as specified on the enclosed sheets (wastewater drains or alternative wastewater drains) would be acceptable for receiving waste from dishwashing and handwashing by campground users. Installation of wastewater facilities would be subject to Ohio EPA review and approval. The portable toilets are to be considered temporary facilities and will be regulated by the local health department. No approval is required for wastewater drains unless the proposal indicates installation in a flood plain.
3. At recreational vehicle parks and combined park/camps with water supply facilities to the site, Ohio EPA will consider the flow characteristics specified on the attached schedule (worksheet for recreational facilities). If other information is available indicating higher usage rates (water bills for existing sites, etc.) the higher rates shall prevail. Ohio EPA would approve the wastewater system. Pump out facilities would be subject to Ohio EPA review and approval.
4. At marinas, privies with minimum 1,000 gallon water-tight vaults or portable toilets with specified cleaning schedules would be acceptable. Installation of privies of other wastewater facilities would be subject to Ohio EPA review and approval.

Portable toilets are to be considered temporary facilities and will be regulated by the local health departments.

Any water supply system which serves fifteen or more service connections or which regularly serves 25 or more individuals daily

NUMBER: DSW-0200.007
ISSUED: 8-1-88
STATUS: FINAL
DIVISION: DSW
PAGE: 2 OF 2

at least sixty days out of the year is a public water system. Most recreation camps, recreational vehicle parks, combined park/camps, and marinas which have their own water supply will fall under this definition.

Plans for public water systems must be approved by the director of the Ohio Environmental Protection Agency. The operation of public water systems are supervised by the Ohio EPA Division of Public Water Supply according to the rules of the Ohio EPA.

Please refer any such systems to the public water supply unit in the district office.

**WORKSHEET FOR
RECREATIONAL FACILITIES**

Recreational Vehicle Parks/Camps

- A) Usage Factors based upon facilities plan
 - 1) Water to sites for standard R. V.'s and campers -
50 gal per day/per site served
 - 2) Park Model R.V. Sites or Older Mobile Homes -
250 gal. per day/per site served
 - 3) Hand Sinks
10 gal. per day/per site served
 - 4) Showers
 - A) 30 gal. per day/per site served
 - B) 15 gal. per day/per site served (restricted flow)
 - 5) Waste Closets or Urinals
 - A) 60 gal. per day/per site served
 - B) 35 gal. per day/per site served (low flow design)
 - 6) Other Facilities
 - A) Flow based upon design usage or -
 - B) Flow criteria previously established in Ohio EPA Design Guidelines.

- B) Usage Factors are all additive for design of new parks and camps and are limiting on expansion or alteration of existing parks and camps.