

Ohio EPA Policy DSW-0200.008 Removed	Permits to Install; Policy for Addressing Wastewater Facilities at Food Service Operations	
	Statutory reference: Rule reference:	Ohio EPA, Division of Surface Water Revision 0, August 1, 1988 Removed, April 30, 2003
THIS POLICY DOES NOT HAVE THE FORCE OF LAW Pursuant to Section 3745.30 of the Revised Code, this policy was reviewed and removed.		

This policy does not meet the definition of policy contained in Section 3745.30 of the Ohio Revised Code. Ohio EPA is removing this document from the Division of Surface Water Policy Manual and is considering addressing this topic in a future rulemaking.

For more information contact:

Ohio EPA, Division of Surface Water
Permits & Compliance Section
P.O. Box 1049
Columbus, OH 43216-1049
(614) 644-2001

THIS POLICY DOES NOT HAVE THE FORCE OF LAW

NUMBER: DSW-0200.008
ISSUED: 8-1-88
STATUS: FINAL
DIVISION: DSW
PAGE: 1 OF 1

Permits to Install; Policy For Addressing Wastewater Facilities At Food Service Operations

PURPOSE: To provide a policy on addressing the installation of wastewater facilities at food service operations

POLICY: Sewage treatment works for food service operations, as defined by ORC 3732.01(A) and modified by)Ac 3701-21-01(L), shall consist of, as a minimum, a trash trap, extended aeration, surface sand filters, disinfection, and discharge to a suitable receiving stream, except as noted below.

When a suitable receiving stream is not available, wastewater treatment works for food service operations may discharge to a tile field system if the tile field is designed to comply with Ohio EPA requirements by a registered engineer, soil scientist, or geologist with expertise in soil science after bedrock elevations, if encountered, have been identified by augers or observation pits providing:

- 1) Aerobic treatment works discharging to a tile field shall consist of, as a minimum, a trash trap, extended aeration, and surface sand filters.
- 2) Anaerobic treatment works discharging to a tile field may be approved providing:
 - a) Average daily flow to the tile field must not exceed 1,000 gallons.
 - b) The PTI is conditioned with all or part of a special condition:

"For purposes of licensing a food service operation, this permit applies to a wastewater disposal system: 1) designed to serve an average daily flow of no more than ___ gallons; 2) conditioned that garbage grinders are not permitted; and #) conditioned that the septic tanks and grease traps shall be adequately maintained."

All aerobic approvals should be conditioned by appropriate average daily hydraulic flow using condition e of EPA 4463, Terms and Conditions: "This permit applies to a wastewater disposal system designed to serve an average daily hydraulic flow of no more than ___ gallons" or a condition similar to 2(b) above.