

3745-52-253

Testing and maintenance of equipment - preparedness, prevention, and emergency procedures for large quantity generators.

All communications or alarm systems, fire protection equipment, spill control equipment, and decontamination equipment, where required, shall be tested and maintained as necessary to assure proper operation in time of emergency.

Effective: 10/5/2020

Five Year Review (FYR) Dates: Exempt

CERTIFIED ELECTRONICALLY

Certification

09/21/2020

Date

Promulgated Under: 119.03
Statutory Authority: 3734.12
Rule Amplifies: 3734.12