

3745-55-94 General operating requirements.

- (A) Hazardous waste or treatment reagents must not be placed in a tank system if they could cause the tank, its ancillary equipment, or the containment system to rupture, leak, corrode, or otherwise fail.
- (B) The owner or operator must use appropriate controls and practices to prevent spills and overflows from tank or containment systems. These include, at a minimum:
 - (1) Spill prevention controls (e.g., check valves, dry disconnect couplings);
 - (2) Overfill prevention controls (e.g., level sensing devices, high level alarms, automatic feed cutoff, or bypass to a standby tank); and
 - (3) Maintenance of sufficient freeboard in uncovered tanks to prevent overtopping by wave or wind action or by precipitation.
- (C) The owner or operator must comply with the requirements of rule 3745-55-96 of the Administrative Code if a leak or spill occurs in the tank system.

Effective: 12/08/1988

119.032 review dates: Exempt

Promulgated under: 119.03

Statutory authority: 3734.12

Rule amplifies: 3734.12

Prior effective dates: 01/07/1983, 01/30/1986