

3745-65-33

**Testing and maintenance of equipment.**

All facility communications or alarm systems, fire protection equipment, spill control equipment, and decontamination equipment, where required, ~~must~~shall be tested and maintained as necessary to assure ~~its~~ proper operation of the equipment in time of emergency. The owner or operator ~~must~~shall record the inspections in a log or summary.

Effective: 2/12/2018

Five Year Review (FYR) Dates: 10/30/2017 and 02/12/2023

CERTIFIED ELECTRONICALLY

---

Certification

01/10/2018

---

Date

Promulgated Under: 119.03

Statutory Authority: 3734.12

Rule Amplifies: 3734.12

Prior Effective Dates: 04/15/1981, 01/07/1983, 04/01/1990, 02/11/1992,  
10/20/1998, 03/13/2002, 05/13/2007