

**3745-555-215      Conveyance pipes.**

This rule is applicable as specified in rule 3745-555-200 of the Administrative Code.

Conveyance pipes shall be designed to meet the following criteria:

- (A) Have a diameter and schedule capable of conveying the anticipated amount of fluid under anticipated operating pressures.
- (B) Be protected from damage caused by freezing temperatures, crushing, and deflection.
- (C) Be capable of being inspected for leaks.

Effective: 04/01/2017

Five Year Review (FYR) Dates: 04/01/2022

CERTIFIED ELECTRONICALLY

---

Certification

09/21/2016

---

Date

Promulgated Under: 119.03  
Statutory Authority: 3734.02  
Rule Amplifies: 3734.02