

Everyday WWTP
50 W. Town St., Columbus, OH 43215
(614) 644-2018
NPDES Permit #6PA00000

The material you are receiving is or contains biosolids that have been treated to meet the requirements in Chapter 3745-40 of the Ohio Administrative Code.

Most recent analysis of biosolids:

TKN =	35,000 mg/kg	Hg=	<1 mg/kg	As=	24 mg/kg	Cu=	500 mg/kg
NH ₄ =	7,000 mg/kg	Mb=	15 mg/kg	Cd=	<1 mg/kg	Pb=	75 mg/kg
Total P=	18,000 mg/kg	Zn=	1,300 mg/kg	Se=	4 mg/kg	Ni=	30 mg/kg
Total K=	3,000 mg/kg						

Pathogen Reduction Alternative P-1, Geometric Mean of Seven Fecal Coliform Samples, has been met.
Vector Attraction Reduction Option VAR-1, 38% Volatile Solids Reduction, has been met.

The biosolids you are receiving are Class B, and shall be further treated, stored, transferred, disposed of, or beneficially used in accordance with Chapter 3745-40 of the Ohio Administrative Code, which may be found here:
http://www.epa.state.oh.us/dsw/rules/3745_40.aspx

Treatment Plant Official Name (printed)

Treatment Plant Official Name (signature)

Date