

## Minimum Lead Service Line Inventory Data

For each service line served by the system, no matter the material or ownership status, water systems are asked to provide the following information. This table outlines the draft information to be included in the LSL inventory and LSL inventory reporting requirements are subject to change.

<b>Information</b>	<b>Required or Optional?</b>	<b>Data to be collected</b>
System Site Identification Number	Optional	<i>e.g., 101-5669, 123 Ohio Ave, etc.</i>
LCR Sample Monitoring Point (SMP) ID	Required	LCRXXX
		Not an LCR SMP
Locational Identifier	Required	Address
		Latitude/Longitude
Is service line metered?	Required	Yes
		No
		Unknown
Service Line Use	Required	Drinking
		Non-Drinking
		Combination (Drinking and Non-Drinking)
Lead gooseneck/pigtail currently present?	Required	Yes
		No
		Unknown
Was a lead gooseneck/pigtail previously connected to this service line?	Required	Yes
		No
		Unknown
Current Utility Side SL Material	Required	Lead
		Copper
		Galvanized
		Plastic
		Ductile Iron
		Lined Cast Iron
		Unlined Cast Iron
		Unknown - May be Lead
		Unknown - No Lead
Other – please describe		
Utility Side SL Verification Method	Required	Records Only
		Field Inspection Only
		Records Validation
		Records Invalidation
		Statistical Analysis
		Other – please describe
Previously Lead?	Required	Yes

		No
		Unknown
Utility Service Line Diameter	Optional	<i>e.g., 1 inch</i>
Utility Side Installation/ Replacement Date	Optional	<i>e.g., 1974</i>
Current Customer SL Material	Required	Lead
		Copper
		Galvanized
		Plastic
		Ductile Iron
		Lined Cast Iron
		Unlined Cast Iron
		Unknown – May be Lead
		Unknown – No Lead
Customer Side Verification Method	Required	Records Only
		Field Inspection Only
		Records Validation
		Records Invalidation
		Statistical Analysis
		Other – please describe
		Records Only
Customer Side Installation/ Replacement Date	Optional	<i>e.g., 1974</i>
Building Type	Optional	Single Family Structure
		Multi-Family Residential
		Elementary School
		Secondary School
		Childcare Center
		Nonresidential
		Other
Building Construction Date	Optional	<i>e.g., 1974</i>
Building Plumbing Material 1	Optional	Lead Internal Plumbing
		Copper with Lead Solder
		Copper withOUT Lead Solder
		Other – No Lead
Building Plumbing Material 2	Optional	Lead Internal Plumbing
		Copper with Lead Solder
		Copper withOUT Lead Solder
		Other – No Lead
Point of Entry (POE) or Point of Use (POU) Treatment	Required	Yes
		No
		Unknown

Comments	Optional	e.g., Building abandoned, service line permanently disconnected from customer side, site currently under investigation by health department for elevated blood lead levels, etc.
----------	----------	--